

TINDOUF, Algeria

WMO: 606560

Lat: 27.700N

Lon: 8.167W

Elev: 443

StdP: 96.12

Time Zone: 1.00 (E01)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 4.3	(c) 5.9	(d) -10.3	(e) 1.6	(f) 15.8	(g) -8.8	(h) 1.9	(i) 16.7	(j) 15.1	(k) 17.2	(l) 13.6	(m) 15.5	(n) 2.9	(o) 20	(p) 0.593

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.7	45.2	20.9	44.4	20.6	43.5	20.3	22.2	38.0	21.5	38.2	20.8	38.2	4.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.4	14.0	25.6	16.8	12.7	25.5	15.2	11.4	25.6	67.0	37.5	64.2	37.8	61.9	38.1	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 14.0	(b) 12.4	(c) 11.1	(e) 1.8	(f) 47.0	(g) 1.6	(h) 1.0	(i) 0.7	(j) 47.7	(k) -0.3	(l) 48.3	(m) -1.2	(n) 48.9	(o) -2.4	(p) 49.7		
(4) 14.0	(5) 12.4	(6) 11.1	(7) -1.3	(8) 24.0	(9) 1.6	(10) 0.9	(11) -2.5	(12) 24.6	(13) -3.4	(14) 25.1	(15) -4.4	(16) 25.6	(17) -5.6	(18) 26.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.1	13.7	16.0	20.2	23.1	26.0	30.1	35.4	34.8	30.2	25.2	19.0	14.7
	DBStd	7.92	2.37	2.68	3.12	3.45	4.12	4.06	3.30	2.97	3.45	3.32	3.23	2.33
	HDD10.0	3	2	1	0	0	0	0	0	0	0	0	0	0
	HDD18.3	381	143	74	17	3	0	0	0	0	0	1	29	114
	CDD10.0	5141	117	168	316	392	494	603	787	769	606	471	271	147
	CDD18.3	2477	1	8	74	144	237	353	529	511	356	213	50	2
	CDH23.3	38492	31	165	974	1941	3492	5624	9278	8755	5174	2477	542	38
	CDH26.7	25558	2	27	359	982	2108	3875	6988	6437	3331	1274	171	3
Wind	WSAvg	5.4	4.5	5.0	5.5	6.7	6.8	6.6	5.4	5.2	5.6	4.6	4.5	4.2
Precipitation	PrecAvg	56	3	7	3	1	2	1	1	5	6	19	4	4
	PrecMax	185	24	81	35	15	30	9	10	25	54	175	44	30
	PrecMin	3	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	46	5	18	8	3	6	2	2	8	13	42	10	7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.1	29.5	35.0	37.5	41.7	44.9	46.8	45.8	43.3	38.1	33.2	26.3
		MCWB	12.4	13.5	16.0	17.2	18.9	20.9	21.2	21.2	20.3	17.9	16.2	13.8
	2%	DB	24.0	27.0	32.1	35.9	40.1	43.2	45.9	44.9	42.0	36.4	30.8	24.1
		MCWB	11.5	12.7	15.4	16.8	18.7	20.3	21.2	20.8	19.9	17.7	15.4	12.6
	5%	DB	22.2	25.2	30.2	34.1	38.1	41.9	45.0	44.0	40.3	35.0	28.8	22.8
		MCWB	10.9	11.9	14.2	16.2	17.9	19.8	20.7	20.5	19.3	17.4	14.9	12.2
	10%	DB	20.9	23.8	28.6	32.2	36.1	40.1	44.1	43.0	38.8	33.2	26.6	21.0
		MCWB	10.3	11.4	13.6	15.4	17.1	19.2	20.4	20.2	19.0	17.1	13.9	11.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.4	15.7	18.1	19.0	20.9	22.5	22.4	23.5	22.7	20.5	18.3	16.1
		MCDB	21.9	23.5	28.3	32.6	32.7	39.9	42.6	37.9	31.9	28.3	29.6	21.6
	2%	WB	12.8	14.2	16.4	17.5	19.3	21.1	21.5	22.4	21.5	19.6	16.8	14.4
		MCDB	20.6	23.0	28.2	31.9	34.1	38.5	42.2	37.5	33.8	29.0	26.6	21.1
	5%	WB	11.9	13.1	15.2	16.4	18.3	20.3	20.9	21.6	20.7	18.8	15.7	13.2
		MCDB	20.2	22.2	27.3	30.8	33.9	37.8	41.5	38.0	34.5	29.3	25.8	20.2
	10%	WB	10.9	12.1	14.2	15.6	17.5	19.5	20.4	20.9	19.9	18.2	14.7	12.2
		MCDB	19.3	21.7	26.2	29.6	33.0	36.8	40.7	38.4	34.9	29.1	24.7	19.5
Mean Daily Temperature Range	5% DB	MDBR	14.1	14.5	15.1	15.8	16.8	17.6	16.7	15.3	14.6	13.8	13.7	13.0
		MCDBR	16.1	16.7	17.0	17.5	17.5	16.5	16.2	15.5	15.6	15.2	15.4	14.7
		MCWBR	7.5	7.1	6.5	6.0	5.8	4.7	4.5	4.5	4.9	5.1	6.1	6.8
	5% WB	MCDBR	14.6	14.7	15.2	16.5	16.5	16.5	15.9	14.2	13.8	12.9	13.8	13.0
		MCWBR	7.0	6.5	6.1	5.9	5.6	5.2	4.6	4.3	4.7	4.8	6.1	6.5
Clear-Sky Solar Irradiance	taub		0.348	0.401	0.467	0.473	0.495	0.556	0.679	0.652	0.566	0.478	0.396	0.369
	taud		2.190	2.009	1.828	1.842	1.805	1.685	1.474	1.540	1.708	1.889	2.077	2.141
	Ebn at Noon		883	860	823	831	810	758	668	682	728	771	819	838
	Edh at Noon		125	162	207	210	219	245	302	281	230	181	139	126
All-Sky Solar Radiation	RadAvg		4.32	5.18	6.25	7.14	7.68	7.84	7.53	6.96	6.10	5.19	4.42	3.88
	RadStd		0.21	0.28	0.23	0.23	0.32	0.24	0.14	0.16	0.33	0.28	0.17	0.20

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.41	N/A	-1.89	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page