

DJANET TISKA, Algeria

WMO: 606700

Lat: 24.293N

Lon: 9.452E

Elev: 968

StdP: 90.22

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.7	3.1	-14.0	1.3	12.6	-12.1	1.5	12.8	12.1	19.4	10.1	16.9	0.8	350	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.0	40.1	18.7	39.1	18.4	38.4	18.1	21.7	34.7	20.5	34.2	19.5	34.3	4.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.2	13.9	29.0	15.3	12.2	29.1	13.7	11.0	28.7	68.0	34.7	63.6	33.9	59.8	34.2	27.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.3	9.7	8.4	-1.6	41.7	2.2	0.8	-3.1	42.3	-4.4	42.8	-5.6	43.3	-7.2	43.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.6	11.9	14.8	19.6	25.4	29.5	31.6	31.5	31.3	29.8	24.7	18.5	13.8	
	DBStd	7.69	3.07	3.55	3.72	3.07	2.57	2.13	1.51	1.53	1.91	2.94	2.96	3.13	
	HDD10.0	19	13	2	0	0	0	0	0	0	0	0	0	4	
	HDD18.3	522	202	108	31	0	0	0	0	0	0	1	34	146	
	CDD10.0	4973	71	138	297	463	606	649	667	660	593	455	254	121	
	CDD18.3	2433	1	10	69	213	348	399	409	402	343	198	38	4	
	CDH23.3	36035	27	163	862	2752	5123	6291	6594	6348	5002	2313	493	66	
CDH26.7	21527	3	38	294	1426	3124	4086	4285	4057	3018	1083	108	6		
Wind	WSAvg	3.3	2.2	2.7	3.4	3.9	4.0	3.9	4.2	3.8	3.6	2.9	2.2	2.0	
Precipitation	PrecAvg	16	1	1	2	1	3	2	1	1	2	2	0	0	
	PrecMax	54	14	9	24	9	25	24	11	10	17	15	2	2	
	PrecMin	3	0	0	0	0	0	0	0	0	0	0	0	0	
	PrecStd	12	3	2	5	2	6	5	2	2	4	3	0	0	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.2	30.9	33.2	37.9	40.0	41.6	41.0	40.1	39.1	36.1	30.9	27.3	
		MCWB	12.2	13.2	14.6	17.3	18.4	19.3	18.6	19.4	18.7	16.8	14.2	12.4	
	2%	DB	23.2	27.2	31.7	36.1	38.9	40.2	39.9	39.1	38.0	34.8	29.1	25.1	
		MCWB	10.5	12.0	13.9	16.5	18.1	18.7	18.4	18.7	17.9	16.6	13.8	11.4	
	5%	DB	21.2	25.0	29.9	34.9	37.8	39.1	39.0	38.2	37.2	33.3	27.9	23.2	
		MCWB	9.5	11.2	13.2	16.1	17.6	18.3	18.3	18.3	17.5	16.3	13.4	10.5	
	10%	DB	19.7	23.1	28.1	33.2	36.6	38.1	38.0	37.3	36.3	32.0	26.2	21.5	
		MCWB	8.9	10.2	12.5	15.5	17.2	18.0	17.9	17.8	17.3	15.8	12.6	9.9	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.6	14.4	16.5	19.0	22.4	22.6	22.8	23.1	21.6	19.2	17.0	14.1
			MCDB	21.6	25.0	25.6	33.4	35.2	36.1	36.1	36.0	31.8	30.5	27.4	22.9
2%		WB	11.7	13.1	15.1	17.6	19.9	20.7	20.9	21.3	20.1	18.1	15.2	12.6	
		MCDB	21.0	24.1	25.7	32.8	34.1	34.7	34.1	34.8	33.4	29.4	26.4	22.2	
5%		WB	10.4	12.0	14.0	16.7	18.6	19.4	19.4	20.2	19.0	17.4	14.0	11.4	
		MCDB	19.8	22.4	27.0	32.0	34.0	34.9	35.7	34.3	33.6	29.7	26.2	21.3	
10%		WB	9.2	10.7	13.0	15.9	17.7	18.6	18.3	19.2	18.2	16.7	13.0	10.4	
		MCDB	18.5	21.7	27.0	31.3	33.9	35.1	36.1	34.2	33.8	29.6	25.3	20.5	
Mean Daily Temperature Range	5% DB	MDBR	15.4	15.3	14.8	14.3	13.3	12.6	13.0	12.7	13.2	13.6	15.0	15.1	
		MCDBR	16.3	16.7	16.2	15.1	14.0	13.2	13.9	13.0	13.6	13.9	15.5	16.0	
		MCWBR	8.8	7.9	7.1	6.1	5.1	4.5	5.2	4.8	5.0	5.5	7.2	8.1	
	5% WB	MCDBR	15.4	15.0	13.9	13.4	12.6	12.2	13.1	12.3	12.4	13.0	14.7	14.9	
		MCWBR	8.7	7.8	6.7	5.9	5.2	4.7	5.6	5.0	4.9	5.3	7.4	8.4	
Clear-Sky Solar Irradiance	taub		0.320	0.353	0.451	0.556	0.623	0.621	0.486	0.511	0.510	0.474	0.386	0.330	
	taud		2.260	2.154	1.848	1.637	1.536	1.555	1.836	1.796	1.787	1.856	2.058	2.238	
	Ebn at Noon		937	926	847	768	715	711	814	794	784	789	849	907	
	Edh at Noon		120	144	206	260	287	279	211	219	216	192	147	119	
All-Sky Solar Radiation	RadAvg		4.69	5.49	6.55	7.12	7.34	7.63	7.98	7.40	6.74	5.70	4.82	4.34	
	RadStd		0.23	0.33	0.35	0.30	0.34	0.32	0.18	0.22	0.23	0.24	0.17	0.20	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page