

MERTOUEK, AlgeriaWMO: **606720**Lat: **24.227N**Lon: **5.540E**Elev: **4406**StdP: **12.50**Time Zone: **1.00 (E01)**Period: **08-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	36.6	39.5	-6.6	4.5	62.1	-2.8	5.6	61.7	22.7	59.2	19.4	57.4	3.1	330	0.392

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	99.6	58.5	98.2	58.4	97.0	58.3	63.5	84.0	62.5	85.7	61.6	86.2	5.0	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.8	81.1	71.8	53.8	72.5	73.9	50.9	65.1	76.1	31.2	84.0	30.4	84.9	29.7	85.9	67.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.7	16.2	14.1	DB	31.8	102.1	3.4	0.8	29.4	102.7	27.4	103.2	25.5	103.6	23.0	104.3	(4)
(5)			WB	24.1	65.6	3.1	1.4	21.9	66.6	20.1	67.4	18.4	68.2	16.2	69.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	73.2	54.1	59.4	65.7	74.4	82.7	86.9	88.2	86.4	83.6	74.8	64.7	56.7
	DBStd	12.94	5.42	6.95	6.33	5.32	3.80	3.55	2.78	2.66	2.99	4.05	4.34	5.62
	HDD50	40	21	8	2	0	0	0	0	0	0	0	0	9
	HDD65	913	340	182	71	2	0	0	0	0	0	0	56	262
	CDD50	8509	148	271	488	733	1013	1107	1186	1128	1007	769	442	217
	CDD65	3906	2	25	93	285	548	657	721	663	557	304	47	4
	CDH74	54328	14	214	907	3388	7513	10094	11238	9631	7551	3252	461	65
	CDH80	29449	0	42	160	1352	4014	6163	6980	5543	4017	1149	27	2
Wind	WSAvg	4.6	4.3	4.8	5.2	5.6	5.3	4.6	4.7	4.4	3.8	3.9	4.5	4.2
Precipitation	PrecAvg	3.5	0.1	0.1	0.3	0.1	0.2	0.4	0.4	0.8	0.5	0.3	0.2	0.1
	PrecMax	7.1	0.7	0.4	2.0	0.5	1.4	2.0	1.7	2.8	1.6	2.2	2.8	0.8
	PrecMin	1.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0
	PrecStd	1.3	0.2	0.1	0.5	0.1	0.2	0.5	0.4	0.6	0.4	0.5	0.5	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.0	85.3	86.4	95.8	97.7	101.3	101.1	99.6	97.0	92.6	82.7	79.1
		MCWB	48.6	51.9	52.6	56.1	57.9	58.3	58.9	59.4	58.8	56.9	53.7	49.2
	2%	DB	72.6	80.0	84.0	92.0	96.1	99.9	99.5	97.7	95.5	90.2	80.5	75.8
		MCWB	46.9	50.2	51.5	55.2	57.4	58.2	58.7	59.3	58.5	56.6	52.3	48.2
	5%	DB	69.7	75.9	81.7	89.7	94.8	98.5	98.2	96.3	94.4	88.1	78.6	72.4
		MCWB	45.4	48.2	50.8	54.0	56.9	58.0	58.5	59.1	58.3	56.2	51.3	47.2
	10%	DB	67.0	73.1	79.3	87.2	93.3	96.9	96.9	95.0	93.1	86.1	76.9	69.6
		MCWB	44.3	46.8	50.1	53.3	56.3	57.8	58.3	59.0	58.1	55.6	50.6	45.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.8	53.7	56.3	58.6	61.1	63.6	64.8	64.8	63.9	61.1	56.6	51.5
		MCDB	70.0	72.4	71.1	84.0	86.6	83.4	81.8	84.0	81.3	75.1	76.0	69.8
	2%	WB	49.0	52.1	54.8	56.9	59.8	62.1	63.1	63.6	62.5	59.7	54.3	50.0
		MCDB	67.7	73.6	74.1	85.5	87.8	85.2	85.5	84.9	84.1	78.1	74.3	70.7
	5%	WB	46.6	50.2	53.3	55.8	58.8	60.9	61.7	62.6	61.5	58.6	52.8	48.3
		MCDB	67.8	72.2	75.6	85.2	88.4	87.0	88.6	86.3	84.6	80.3	74.3	70.2
	10%	WB	44.7	48.2	51.7	54.5	57.7	59.9	60.4	61.7	60.6	57.5	51.6	46.7
		MCDB	66.7	70.3	76.6	83.9	89.0	88.9	90.5	86.7	85.1	80.9	74.2	68.6
Mean Daily Temperature Range		MDBR	23.0	22.7	22.2	22.0	19.9	19.4	17.8	18.2	19.6	21.1	22.1	22.1
	5% DB	MCDBR	25.5	24.7	24.0	23.5	20.8	20.5	19.0	19.0	20.2	22.4	24.1	25.4
		MCWBR	12.3	11.3	9.9	8.8	7.5	6.4	6.1	6.2	6.1	7.5	10.3	11.5
	5% WB	MCDBR	22.8	21.7	18.7	20.1	18.8	19.6	18.4	19.1	19.8	19.8	20.4	22.8
		MCWBR	11.6	10.4	7.4	7.6	6.4	5.5	6.2	5.9	5.6	6.1	8.9	10.5
Clear-Sky Solar Irradiance	taub	0.282	0.312	0.401	0.473	0.553	0.587	0.498	0.522	0.510	0.443	0.350	0.297	
	taud	2.431	2.334	2.021	1.845	1.685	1.633	1.830	1.793	1.817	1.968	2.223	2.406	
	Ebn at Noon	313	309	284	266	243	233	255	249	249	260	283	303	
	Edh at Noon	32	38	55	67	78	82	67	70	67	54	39	32	
All-Sky Solar Radiation	RadAvg	1536	1765	2101	2292	2336	2345	2424	2239	2048	1785	1555	1427	
	RadStd	74	94	128	113	90	128	86	75	93	108	54	60	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	+1.04	+1.75	+3.28	+5	N/A	N/A	+130

Nomenclature: See separate page