

AFARA, Algeria

WMO: 606770

Lat: 25.333N

Lon: 7.800E

Elev: 1240

StdP: 87.29

Time Zone: 1.00 (E01)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -0.6	(c) 1.1	(d) -21.8	(e) 0.6	(f) 12.4	(g) -19.5	(h) 0.8	(i) 13.9	(j) 8.3	(k) 20.2	(l) 6.0	(m) 17.7	(n) 0.0	(o) N/A	(p) 0.366

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.3	(c) 38.6	(d) 15.4	(e) 37.8	(f) 15.3	(g) 37.1	(h) 15.2	(i) 18.2	(j) 28.5	(k) 17.5	(l) 29.8	(m) 16.9	(n) 30.8	(o) 0.5	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.4	12.8	21.7	13.4	11.1	23.0	11.3	9.7	23.7	56.6	27.3	54.0	29.3	52.0	30.4	21.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 7.2	(b) 5.7	(c) 4.1	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	22.3	10.7	13.3	17.8	23.6	27.9	30.9	31.3	30.3	28.4	23.2	17.2	12.2	(6)
(7)		DBStd	7.86	2.91	3.95	3.82	3.11	2.50	1.75	1.52	1.55	2.00	2.45	2.72	2.86	(7)
(8)		HDD10.0	49	25	12	1	0	0	0	0	0	0	0	0	11	(8)
(9)		HDD18.3	689	238	149	57	2	0	0	0	0	1	52	191		(9)
(10)		CDD10.0	4526	46	102	243	407	556	627	659	629	551	411	217	79	(10)
(11)		CDD18.3	2125	1	7	41	158	297	377	401	371	301	153	19	1	(11)
(12)		CDH23.3	32111	14	126	640	2112	4267	6119	6583	5718	4338	1802	336	56	(12)
(13)		CDH26.7	18314	0	28	188	951	2406	3901	4230	3451	2418	701	38	3	(13)
(14)	Wind	WSAvg	0.5	0.3	0.1	0.2	0.9	0.9	0.8	0.0	0.1	0.4	0.7	0.6	0.5	(14)
(15)	Precipitation	PrecAvg	42	4	2	4	2	3	4	1	5	5	6	2	3	(15)
(16)		PrecMax	83	21	12	21	11	23	23	7	24	25	38	26	15	(16)
(17)		PrecMin	15	0	0	0	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	14	5	2	6	3	4	6	2	6	6	8	5	3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.9	29.8	32.0	36.4	38.1	39.7	39.3	38.5	36.9	34.2	29.0	27.0	(19)
(20)			MCWB	9.8	11.2	12.2	13.9	15.1	15.6	15.5	15.9	15.4	14.6	12.7	10.4	(20)
(21)		2%	DB	23.2	26.9	30.4	34.4	37.1	38.8	38.3	37.2	36.1	32.9	27.9	25.1	(21)
(22)			MCWB	8.4	10.2	11.4	13.6	15.0	15.3	15.4	15.9	15.2	14.4	12.1	9.8	(22)
(23)		5%	DB	21.2	24.5	28.9	32.9	36.1	38.1	37.7	36.5	35.4	31.7	26.7	22.8	(23)
(24)			MCWB	7.7	9.0	11.1	12.9	14.8	15.2	15.3	15.8	15.1	14.0	11.4	8.7	(24)
(25)		10%	DB	19.6	22.6	27.1	31.6	35.0	37.2	36.9	35.7	34.6	30.5	25.5	20.7	(25)
(26)			MCWB	6.9	8.4	10.7	12.4	14.4	15.1	15.2	15.6	14.9	13.6	10.9	8.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.6	12.2	14.3	15.9	17.2	17.6	17.9	19.8	19.0	16.9	14.4	11.6	(27)
(28)			MCDWB	21.0	25.2	23.3	29.6	29.4	32.9	30.1	25.5	24.4	22.8	26.5	22.3	(28)
(29)		2%	WB	9.4	11.1	13.2	14.7	16.4	16.6	16.8	18.5	18.0	16.1	12.9	10.2	(29)
(30)			MCDWB	20.8	22.9	23.9	29.2	31.0	33.4	32.6	28.7	25.8	25.6	25.6	23.2	(30)
(31)		5%	WB	8.0	10.2	12.3	14.0	15.8	16.1	16.2	17.6	17.2	15.5	12.1	9.3	(31)
(32)			MCDWB	20.5	20.9	24.5	30.4	31.9	34.6	34.2	31.1	28.1	26.5	24.4	22.0	(32)
(33)		10%	WB	7.1	9.0	11.2	13.2	15.2	15.7	15.7	17.0	16.6	14.9	11.4	8.3	(33)
(34)			MCDWB	19.4	21.5	26.0	29.4	32.2	34.8	34.7	31.9	29.0	27.0	23.7	20.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	17.3	15.9	15.2	14.2	13.0	12.3	11.3	11.4	12.3	13.5	15.7	16.5	(35)
(36)			MCDBR	19.2	18.1	17.7	15.4	14.0	13.4	12.6	12.3	13.1	14.4	16.7	19.3	(36)
(37)			MCWBR	10.2	8.7	7.9	6.1	5.1	4.5	4.5	3.9	4.3	4.8	7.1	9.8	(37)
(38)		5% WB	MCDWB	17.9	15.4	14.3	12.9	12.7	12.0	11.2	11.6	11.8	12.3	14.7	18.1	(38)
(39)			MCWBR	9.7	7.8	6.0	4.8	4.3	3.7	3.7	3.3	3.0	3.6	6.2	9.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.293	0.328	0.427	0.506	0.581	0.595	0.476	0.497	0.506	0.453	0.363	0.309	(40)	
(41)		taud	2.426	2.310	1.969	1.793	1.658	1.646	1.917	1.884	1.855	1.974	2.209	2.397	(41)	
(42)		Ebn at Noon	969	952	867	807	745	729	821	804	785	807	874	933	(42)	
(43)		Edh at Noon	101	122	182	222	254	255	194	200	201	169	125	100	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.72	5.48	6.58	7.06	7.21	7.47	7.90	7.22	6.49	5.60	4.80	4.35	(44)	
(45)		RadStd	0.21	0.30	0.39	0.34	0.32	0.39	0.23	0.31	0.31	0.35	0.18	0.20	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page