

TAMANRASSET ASSEKREM, Algeria

WMO: 606790

Lat: 23.260N

Lon: 5.632E

Elev: 8891

StdP: 10.55

Time Zone: 1.00 (E01)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.4	32.9	-37.4	0.9	45.0	-30.0	1.4	45.5	51.7	37.6	46.2	38.2	19.3	350	0.614

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	14.1	77.9	47.8	76.5	47.7	75.3	47.6	53.4	66.3	52.4	65.9	51.5	65.7	11.9	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
48.6	70.9	59.0	46.5	65.5	59.8	44.7	61.0	60.1	25.9	66.4	25.2	66.2	24.6	65.5	57.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 41.8	35.8	30.2	DB	21.4	80.8	5.4	0.9	17.5	81.4	14.4	81.9	11.3	82.4	7.4	83.0	(4)
(5)			WB	18.1	56.3	3.3	0.6	15.8	56.7	13.9	57.1	12.0	57.4	9.7	57.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	57.6	44.4	46.7	51.8	59.2	65.2	68.3	68.1	66.1	64.7	58.7	51.5	46.4	(6)
(7)		DBStd	9.55	4.71	5.89	5.68	4.47	3.51	3.06	2.67	2.58	2.55	3.44	3.36	5.06	(7)
(8)		HDD50	503	181	121	48	1	0	0	0	0	0	0	22	130	(8)
(9)		HDD65	3030	639	514	409	181	40	10	7	19	34	197	404	576	(9)
(10)		CDD50	3289	7	27	104	276	471	548	561	498	441	268	69	19	(10)
(11)		CDD65	340	0	0	0	5	46	108	103	52	25	1	0	0	(11)
(12)		CDH74	585	0	0	0	6	58	256	196	62	7	0	0	0	(12)
(13)		CDH80	2	0	0	0	0	0	1	1	0	0	0	0	0	(13)
(14)	Wind	WSAvg	13.6	14.0	16.5	16.1	15.3	13.6	11.7	12.6	11.9	12.1	12.2	14.7	12.6	(14)
(15)	Precipitation	PrecAvg	6.8	0.2	0.1	0.7	0.2	0.4	0.7	0.7	1.8	1.0	0.6	0.4	0.1	(15)
(16)		PrecMax	13.5	1.5	0.7	4.9	0.9	1.9	3.1	3.1	3.7	2.6	3.8	5.4	1.0	(16)
(17)		PrecMin	2.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	2.9	0.4	0.2	1.4	0.3	0.6	0.8	0.8	1.2	0.9	1.0	1.2	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.4	67.5	67.7	74.9	77.5	79.9	79.4	77.4	74.7	70.9	64.5	62.3	(19)
(20)			MCWB	36.9	41.4	41.2	45.2	47.5	47.9	48.2	49.1	47.9	46.1	42.2	38.9	(20)
(21)		2%	DB	56.8	61.5	65.5	72.1	75.7	78.2	77.5	75.8	73.5	69.0	61.4	59.0	(21)
(22)			MCWB	36.0	39.6	40.7	44.5	47.3	47.6	47.9	48.9	47.9	45.8	40.8	36.9	(22)
(23)		5%	DB	54.2	57.9	63.2	70.0	74.1	76.9	76.2	74.2	72.2	67.4	59.4	56.3	(23)
(24)			MCWB	34.1	37.0	39.8	43.6	46.6	47.4	47.7	48.8	47.7	45.5	39.8	35.7	(24)
(25)		10%	DB	51.8	55.4	60.9	67.6	72.7	75.4	74.8	72.5	70.9	65.4	57.8	54.1	(25)
(26)			MCWB	32.8	35.8	39.1	42.4	45.9	47.3	47.6	48.8	47.4	44.8	39.1	34.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.0	43.1	44.9	48.0	51.9	53.5	54.9	54.9	53.1	50.7	45.9	43.2	(27)
(28)			MCD B	49.3	60.5	56.7	67.1	65.4	66.1	66.6	67.1	66.4	60.1	59.0	48.0	(28)
(29)		2%	WB	37.9	41.0	43.6	46.3	49.8	51.6	52.9	53.7	51.8	49.2	43.8	39.9	(29)
(30)			MCD B	52.3	58.3	57.1	65.8	67.3	66.5	66.5	66.5	66.4	61.1	55.6	53.7	(30)
(31)		5%	WB	35.6	39.1	42.1	45.1	48.6	50.4	51.6	52.8	50.7	47.8	42.2	37.7	(31)
(32)			MCD B	52.5	53.8	57.5	65.7	68.2	67.9	66.6	65.9	65.2	61.4	54.9	54.1	(32)
(33)		10%	WB	33.9	37.3	40.6	44.0	47.6	49.5	50.4	51.9	49.6	46.6	40.7	36.2	(33)
(34)			MCD B	50.9	52.4	58.4	65.0	68.4	68.7	67.2	65.3	64.6	61.2	54.9	52.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.9	14.3	15.2	14.9	14.4	14.1	13.8	13.7	13.2	13.0	12.7	13.9	(35)
(36)			MCD BR	14.4	14.8	16.1	15.4	14.6	14.8	14.4	14.8	13.7	13.7	13.6	14.5	(36)
(37)			MCWBR	7.5	7.6	7.3	6.6	6.1	5.7	5.8	6.0	5.7	5.7	6.7	7.4	(37)
(38)		5% WB	MCD BR	13.6	12.4	13.7	14.0	14.1	14.1	13.9	13.7	13.5	12.7	11.9	12.8	(38)
(39)			MCWBR	7.8	7.4	7.2	6.5	6.2	5.9	6.5	6.0	5.8	5.6	6.7	7.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.235	0.257	0.324	0.402	0.476	0.517	0.433	0.456	0.434	0.377	0.295	0.251	(40)	
(41)		taud	2.590	2.510	2.260	2.009	1.821	1.738	1.963	1.917	1.968	2.126	2.409	2.554	(41)	
(42)		Ebn at Noon	334	330	309	285	263	250	272	267	271	283	307	324	(42)	
(43)		Edh at Noon	28	32	43	57	69	74	59	62	57	47	33	28	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1586	1819	2148	2320	2327	2306	2390	2180	2028	1825	1609	1480	(44)	
(45)		RadStd	74	111	128	107	106	134	99	85	110	101	57	58	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	+1.04	+1.75	+3.28	+5	N/A	N/A	N/A	+130

Nomenclature: See separate page