

TAMANRASSET, Algeria

WMO: 606800

Lat: 22.800N

Lon: 5.433E

Elev: 4475

StdP: 12.47

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.1	39.5	-4.7	5.0	49.0	-0.6	6.3	52.1	29.5	56.1	25.4	58.5	3.1	20	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.8	98.9	61.1	97.2	60.6	96.6	60.5	66.4	83.0	65.0	84.0	63.8	85.0	11.4	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.1	94.9	74.2	58.8	87.4	75.3	55.7	77.9	76.1	33.7	82.7	32.5	84.0	31.5	84.5	71.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.5	22.6	20.1	31.4	102.4	2.8	3.0	29.3	104.5	27.7	106.3	26.1	107.9	24.1	110.1		
(5)			23.2	69.5	1.7	2.2	22.0	71.1	21.0	72.4	20.1	73.7	18.9	75.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	72.8	55.4	59.2	66.1	74.4	81.4	85.3	85.8	84.6	82.3	74.6	64.9	58.3		
	DBStd	11.69	4.64	5.29	5.49	4.85	3.90	3.01	2.65	2.73	2.80	3.94	3.83	4.54		
	HDD50	13	8	2	1	0	0	0	0	0	0	0	0	2		
	HDD65	787	300	174	53	1	0	0	0	0	0	0	48	211		
	CDD50	8322	174	260	501	732	974	1059	1110	1072	970	764	446	260		
	CDD65	3623	2	11	88	284	509	609	645	607	520	299	45	4		
	CDH74	48733	48	191	1127	3577	7046	8829	9368	8128	6572	3180	585	82		
	CDH80	25566	3	35	252	1539	3877	5180	5491	4493	3438	1200	56	2		
(14) Wind	WSAvg	8.6	7.2	8.0	9.2	9.5	9.8	9.6	9.9	9.3	8.7	8.1	6.6	6.7		
(15) Precipitation	PrecAvg	1.7	0.0	0.0	0.0	0.0	0.1	0.2	0.2	0.4	0.3	0.1	0.0	0.0		
	PrecMax	3.7	1.4	0.7	1.3	0.8	1.7	2.7	1.1	2.6	1.2	1.9	1.3	0.3		
	PrecMin	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	1.0	0.2	0.2	0.2	0.2	0.3	0.4	0.3	0.6	0.3	0.3	0.2	0.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.9	84.6	87.9	95.2	98.7	100.8	100.8	98.9	97.0	91.8	84.2	79.2		
		MCWB	51.7	54.0	55.3	59.2	61.0	61.2	61.6	61.8	61.1	58.5	54.2	50.6		
	2%	DB	74.8	79.0	84.9	92.9	96.8	99.0	98.8	97.1	95.2	89.9	81.3	76.5		
		MCWB	48.6	51.5	53.6	57.7	60.2	60.7	61.1	61.1	60.5	58.2	53.6	49.8		
	5%	DB	71.5	75.4	82.7	90.1	95.1	97.2	97.1	95.6	93.6	88.1	79.2	73.6		
		MCWB	46.8	49.2	52.8	56.6	59.4	60.3	60.6	60.9	60.1	57.6	52.6	48.6		
	10%	DB	68.9	73.2	80.6	88.0	93.4	96.0	95.9	94.6	92.8	86.2	77.3	71.4		
		MCWB	45.5	48.1	51.8	55.6	58.5	59.9	60.3	60.8	59.9	57.1	51.5	47.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.4	55.3	58.1	60.7	64.8	66.3	67.5	68.6	66.4	63.4	58.3	54.4		
		MCDB	70.4	77.2	72.8	87.7	85.7	85.3	84.8	83.0	81.2	77.4	77.9	69.0		
	2%	WB	50.5	52.7	55.8	58.9	62.8	63.8	65.3	66.9	64.5	61.6	55.5	52.0		
		MCDB	69.2	73.3	75.5	86.8	88.2	87.7	85.0	82.6	83.7	79.6	77.3	69.4		
	5%	WB	48.1	50.7	54.2	57.4	61.2	62.6	63.8	65.6	63.1	60.2	53.9	50.2		
		MCDB	68.2	71.5	77.2	86.0	89.1	88.6	86.3	82.9	85.2	81.0	76.7	70.2		
	10%	WB	46.1	48.7	52.6	56.1	59.9	61.6	62.6	64.3	62.0	58.8	52.5	48.5		
		MCDB	67.2	70.4	77.8	84.5	89.3	89.0	87.9	83.8	85.8	81.7	75.5	69.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	26.6	26.4	25.5	25.2	23.1	21.3	20.8	20.5	21.0	22.3	24.9	25.3		
		MCDBR	29.4	28.2	27.0	26.4	23.8	22.9	22.3	21.4	21.9	23.6	26.2	27.1		
		MCWBR	15.1	14.0	12.4	11.9	9.8	8.9	8.9	7.8	8.0	9.5	12.5	13.4		
		MCDBR	25.0	24.9	22.8	22.9	21.5	20.5	20.4	20.8	20.6	20.3	24.0	24.1		
	5% WB	MCWBR	14.3	13.2	12.1	11.1	9.8	8.3	8.1	7.5	7.7	8.6	12.1	12.5		
(40) Clear-Sky Solar Irradiance	taub		0.288	0.317	0.398	0.510	0.592	0.641	0.551	0.579	0.542	0.472	0.369	0.313		
	taud		2.442	2.347	2.052	1.774	1.619	1.547	1.723	1.689	1.756	1.899	2.167	2.366		
	Ebn at Noon		313	309	286	256	234	221	242	236	242	253	279	298		
	Edh at Noon		32	38	54	72	84	89	75	77	71	59	43	34		
(44) All-Sky Solar Radiation	RadAvg		1586	1815	2144	2326	2348	2329	2401	2218	2076	1849	1618	1478		
	RadStd		71	112	128	96	99	119	82	81	100	93	56	60		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+1.04	+1.75	+3.28	+5	N/A	N/A	+130
(47) Regional (2 neighbors)	N/A	N/A	N/A	+1.04	+1.75	+3.28	+5	N/A	N/A	+130

Nomenclature: See separate page