

TABARKA, Tunisia

WMO: 607100

Lat: 36.980N

Lon: 8.877E

Elev: 230

StdP: 14.57

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 39.2	(c) 41.2	(d) 32.3	(e) 26.9	(f) 52.6	(g) 35.2	(h) 30.3	(i) 52.4	(j) 34.1	(k) 55.1	(l) 30.8	(m) 55.7	(n) 7.1	(o) 80	(p) 0.432

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 19.2	(c) 102.0	(d) 70.9	(e) 96.9	(f) 71.1	(g) 92.8	(h) 70.8	(i) 78.7	(j) 85.5	(k) 77.3	(l) 84.9	(m) 76.0	(n) 84.1	(o) 8.4	(p) 350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.9	141.4	82.3	75.2	133.4	81.6	73.5	125.9	80.9	42.3	85.7	40.9	84.6	39.6	84.1	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 27.0	(b) 23.5	(c) 20.6	(e) 35.0	(f) 110.1	(g) 2.2	(h) 3.3	(i) 33.4	(j) 112.5	(k) 32.1	(l) 114.4	(m) 30.9	(n) 116.3	(o) 29.3	(p) 118.7		
(a) 27.0	(b) 23.5	(c) 20.6	(e) 34.3	(f) 80.9	(g) 2.2	(h) 1.7	(i) 32.7	(j) 82.1	(k) 31.5	(l) 83.0	(m) 30.2	(n) 84.0	(o) 28.7	(p) 85.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.5	53.2	53.2	56.7	61.1	67.3	73.8	78.8	79.8	74.8	69.5	61.4	55.6	(6)
	DBStd	10.76	4.37	4.76	5.09	5.14	5.87	6.11	5.29	5.43	5.06	5.34	5.09	4.37	(7)
	HDD50	48	18	19	4	0	0	0	0	0	0	0	1	6	(8)
	HDD65	1575	365	331	262	142	36	2	0	0	0	14	130	293	(9)
	CDD50	5706	118	108	213	333	536	715	891	922	743	605	343	179	(10)
	CDD65	1760	0	1	6	25	107	266	426	457	293	155	22	2	(11)
	CDH74	17460	1	9	85	249	985	2545	4730	5248	2432	1045	121	10	(12)
	CDH80	7478	0	0	21	70	403	1129	2146	2466	879	348	16	0	(13)
(14) Wind	WSAvg	8.6	9.7	9.9	9.9	9.6	9.0	8.0	7.9	7.4	7.4	7.3	8.4	9.3	(14)
(15) Precipitation	PrecAvg	42.0	6.3	5.0	4.0	3.6	1.9	0.7	0.2	0.6	2.6	4.2	6.5	6.7	(15)
	PrecMax	51.7	11.4	13.5	9.2	7.6	4.9	2.7	1.0	2.7	5.1	8.9	11.4	11.4	(16)
	PrecMin	22.6	1.9	0.3	0.1	1.3	0.4	0.0	0.0	0.0	0.0	0.6	2.2	2.4	(17)
	PrecStd	7.0	2.5	3.3	2.1	1.7	1.0	0.7	0.2	0.7	1.4	2.4	2.7	2.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.5	75.0	82.2	87.7	96.6	104.3	107.6	107.2	100.2	95.0	82.3	75.1	(19)
		MCWB	56.4	58.4	61.1	64.7	69.6	70.3	70.9	71.5	72.3	67.7	62.2	60.4	(20)
	2%	DB	66.5	68.6	75.4	80.8	89.8	97.0	101.6	101.3	93.5	87.9	77.2	69.6	(21)
		MCWB	55.7	56.3	59.3	62.4	66.8	70.4	70.7	71.2	71.1	67.7	61.1	57.6	(22)
	5%	DB	63.0	64.7	70.2	75.4	84.3	91.4	95.1	96.1	89.1	83.2	73.7	66.0	(23)
		MCWB	54.8	55.1	57.5	60.8	65.8	68.8	71.1	71.9	71.6	67.7	61.0	56.0	(24)
	10%	DB	60.9	61.6	66.4	71.1	79.0	86.2	89.7	91.2	84.5	79.1	70.6	63.0	(25)
		MCWB	54.3	54.5	56.8	59.5	63.9	69.1	71.5	72.8	71.4	67.5	60.8	56.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.8	60.5	64.1	67.1	72.2	76.7	80.2	80.9	78.6	74.6	68.1	62.0	(27)
		MCDB	65.1	68.6	75.5	80.7	87.5	86.6	86.4	86.9	85.7	82.2	74.1	68.1	(28)
	2%	WB	57.8	58.3	61.0	64.3	69.6	74.4	78.1	79.1	76.3	72.1	65.3	60.1	(29)
		MCDB	63.0	64.9	70.0	75.9	82.5	84.0	84.9	85.8	84.2	79.3	71.3	64.7	(30)
	5%	WB	56.4	56.8	59.3	62.6	67.8	72.8	76.6	78.0	74.5	70.5	63.6	58.8	(31)
		MCDB	61.5	62.5	67.0	70.8	78.2	82.5	84.3	85.2	82.4	77.8	69.5	63.6	(32)
	10%	WB	55.1	55.2	57.9	61.1	66.3	71.6	75.3	76.6	72.9	69.1	62.1	57.3	(33)
		MCDB	60.0	60.5	64.6	68.4	75.4	81.2	83.5	84.5	81.1	76.4	67.9	62.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	14.4	16.1	16.5	18.0	19.3	19.2	19.2	17.1	17.2	15.0	13.8	(35)
		MCDBR	18.7	20.8	24.7	25.8	28.1	29.3	29.6	28.0	24.3	24.0	20.6	19.6	(36)
		MCWBR	11.3	11.7	12.4	12.4	12.0	11.9	12.0	12.3	10.5	10.5	10.7	11.0	(37)
	5% WB	MCDBR	15.3	17.1	19.8	20.1	22.7	22.4	20.3	20.1	18.8	18.6	16.9	14.7	(38)
		MCWBR	10.4	11.0	11.4	11.2	11.1	11.4	11.7	11.9	10.5	10.2	10.2	9.6	(39)
(40) Clear-Sky Solar Irradiance	taub		0.352	0.372	0.425	0.470	0.491	0.460	0.487	0.476	0.466	0.431	0.387	0.359	(40)
	taud		2.416	2.350	2.184	2.081	2.058	2.185	2.109	2.142	2.179	2.234	2.331	2.393	(41)
	Ebn at Noon		262	271	265	259	255	263	254	254	249	246	246	250	(42)
	Edh at Noon		28	34	43	51	53	47	50	47	43	37	30	27	(43)
(44) All-Sky Solar Radiation	RadAvg		721	978	1383	1742	2058	2368	2372	2088	1570	1185	806	650	(44)
	RadStd		65	79	112	133	120	80	68	95	71	72	53	56	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page