

BIZERTE, Tunisia

WMO: 607140

Lat: 37.245N

Lon: 9.791E

Elev: 20

StdP: 14.69

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	38.9	41.0	33.7	28.3	47.4	36.2	31.4	47.1	31.9	53.8	28.8	54.7	3.6	340	0.475

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.5	98.7	73.3	94.8	73.3	91.5	73.2	79.9	87.3	78.1	86.1	76.6	85.1	11.2	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.4	147.6	83.6	75.9	135.6	81.4	74.1	127.4	80.6	43.4	88.1	41.4	86.4	40.0	85.5	89.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	23.9	21.3	34.5	106.8	2.0	3.4	33.1	109.3	31.9	111.2	30.8	113.1	29.4	115.6
			33.9	81.1	1.9	2.8	32.6	83.1	31.5	84.8	30.4	86.3	29.0	88.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.6	52.9	52.8	55.9	60.4	67.2	74.7	79.9	80.9	75.6	69.7	61.1	55.0
	DBStd	10.98	3.75	3.90	4.16	4.11	4.76	5.13	4.04	4.11	4.59	4.86	4.51	3.91
	HDD50	40	15	16	3	0	0	0	0	0	0	0	0	6
	HDD65	1628	376	343	282	147	28	1	0	0	0	11	131	309
	CDD50	5731	103	93	187	313	533	741	928	957	768	612	334	162
	CDD65	1843	0	0	1	9	96	291	463	492	318	158	15	0
	CDH74	17065	0	1	25	96	726	2591	4913	5332	2446	866	67	2
	CDH80	7053	0	0	5	16	218	1041	2261	2485	800	220	7	0
Wind	WSAvg	9.6	9.5	9.9	10.1	10.1	10.5	10.4	10.5	9.2	9.1	8.4	8.6	8.8
Precipitation	PrecAvg	25.2	3.5	3.1	2.2	2.0	0.9	0.4	0.1	0.4	2.1	2.5	3.7	4.2
	PrecMax	40.5	7.2	9.4	6.1	9.0	2.0	2.4	0.7	2.3	8.6	6.0	6.5	8.2
	PrecMin	15.7	0.8	0.0	0.0	0.2	0.2	0.0	0.0	0.0	0.3	0.1	1.4	0.9
	PrecStd	6.2	1.9	2.2	1.5	1.7	0.5	0.6	0.2	0.6	1.7	1.5	1.6	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.9	70.1	77.0	82.4	92.1	100.8	103.8	104.5	98.2	91.6	80.4	71.4
		MCWB	58.5	59.3	64.6	67.5	70.0	72.9	74.1	73.8	72.5	70.7	63.1	59.4
	2%	DB	64.3	65.9	71.0	76.6	85.8	94.6	98.1	98.6	91.8	85.6	75.4	66.6
		MCWB	57.4	57.6	60.8	63.5	68.0	72.0	73.3	74.4	73.9	71.2	64.3	59.1
	5%	DB	62.2	62.9	67.8	72.0	81.2	89.7	93.5	94.6	87.7	81.3	72.0	64.4
		MCWB	56.7	56.8	59.2	62.2	66.5	70.8	73.0	74.0	74.3	70.5	63.5	58.1
	10%	DB	60.4	60.8	64.6	69.4	77.4	85.8	90.0	91.2	84.3	78.6	69.7	62.5
		MCWB	55.3	55.3	57.8	61.2	65.3	70.3	73.2	74.2	72.8	69.6	62.6	57.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.5	61.7	66.0	70.1	74.2	79.0	81.7	82.8	80.7	76.8	70.7	63.8
		MCDB	64.4	66.9	73.8	78.1	86.6	87.5	88.1	89.0	86.8	82.1	74.2	66.2
	2%	WB	59.2	59.3	62.5	66.0	70.6	75.9	79.3	80.2	78.1	74.4	67.1	61.0
		MCDB	62.5	63.7	68.2	72.1	79.5	85.4	86.8	87.7	85.0	79.6	71.3	63.9
	5%	WB	57.4	57.5	60.3	63.9	68.5	73.7	77.3	78.3	76.1	72.6	65.2	59.4
		MCDB	61.1	61.7	65.7	70.2	77.0	83.4	86.2	86.3	83.0	77.8	69.8	62.9
	10%	WB	55.8	55.8	58.7	62.2	66.7	71.9	75.6	76.8	74.5	71.0	63.5	58.0
		MCDB	59.3	59.8	63.4	67.7	74.9	82.1	85.0	85.5	81.2	76.4	68.1	61.9
Mean Daily Temperature Range	5% DB	MDBR	14.1	15.1	17.0	17.3	18.7	19.5	19.5	19.5	16.8	16.9	15.3	14.3
		MCDBR	17.5	19.9	23.5	23.8	26.5	27.2	27.1	26.4	21.8	21.1	20.0	17.9
		MCWBR	12.3	13.3	14.5	13.6	12.1	10.2	10.0	9.6	8.8	9.9	11.2	11.9
	5% WB	MCDBR	16.0	18.1	20.6	20.8	22.1	23.0	21.8	21.2	19.2	18.2	17.3	15.6
		MCWBR	12.1	12.7	13.7	13.1	11.6	10.5	10.2	10.3	9.2	10.1	11.5	11.6
Clear-Sky Solar Irradiance	taub	0.352	0.369	0.417	0.460	0.477	0.445	0.468	0.458	0.454	0.425	0.385	0.358	
	taud	2.429	2.369	2.223	2.122	2.111	2.245	2.181	2.216	2.235	2.275	2.358	2.412	
	Ebn at Noon	262	272	267	262	259	266	259	259	253	248	246	251	
	Edh at Noon	28	33	42	49	50	44	46	44	41	36	30	26	
All-Sky Solar Radiation	RadAvg	712	971	1372	1741	2053	2329	2328	2048	1560	1171	799	644	
	RadStd	58	72	107	124	111	78	63	93	68	69	46	54	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page