

JENDOUBA, Tunisia

WMO: 607250

Lat: 36.483N

Lon: 8.800E

Elev: 472

StdP: 14.45

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 35.6	(c) 37.8	(d) 31.9	(e) 26.7	(f) 45.6	(g) 34.0	(h) 29.2	(i) 45.3	(j) 20.3	(k) 51.3	(l) 18.3	(m) 52.3	(n) 2.7	(o) 200	(p) 0.411

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.5	106.7	74.0	103.5	73.7	100.0	72.9	78.6	98.3	76.8	95.5	75.3	93.5	8.2	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.4	126.3	88.1	71.5	118.5	85.1	69.9	111.8	84.0	42.3	98.9	40.5	95.2	39.0	94.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	15.8	14.0	30.6	113.4	2.1	2.0	29.1	114.8	27.8	116.0	26.7	117.2	25.2	118.6
			30.3	80.8	2.2	2.6	28.7	82.7	27.4	84.3	26.2	85.7	24.5	87.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.1	51.1	51.7	55.5	60.9	69.2	78.1	83.8	83.7	76.9	69.2	59.4	52.9
	DBStd	12.94	4.20	4.38	4.78	4.79	6.11	6.45	5.01	4.86	5.64	5.52	4.79	4.43
	HDD50	99	36	29	10	1	0	0	0	0	0	0	2	21
	HDD65	1835	431	373	295	140	23	1	0	0	1	20	176	375
	CDD50	5988	70	76	181	327	597	844	1049	1045	806	596	285	112
	CDD65	2248	0	0	1	16	155	395	584	580	357	150	10	0
	CDH74	27427	1	4	58	304	1814	4812	7891	7545	3583	1326	84	5
	CDH80	15222	0	0	9	78	816	2731	4844	4510	1715	510	9	0
(14) Wind	WSAvg	6.0	5.8	6.2	6.0	6.1	6.3	6.6	6.7	6.3	5.8	5.0	5.6	5.6
(15) Precipitation	PrecAvg	18.6	2.4	2.2	2.1	1.7	1.3	0.7	0.2	0.6	1.4	1.8	2.0	2.4
	PrecMax	33.1	8.1	6.1	7.3	5.7	4.2	3.1	1.2	3.4	4.4	7.6	5.6	7.8
	PrecMin	9.6	0.2	0.0	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.3
	PrecStd	5.3	1.6	1.5	1.2	1.0	1.0	0.7	0.3	0.7	1.1	1.5	1.6	1.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.3	73.3	80.4	87.7	100.1	109.2	111.3	110.8	103.0	96.0	81.3	73.0
		MCWB	57.6	59.6	64.5	68.2	70.7	74.2	75.4	74.6	74.3	70.8	63.9	59.5
	2%	DB	65.8	68.5	74.7	81.5	93.3	103.8	106.9	106.1	98.3	90.0	76.5	67.6
		MCWB	55.5	58.2	62.3	65.4	69.4	73.2	74.7	74.0	73.0	69.3	62.7	56.9
	5%	DB	62.5	64.7	71.3	77.0	88.8	98.9	103.2	102.4	93.7	85.7	72.8	64.4
		MCWB	54.5	55.8	60.2	63.9	68.0	71.8	73.8	74.1	72.4	67.9	61.3	55.8
	10%	DB	59.4	61.3	67.6	73.3	84.1	94.3	99.2	98.6	89.6	81.0	69.6	61.5
		MCWB	53.2	54.1	58.5	61.9	66.4	70.9	72.9	73.5	71.2	67.0	60.1	55.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.8	62.3	68.0	70.7	74.3	77.9	81.3	81.0	78.7	75.0	67.5	61.0
		MCDB	67.5	69.6	77.2	82.6	92.5	100.1	102.3	100.4	94.0	87.7	75.0	69.2
	2%	WB	57.0	58.9	63.7	67.2	71.4	75.5	78.4	78.8	76.1	72.0	64.8	58.5
		MCDB	63.3	66.5	72.2	78.3	88.3	97.2	100.5	97.6	91.2	84.6	72.4	65.0
	5%	WB	55.3	56.6	61.1	64.7	69.4	73.7	76.3	77.0	74.4	70.1	62.9	57.0
		MCDB	61.0	63.7	69.0	75.0	85.4	93.9	96.8	94.9	88.9	81.3	70.6	62.7
	10%	WB	53.8	54.6	58.8	62.5	67.5	71.9	74.6	75.3	72.8	68.3	61.0	55.5
		MCDB	59.0	61.0	66.0	71.9	81.7	90.8	94.3	92.6	85.9	78.6	67.8	60.8
(35) Mean Daily Temperature Range	5% DB	MDBR	17.3	18.8	21.3	22.9	25.5	27.4	28.5	27.5	23.3	22.2	18.9	17.2
		MCDBR	23.3	25.9	29.8	32.2	34.1	35.7	35.5	34.5	29.7	30.5	25.2	22.4
	5% WB	MCWBR	14.9	16.4	18.4	18.0	14.4	13.6	13.4	13.6	11.5	13.3	14.0	13.9
		MCWBR	20.8	24.4	27.3	28.5	31.1	31.9	31.0	28.7	25.5	25.7	21.9	19.3
(40) Clear-Sky Solar Irradiance	taub		0.347	0.370	0.432	0.481	0.507	0.475	0.506	0.493	0.480	0.438	0.385	0.354
		taud	2.384	2.307	2.111	2.006	1.968	2.085	2.006	2.035	2.085	2.156	2.283	2.361
	Ebn at Noon		265	272	263	256	251	259	249	250	246	244	246	253
		Edh at Noon	29	35	47	55	58	51	55	53	48	41	32	28
(44) All-Sky Solar Radiation	RadAvg		745	984	1377	1722	2034	2363	2391	2097	1567	1195	836	666
	RadStd		71	79	108	138	127	84	64	95	65	76	58	61

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page