

ENFIDHA, Tunisia

WMO: 607310

Lat: 36.083N

Lon: 10.433E

Elev: 6

StdP: 101.25

Time Zone: 1.00 (E01)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.9	5.0	-1.8	3.3	10.9	0.0	3.8	10.1	14.4	14.7	13.4	15.0	2.8	230	0.482

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.4	35.0	22.4	33.2	22.3	32.0	22.4	26.2	30.2	25.5	29.6	24.8	29.1	6.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.9	20.0	28.9	24.1	19.0	28.3	23.2	18.0	27.8	81.1	30.6	77.8	29.7	75.3	29.1	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	10.6	9.4	1.3	40.3	1.0	2.6	0.6	42.2	0.0	43.7	-0.6	45.2	-1.3	47.1		
(5)			0.2	27.3	1.6	0.8	-1.0	27.9	-1.9	28.4	-2.7	28.8	-3.9	29.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.1	12.0	12.0	14.3	17.0	19.8	23.6	26.9	26.9	25.1	21.6	16.9	13.3		
	DBStd	5.84	2.09	2.51	2.46	1.78	2.04	2.11	1.95	1.73	2.16	2.52	2.59	2.28		
	HDD10.0	14	4	7	1	0	0	0	0	0	0	0	0	2		
	HDD18.3	777	197	178	128	48	8	0	0	0	0	4	57	158		
	CDD10.0	3350	66	63	133	209	304	407	524	523	453	358	207	103		
	CDD18.3	1069	0	0	2	7	53	157	266	264	203	104	13	1		
	CDH23.3	10188	2	7	23	42	276	1289	3037	3054	1785	610	58	6		
	CDH26.7	3765	0	0	2	4	45	378	1329	1329	564	108	6	0		
(14) Wind	WSAvg	4.4	4.4	4.6	4.8	4.6	5.0	4.6	4.5	4.1	4.1	3.8	4.0	4.3		
(15) Precipitation	PrecAvg	435	56	41	43	34	26	10	4	16	50	48	48	55		
	PrecMax	553	186	140	132	88	71	48	27	69	155	189	125	152		
	PrecMin	269	3	2	7	0	1	0	0	4	9	5	5	6		
	PrecStd	90	52	35	33	24	20	12	6	18	39	35	29	39		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.9	24.4	26.0	26.8	31.2	33.8	37.8	37.0	35.5	31.2	27.2	24.2		
		MCWB	14.5	14.4	14.6	16.0	18.3	20.7	22.3	22.4	21.7	20.5	17.9	14.5		
	2%	DB	20.1	21.1	23.0	24.2	27.8	31.9	35.1	34.8	32.1	29.1	25.0	21.1		
		MCWB	12.7	13.4	14.2	15.1	17.5	20.2	22.4	22.5	22.5	21.4	17.5	13.3		
	5%	DB	18.2	18.9	21.0	22.9	26.1	30.2	33.2	33.1	30.8	27.8	23.2	19.8		
		MCWB	12.0	12.6	14.0	15.4	17.4	20.2	22.2	23.0	23.1	21.5	17.4	13.4		
	10%	DB	17.0	17.1	19.4	21.2	24.8	28.9	32.0	31.9	29.5	26.3	22.1	18.1		
		MCWB	11.7	11.8	13.5	15.3	17.2	20.1	22.3	23.1	22.8	21.1	16.8	12.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.1	16.0	17.0	18.1	20.7	24.2	26.5	27.2	26.6	24.6	21.0	16.5		
		MCDB	20.0	21.4	21.0	22.1	26.1	29.0	31.8	31.7	29.4	27.2	23.8	20.4		
	2%	WB	13.8	14.7	15.9	17.5	19.8	23.1	25.6	26.3	25.8	23.7	19.7	15.2		
		MCDB	18.1	19.0	19.9	20.8	24.6	27.4	30.3	30.7	28.8	26.5	23.1	18.4		
	5%	WB	13.0	13.6	15.2	17.0	19.2	22.4	25.0	25.6	25.1	23.1	18.6	14.4		
		MCDB	17.1	17.8	18.8	20.0	23.4	26.8	29.6	30.0	28.5	25.9	21.7	17.9		
	10%	WB	12.1	12.6	14.5	16.4	18.5	21.7	24.4	24.9	24.3	22.1	17.6	13.7		
		MCDB	16.5	16.4	17.9	19.7	22.6	26.3	29.1	29.5	28.0	25.2	20.9	17.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.1	10.1	10.0	9.2	9.7	10.1	10.5	10.4	9.1	9.0	9.6	10.0		
		MCDBR	12.5	13.3	12.7	12.4	12.2	12.4	12.8	12.4	10.8	10.6	11.3	12.3		
	5% WB	MCWBR	7.2	7.2	6.7	6.2	6.0	5.9	6.5	6.8	5.3	5.4	5.8	6.7		
		MCWBR	11.8	11.5	10.8	9.1	10.5	10.3	10.9	10.6	8.7	8.9	9.1	10.1		
(40) Clear-Sky Solar Irradiance	taub		0.349	0.374	0.436	0.483	0.502	0.469	0.494	0.485	0.483	0.444	0.392	0.357		
	taud		2.402	2.319	2.128	2.023	2.005	2.129	2.075	2.099	2.113	2.177	2.289	2.378		
	Ebn at Noon		837	856	827	807	796	821	797	795	773	766	773	798		
	Edh at Noon		91	110	146	170	176	155	163	156	147	126	101	88		
(44) All-Sky Solar Radiation	RadAvg		2.58	3.36	4.54	5.64	6.69	7.44	7.56	6.65	5.03	3.88	2.80	2.29		
	RadStd		0.17	0.21	0.28	0.35	0.33	0.30	0.14	0.26	0.23	0.22	0.14	0.17		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page