

THALA, Tunisia

WMO: 607380

Lat: 35.550N

Lon: 8.683E

Elev: 3583

StdP: 12.89

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.1	32.1	16.0	14.1	53.5	19.7	16.9	51.6	42.2	40.9	36.4	42.1	15.7	320	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.5	96.8	62.2	93.8	61.9	90.9	61.8	67.1	82.7	65.8	82.4	64.7	81.4	13.8	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.1	99.0	70.1	61.3	92.7	69.3	59.8	87.8	68.6	33.7	82.5	32.6	82.5	31.7	81.0	75.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.8	31.9	27.5	DB	27.7	101.9	2.5	1.9	25.9	103.3	24.4	104.4	23.0	105.5	21.1	106.9	(4)
(5)			WB	26.1	70.0	2.8	2.3	24.1	71.7	22.5	73.0	20.9	74.4	18.9	76.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	59.2	43.5	44.0	49.4	54.1	63.2	72.0	78.3	77.1	68.4	61.8	51.5	45.3	(6)
(7)		DBStd	14.00	5.84	6.40	7.57	7.04	7.83	7.81	6.26	6.00	6.48	6.74	6.14	5.87	(7)
(8)		HDD50	768	217	187	105	35	2	0	0	0	0	2	53	167	(8)
(9)		HDD65	3429	668	587	487	333	131	24	1	1	36	145	406	610	(9)
(10)		CDD50	4109	15	20	86	159	410	660	878	840	553	368	98	22	(10)
(11)		CDD65	1291	0	0	2	6	74	234	414	376	139	46	0	0	(11)
(12)		CDH74	12939	0	2	11	61	685	2437	4688	3848	955	251	1	0	(12)
(13)		CDH80	5742	0	0	1	7	198	1062	2355	1786	284	49	0	0	(13)
(14)	Wind	WSAvg	12.2	12.5	14.2	13.4	13.8	12.3	11.5	10.8	10.3	10.7	10.9	12.8	13.8	(14)
(15)	Precipitation	PrecAvg	16.5	1.8	1.2	1.6	1.6	1.6	1.0	0.5	1.0	1.9	1.2	1.6	1.6	(15)
(16)		PrecMax	28.8	5.7	3.2	5.4	6.5	4.1	3.7	2.0	3.1	3.7	2.8	4.5	6.0	(16)
(17)		PrecMin	9.6	0.4	0.0	0.4	0.0	0.0	0.0	0.0	0.1	0.5	0.2	0.1	0.2	(17)
(18)		PrecStd	4.6	1.4	0.9	1.1	1.3	1.1	0.9	0.4	0.7	0.9	0.6	1.2	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.0	67.5	74.7	80.3	90.9	98.5	100.7	98.9	90.5	84.9	71.9	66.7	(19)
MCWB			47.1	48.9	52.4	55.4	59.5	61.2	62.7	63.2	62.1	58.4	50.6	49.5	(20)	
2%		DB	58.7	61.6	69.5	74.9	85.4	93.8	97.6	95.6	86.8	80.1	67.2	61.2	(21)	
		MCWB	45.5	46.7	50.2	54.0	58.1	60.7	62.4	62.7	61.6	58.2	51.0	47.6	(22)	
5%		DB	55.0	57.7	65.4	70.7	81.3	90.2	94.7	92.5	83.6	76.1	63.7	57.2	(23)	
		MCWB	43.8	45.6	49.2	52.9	57.9	60.6	62.3	62.7	61.5	56.8	50.2	46.4	(24)	
10%		DB	52.0	54.0	61.7	66.8	77.6	86.3	91.6	89.5	80.0	72.3	60.5	53.9	(25)	
		MCWB	42.6	43.7	48.2	51.7	56.9	60.0	61.8	62.3	60.8	55.9	49.2	45.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.0	51.6	56.1	59.0	63.2	66.0	68.3	69.4	67.3	63.9	56.7	53.5	(27)
MCD B			56.8	61.8	65.0	69.5	78.7	84.6	84.9	82.8	77.5	71.1	63.8	61.3	(28)	
2%		WB	47.7	48.8	53.0	56.6	61.4	64.0	66.5	67.5	65.3	61.4	54.5	50.2	(29)	
		MCD B	54.5	58.5	64.4	68.1	78.4	82.9	85.4	82.6	77.1	70.0	61.0	57.3	(30)	
5%		WB	46.0	46.6	51.1	54.7	59.7	62.7	65.3	66.2	63.9	59.9	52.9	48.2	(31)	
		MCD B	52.4	55.4	62.1	66.5	76.2	81.5	84.7	82.3	75.6	69.3	58.7	53.8	(32)	
10%		WB	44.2	44.7	49.2	53.1	58.2	61.5	64.1	65.0	62.7	58.6	51.3	46.7	(33)	
		MCD B	49.7	52.1	59.5	64.3	73.7	80.4	83.7	81.2	74.4	67.8	57.1	51.7	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.1	12.6	15.5	17.1	19.6	21.2	22.5	20.9	17.4	14.6	12.1	10.5	(35)
MCDBR			15.3	17.6	20.4	22.9	23.3	23.4	24.3	23.0	20.8	18.3	15.9	14.9	(36)	
MCWBR			8.4	9.1	9.2	9.5	8.4	7.3	7.2	6.8	6.5	6.7	7.7	8.6	(37)	
5% WB		MCDBR	13.7	15.9	18.9	19.9	21.4	22.1	22.8	21.7	18.3	15.4	13.5	12.6	(38)	
		MCWBR	8.7	9.1	9.6	9.6	9.1	8.1	8.0	7.8	7.4	7.1	7.5	7.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.284	0.302	0.361	0.401	0.430	0.411	0.437	0.425	0.410	0.368	0.321	0.291	(40)	
taud		2.488	2.435	2.257	2.154	2.093	2.181	2.106	2.138	2.192	2.288	2.417	2.485	(41)		
Ebn at Noon		294	299	287	280	272	277	268	269	267	270	275	283	(42)		
Edh at Noon		26	31	41	47	51	47	50	48	43	36	28	25	(43)		
(44)	All-Sky Solar Radiation	RadAvg	856	1108	1485	1830	2107	2378	2386	2132	1643	1272	937	766	(44)	
(45)		RadStd	71	77	99	122	111	106	70	100	75	60	56	63	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page