

SIDI BOUZID, Tunisia

WMO: 607480

Lat: 35.000N

Lon: 9.483E

Elev: 355

StdP: 97.13

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.0	4.3	-4.5	2.7	13.4	-2.9	3.1	13.5	9.4	12.1	8.4	12.9	0.9	250	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.1	40.8	20.8	38.8	20.9	37.1	20.7	24.3	33.0	23.3	31.7	22.6	30.9	3.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.3	17.7	26.3	21.2	16.6	25.8	20.3	15.7	25.6	74.9	33.2	71.1	31.4	68.1	30.8	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.0	7.0	6.2	0.1	44.8	0.9	0.8	-0.5	45.4	-1.1	45.9	-1.6	46.3	-2.3	47.0		
(5)			-0.9	25.6	1.3	1.0	-1.9	26.3	-2.7	26.9	-3.4	27.5	-4.4	28.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	19.7	11.1	11.6	14.1	17.3	22.3	26.8	30.0	29.1	24.8	21.0	15.2	11.9	(6)
(7)		DBStd	7.29	2.55	2.81	3.15	3.22	3.23	3.57	2.40	2.52	2.94	2.77	2.53	2.75	(7)
(8)		HDD10.0	46	16	12	4	1	0	0	0	0	0	0	1	12	(8)
(9)		HDD18.3	915	223	189	136	56	3	0	0	0	1	7	99	201	(9)
(10)		CDD10.0	3568	51	57	132	218	382	504	620	592	444	341	156	71	(10)
(11)		CDD18.3	1397	0	1	5	24	127	254	362	333	195	89	5	1	(11)
(12)		CDH23.3	16109	1	11	81	259	1253	3025	4814	4144	1804	671	43	2	(12)
(13)		CDH26.7	8738	0	3	15	71	523	1719	2957	2431	809	204	6	0	(13)
(14)	Wind	WSAvg	2.5	2.6	2.7	2.8	3.0	2.8	2.6	2.6	2.3	2.2	2.3	2.6	(14)	
(15)	Precipitation	PrecAvg	253	35	17	23	27	21	11	6	16	35	21	22	21	(15)
(16)		PrecMax	591	252	64	71	80	74	40	36	50	123	65	105	90	(16)
(17)		PrecMin	105	1	0	0	0	0	0	0	0	6	3	0	0	(17)
(18)		PrecStd	103	55	17	18	23	19	9	8	15	28	14	22	22	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.2	24.8	28.6	32.0	37.5	42.8	43.4	42.7	38.3	34.2	27.3	22.7	(19)
(20)			MCWB	12.8	13.0	14.7	16.6	17.9	19.8	21.9	21.0	20.3	19.4	15.6	13.2	(20)
(21)		2%	DB	19.7	22.0	26.0	28.6	33.7	40.2	40.7	40.0	35.5	30.9	24.4	20.7	(21)
(22)			MCWB	11.4	12.8	13.9	15.8	17.8	20.1	21.5	21.0	20.6	18.6	14.9	12.5	(22)
(23)		5%	DB	17.9	19.8	23.5	26.2	31.6	37.2	38.9	37.8	33.3	28.8	22.5	18.8	(23)
(24)			MCWB	10.7	11.7	13.0	15.0	17.7	20.0	21.2	20.9	20.7	18.5	14.1	11.7	(24)
(25)		10%	DB	16.3	17.7	21.4	24.2	29.6	34.7	37.2	36.2	31.6	27.0	20.8	17.1	(25)
(26)			MCWB	10.2	10.4	12.4	14.3	17.1	19.5	21.1	21.1	20.4	18.3	13.7	11.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.6	16.2	16.7	18.0	20.7	23.7	25.4	25.6	25.1	22.4	18.0	14.9	(27)
(28)			MCDWB	19.3	22.3	23.5	27.2	30.4	37.9	38.9	34.6	30.1	28.3	22.8	19.1	(28)
(29)		2%	WB	12.5	13.3	15.4	16.7	19.5	21.8	23.9	24.2	23.8	21.1	16.5	13.7	(29)
(30)			MCDWB	17.5	20.1	23.0	25.9	29.3	32.7	35.2	32.3	29.2	25.7	21.2	17.8	(30)
(31)		5%	WB	11.7	12.2	14.2	15.9	18.6	21.0	22.9	23.4	22.6	20.2	15.5	12.8	(31)
(32)			MCDWB	16.0	18.3	21.6	23.4	28.5	32.0	33.5	31.0	28.0	24.9	20.1	16.7	(32)
(33)		10%	WB	10.9	11.2	13.0	15.1	17.8	20.2	22.2	22.6	21.8	19.4	14.6	11.9	(33)
(34)			MCDWB	15.1	16.5	19.7	21.9	27.2	31.6	32.7	30.4	27.5	24.3	19.1	16.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.4	10.4	11.6	11.1	12.4	13.4	14.1	13.3	11.3	11.0	10.7	9.5	(35)
(36)			MCDBR	12.1	13.7	15.6	15.0	15.0	17.0	16.4	15.6	14.0	13.7	13.0	11.4	(36)
(37)			MCWBR	6.2	6.7	6.6	5.3	4.7	4.6	4.6	4.2	4.1	4.8	5.5	5.7	(37)
(38)		5% WB	MCDWB	9.8	12.4	13.9	13.1	13.3	14.6	14.8	13.2	11.9	11.0	10.6	10.1	(38)
(39)			MCWBR	5.6	6.6	6.5	5.0	4.7	4.9	5.0	4.4	3.9	4.4	5.3	5.9	(39)
(40)																
(41)	Clear-Sky Solar Irradiance	taub	0.320	0.346	0.421	0.472	0.499	0.471	0.500	0.488	0.476	0.429	0.371	0.330	(41)	
(42)		taud	2.376	2.291	2.059	1.943	1.904	2.006	1.946	1.975	2.009	2.101	2.236	2.354	(42)	
(43)		Ebn at Noon	879	891	844	819	800	820	793	795	781	784	802	839	(43)	
(44)		Edh at Noon	93	114	157	185	195	176	186	177	163	137	107	91	(44)	
(45)	All-Sky Solar Radiation	RadAvg	2.96	3.81	4.99	6.07	6.95	7.70	7.75	6.88	5.43	4.21	3.17	2.65	(45)	
(46)		RadStd	0.18	0.20	0.26	0.33	0.37	0.29	0.18	0.24	0.21	0.18	0.14	0.18	(46)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)		+0.22	N/A	N/A	N/A	-0.33	N/A	N/A	N/A	+111	+67

Nomenclature: See separate page