

TOZEUR NEFTA, Tunisia

WMO: 607600

Lat: 33.940N

Lon: 8.111E

Elev: 88

StdP: 100.28

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.9	6.0	-6.8	2.1	16.3	-4.9	2.5	15.2	12.6	15.2	11.1	14.7	3.0	270	0.534

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.0	44.0	21.1	42.1	21.0	40.2	20.9	24.7	33.6	23.9	33.0	23.2	32.9	3.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.3	17.1	28.5	21.2	16.0	28.2	20.2	15.1	28.1	75.2	33.4	71.9	33.0	69.3	32.8	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.4	11.1	10.0	DB	2.2	46.7	1.3	1.2	1.3	47.6	0.6	48.3	-0.1	48.9	-1.0	49.8	(4)
(5)			WB	0.2	25.9	1.4	1.5	-0.8	27.0	-1.6	27.8	-2.4	28.7	-3.4	29.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.7	12.1	13.7	17.5	21.4	26.0	30.5	33.3	33.1	29.2	24.2	17.5	13.0	(6)	
	DBStd	8.09	2.05	2.77	3.32	3.35	3.44	3.33	2.65	2.44	3.21	3.14	3.04	2.31	(7)	
	HDD10.0	12	6	3	0	0	0	0	0	0	0	0	0	3	(8)	
	HDD18.3	608	194	132	55	9	0	0	0	0	0	1	52	166	(9)	
	CDD10.0	4636	70	107	233	341	495	614	723	717	574	440	224	97	(10)	
	CDD18.3	2191	0	3	30	100	237	364	465	459	324	183	26	1	(11)	
	CDH23.3	29239	1	19	253	901	2679	5140	7311	7117	4137	1566	114	2	(12)	
	CDH26.7	17488	0	2	68	337	1374	3196	4928	4698	2269	601	15	0	(13)	
(14) Wind	WSAvg	4.7	3.8	4.2	4.9	5.5	5.8	5.8	5.6	5.2	4.8	3.9	3.6	3.5	(14)	
(15) Precipitation	PrecAvg	117	19	8	10	18	6	3	1	3	13	9	13	13	(15)	
	PrecMax	321	138	62	33	97	41	57	8	28	95	52	80	88	(16)	
	PrecMin	30	0	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	71	34	13	11	26	10	11	2	7	19	12	17	20	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.9	25.9	32.0	36.3	41.2	45.0	46.2	45.2	42.1	36.2	28.4	22.2	(19)	
		MCWB	12.3	13.2	15.3	16.9	19.0	20.5	21.7	21.2	20.8	18.8	16.2	12.8	(20)	
	2%	DB	19.1	23.0	28.2	32.9	37.9	42.3	44.2	43.2	39.2	34.1	26.1	20.2	(21)	
		MCWB	11.4	12.7	14.5	16.4	18.8	20.2	21.3	21.5	20.8	19.0	16.0	12.6	(22)	
	5%	DB	18.0	21.0	26.0	30.2	35.2	40.0	42.2	41.2	37.2	31.9	24.3	19.0	(23)	
		MCWB	11.0	11.8	14.0	15.9	18.4	20.0	21.1	21.6	21.1	18.9	15.3	12.2	(24)	
	10%	DB	16.8	19.2	24.0	28.1	33.1	37.8	40.1	39.7	35.2	30.0	22.9	17.8	(25)	
		MCWB	10.5	11.1	13.4	15.3	17.9	19.8	21.0	21.6	21.0	18.7	14.7	11.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.2	15.2	17.7	19.2	21.5	23.8	25.5	26.1	25.4	23.2	19.0	15.3	(27)	
		MCDB	17.8	22.6	23.8	28.0	33.7	36.4	35.6	35.5	32.1	28.7	24.1	19.4	(28)	
	2%	WB	13.0	13.8	16.0	18.1	20.4	22.4	24.1	24.9	24.2	22.0	17.7	14.0	(29)	
		MCDB	16.7	21.4	24.9	27.2	32.5	35.0	35.3	34.2	31.1	28.0	23.1	18.1	(30)	
	5%	WB	12.0	12.7	15.0	17.2	19.6	21.5	23.2	24.1	23.5	21.1	16.6	13.1	(31)	
		MCDB	16.1	19.0	24.0	26.6	31.7	34.5	35.3	33.2	30.6	27.3	22.4	17.3	(32)	
	10%	WB	11.1	11.7	14.1	16.4	18.9	20.8	22.5	23.4	22.7	20.3	15.6	12.3	(33)	
		MCDB	15.5	17.6	22.2	25.6	30.5	33.8	34.8	33.3	30.3	26.7	21.4	16.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	10.4	11.2	11.7	12.3	12.8	13.0	12.2	10.7	10.2	9.7	9.3	(35)	
		MCDBR	10.8	12.3	13.6	14.4	14.6	14.9	15.3	14.1	12.6	12.0	10.6	10.3	(36)	
	5% WB	MCWBR	5.5	5.8	5.5	5.0	4.6	4.2	4.4	4.4	4.2	4.5	4.6	5.2	(37)	
		MCWBR	9.3	10.8	12.1	12.5	12.9	13.4	13.5	12.3	11.0	9.9	9.5	9.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.359	0.387	0.480	0.534	0.572	0.547	0.579	0.559	0.542	0.487	0.419	0.371	(40)	
		taud	2.223	2.122	1.859	1.753	1.698	1.766	1.713	1.763	1.813	1.917	2.052	2.179	(41)	
	Ebn at Noon		831	846	790	768	744	760	733	739	725	728	747	787	(42)	
		Edh at Noon	111	137	193	225	241	224	235	220	200	166	131	110	(43)	
(44) All-Sky Solar Radiation	RadAvg		3.25	4.25	5.38	6.49	7.18	7.82	7.79	6.95	5.71	4.48	3.44	2.91	(44)	
	RadStd		0.18	0.19	0.23	0.26	0.32	0.25	0.17	0.20	0.19	0.19	0.13	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	-1.14	N/A	N/A	N/A	N/A	N/A	+107	+112	(46)	
(47) Regional (6 neighbors)		N/A	N/A	-0.71	+0.66	N/A	N/A	N/A	N/A	+95	+83	(47)	

Nomenclature: See separate page