

SIKASSO, Mali

WMO: 612970

Lat: 11.350N

Lon: 5.683W

Elev: 375

StdP: 96.90

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.1	18.2	-6.8	2.2	30.1	-4.4	2.7	29.8	7.4	27.6	7.0	27.9	1.2	0	0.335

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	11.6	38.7	20.4	38.0	20.6	37.2	20.6	26.2	32.8	25.7	32.2	25.5	31.7	2.7	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.6	20.5	28.9	24.2	20.0	28.4	23.8	19.6	28.1	83.5	33.0	81.7	32.5	80.4	31.9	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.1	5.9	5.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.1	25.3	28.9	31.4	31.6	30.5	28.3	26.6	26.2	26.6	28.2	28.0	25.8
	DBStd	2.67	1.92	2.36	1.85	1.79	1.87	1.82	1.35	1.25	1.31	1.30	1.16	1.73
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6607	475	528	663	649	636	550	514	501	498	563	541	489
	CDD18.3	3566	217	295	404	399	378	300	256	243	248	305	291	231
	CDH23.3	42466	2352	3940	6042	5858	5171	3481	2357	1937	2058	3263	3491	2516
	CDH26.7	21717	1121	2252	3729	3559	2881	1564	792	558	729	1482	1827	1222
Wind	WSAvg	2.2	2.3	2.5	2.3	2.4	2.8	2.7	2.3	2.1	1.7	1.9	1.6	2.0
Precipitation	PrecAvg	1160	1	4	13	49	100	155	245	299	210	78	11	1
	PrecMax	1679	19	37	68	255	194	246	386	493	431	315	58	41
	PrecMin	754	0	0	0	0	26	29	102	141	69	0	0	0
	PrecStd	206	4	8	17	45	46	39	72	88	69	53	15	6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.5	38.6	39.6	39.6	39.0	36.2	33.9	32.3	33.6	35.7	36.0	35.5
		MCWB	17.9	18.7	19.1	22.1	23.1	24.9	25.4	25.2	25.3	21.9	19.8	17.9
	2%	DB	34.2	37.6	38.7	38.6	37.6	34.8	32.4	31.3	32.4	34.6	35.2	34.4
		MCWB	16.9	18.6	19.1	21.7	24.0	25.1	24.8	24.9	25.1	23.1	20.0	17.7
	5%	DB	33.2	36.7	38.0	37.7	36.5	33.8	31.3	30.6	31.5	33.7	34.6	33.5
		MCWB	16.3	18.4	19.4	21.6	24.2	25.0	24.6	24.7	24.9	23.7	20.1	17.4
	10%	DB	32.2	35.7	37.2	36.9	35.4	32.7	30.5	29.7	30.5	32.8	33.9	32.4
		MCWB	15.8	18.2	19.5	21.9	24.2	24.8	24.5	24.5	24.7	24.0	20.1	17.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.1	23.8	25.2	26.5	26.7	26.5	25.9	26.0	26.5	26.1	25.6	22.5
		MCDB	30.6	33.6	33.8	34.4	33.4	33.6	31.8	30.8	31.6	31.8	32.0	30.6
	2%	WB	19.2	22.7	24.1	25.5	26.0	25.8	25.4	25.4	25.7	25.5	24.3	20.3
		MCDB	29.5	32.4	33.5	34.4	33.7	32.5	30.8	29.9	30.8	31.3	31.2	29.6
	5%	WB	17.9	21.7	23.5	24.7	25.6	25.5	25.1	25.0	25.3	25.1	23.6	18.6
		MCDB	29.2	31.9	32.9	33.3	33.1	32.0	30.1	29.4	30.2	31.0	30.4	30.9
	10%	WB	16.8	20.6	22.9	24.2	25.2	25.1	24.7	24.7	24.9	24.7	22.9	17.7
		MCDB	30.1	31.8	32.3	32.5	32.5	31.3	29.3	28.7	29.6	30.4	29.1	30.3
Mean Daily Temperature Range	5% DB	MDBR	13.6	12.9	11.6	10.4	9.6	8.6	7.6	6.9	8.2	9.9	13.1	14.1
		MCDBR	14.8	13.6	12.4	11.4	10.8	10.0	8.7	8.2	9.5	11.0	13.7	14.9
		MCWBR	4.7	4.7	4.5	3.6	3.0	3.3	3.1	3.1	3.7	3.5	4.1	4.2
	5% WB	MCDBR	13.6	10.8	10.2	10.2	9.6	9.2	8.2	7.8	8.9	9.6	11.2	14.0
	MCWBR	5.4	5.0	4.5	3.3	3.4	3.6	3.3	3.2	3.8	3.7	4.3	4.8	
Clear-Sky Solar Irradiance	taub	0.536	0.607	0.735	0.683	0.625	0.584	0.524	0.498	0.503	0.548	0.517	0.493	
	taud	1.879	1.730	1.530	1.697	1.791	1.902	2.098	2.179	2.143	1.989	1.981	2.001	
	Ebn at Noon	770	733	653	684	710	731	780	812	815	771	782	798	
	Edh at Noon	198	238	295	248	221	195	161	151	158	181	177	172	
All-Sky Solar Radiation	RadAvg	5.71	6.00	6.18	6.11	6.07	5.67	5.32	5.05	5.38	5.81	5.68	5.54	
	RadStd	0.29	0.30	0.29	0.26	0.16	0.19	0.15	0.23	0.25	0.16	0.17	0.18	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page