

NOUADHIBOU, Mauritania

WMO: 614150

Lat: 20.920N

Lon: 17.036W

Elev: 2

StdP: 14.69

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	57.0	58.4	31.7	26.1	71.0	35.3	30.1	70.7	27.7	63.5	25.9	62.8	16.3	0	0.608

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	15.8	93.2	70.2	89.8	70.0	87.4	69.9	77.9	83.6	76.0	82.4	74.5	81.4	12.0	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.5	138.2	80.7	73.8	126.0	79.3	72.2	119.2	78.2	41.2	85.2	39.4	82.9	38.0	81.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.5	25.5	23.9	DB	52.8	102.6	3.5	2.6	50.3	104.4	48.2	105.9	46.3	107.4	43.7	109.2	
			WB	45.3	79.9	2.7	3.0	43.4	82.0	41.8	83.7	40.3	85.4	38.3	87.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	73.2	68.5	69.0	70.3	70.5	71.7	74.2	74.7	77.0	79.5	77.8	74.2	70.5	(6)
(7)		DBStd	5.08	3.28	3.71	4.03	3.60	3.59	3.46	3.06	3.56	4.10	4.67	4.01	3.13	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	13	6	5	1	0	0	0	0	0	0	0	0	1	(9)
(10)		CDD50	8462	574	531	631	614	674	725	766	838	886	862	726	635	(10)
(11)		CDD65	3001	115	116	167	164	209	275	301	373	436	397	276	172	(11)
(12)		CDH74	13568	399	449	613	448	640	941	1021	2019	2946	2339	1203	550	(12)
(13)		CDH80	3782	64	104	193	118	164	215	190	507	953	828	358	88	(13)
(14)	Wind	WSAvg	15.1	13.6	15.4	15.7	16.9	18.2	18.2	16.1	14.2	14.5	14.2	12.9	12.1	(14)
(15)	Precipitation	PrecAvg	0.7	0.1	0.1	0.0	0.0	0.0	0.0	0.1	0.1	0.2	0.1	0.0	0.0	(15)
(16)		PrecMax	1.9	0.7	1.6	0.6	0.6	0.2	0.1	0.4	0.7	1.2	2.9	0.8	0.3	(16)
(17)		PrecMin	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	0.6	0.1	0.3	0.1	0.1	0.0	0.0	0.1	0.2	0.3	0.4	0.2	0.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.9	87.6	91.3	91.1	91.8	91.7	89.6	92.0	98.2	98.3	92.9	85.7	(19)
(20)			MCWB	62.1	61.7	62.8	65.7	67.2	69.2	71.7	75.6	72.7	70.8	66.3	62.5	(20)
(21)		2%	DB	81.0	83.2	85.7	82.8	84.0	85.6	84.4	88.0	91.6	92.8	87.9	82.4	(21)
(22)			MCWB	59.7	60.9	61.9	64.9	65.9	68.9	71.7	74.9	73.6	69.9	64.7	61.5	(22)
(23)		5%	DB	78.5	79.4	80.6	78.7	79.8	81.9	81.6	85.2	88.0	88.1	84.1	80.0	(23)
(24)			MCWB	59.0	60.6	63.2	64.6	65.6	68.7	71.5	74.5	73.7	69.8	64.6	61.3	(24)
(25)		10%	DB	75.4	75.7	76.7	75.4	77.0	78.9	79.0	82.4	85.4	84.1	80.5	77.0	(25)
(26)			MCWB	59.2	60.8	63.0	64.8	65.9	68.0	70.7	73.4	73.5	69.3	65.5	61.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.5	69.5	69.0	70.2	71.2	74.3	78.3	80.4	80.5	77.0	72.9	71.3	(27)
(28)			MCDWB	73.6	75.3	78.0	78.5	80.6	80.4	80.7	84.1	84.7	84.9	78.1	74.6	(28)
(29)		2%	WB	66.4	67.2	67.4	68.3	69.2	71.7	74.7	77.5	78.4	73.9	70.5	69.0	(29)
(30)			MCDWB	72.3	73.1	75.0	75.5	77.3	79.0	79.8	83.4	83.9	82.8	77.6	73.4	(30)
(31)		5%	WB	64.5	65.5	66.2	67.2	68.0	70.2	72.7	75.9	76.2	72.6	69.1	67.1	(31)
(32)			MCDWB	70.9	71.6	72.7	74.0	75.8	77.4	78.4	81.9	83.0	81.7	76.2	72.8	(32)
(33)		10%	WB	63.0	63.9	65.2	66.0	66.9	69.2	71.3	74.4	74.6	71.4	67.9	65.3	(33)
(34)			MCDWB	69.6	70.2	71.5	72.7	74.2	76.2	77.3	80.6	82.3	80.1	75.1	71.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	17.7	17.8	17.4	15.7	15.7	15.5	12.6	12.5	15.8	16.7	16.9	16.3	(35)
(36)			MCDBR	21.0	22.0	22.6	19.7	19.5	18.9	16.3	16.3	19.3	21.4	20.4	19.7	(36)
(37)			MCWBR	9.9	9.5	8.4	7.3	7.1	6.4	6.3	6.9	7.2	7.3	7.4	8.4	(37)
(38)		5% WB	MCDWR	17.5	17.3	17.9	16.5	16.4	15.6	13.3	14.4	15.4	17.0	16.5	14.8	(38)
(39)			MCWBR	9.1	8.7	7.6	7.0	7.1	7.1	7.1	7.8	8.6	7.4	7.3	7.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.444	0.438	0.484	0.493	0.555	0.701	0.789	0.777	0.724	0.561	0.438	0.437	(40)	
(41)		taud	2.027	2.065	1.953	1.977	1.834	1.593	1.477	1.522	1.592	1.865	2.140	2.093	(41)	
(42)		Ebn at Noon	259	270	262	261	243	208	191	193	201	231	259	256	(42)	
(43)		Edh at Noon	50	51	60	59	68	85	96	92	85	62	45	46	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1570	1865	2197	2418	2516	2464	2334	2225	2043	1841	1597	1418	(44)	
(45)		RadStd	86	97	90	105	85	103	86	60	82	102	103	89	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page