

DIEGO GARCIA, British Indian Ocean TerritoryWMO: **619670**Lat: **7.300S**Lon: **72.400E**Elev: **4**StdP: **101.27**Time Zone: **6.00 (E06)**Period: **94-19**WBAN: **70701****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	23.8	24.0	19.8	14.5	27.0	20.5	15.2	26.6	10.4	26.9	9.8	27.1	4.0	130	0.462

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	5.4	33.6	28.0	32.9	27.7	32.2	27.3	28.9	32.3	28.4	31.7	28.1	31.2	3.5	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.0	24.2	31.5	27.5	23.4	30.8	27.1	22.9	30.3	94.1	32.5	91.8	32.1	90.1	31.3	31.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.5	7.9	DB	21.9	35.4	1.4	1.4	20.9	36.4	20.1	37.3	19.3	38.1	18.2	39.1	(4)
(5)			WB	20.6	29.9	1.1	0.8	19.7	30.5	19.1	30.9	18.4	31.4	17.6	32.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.1	28.2	28.5	28.9	28.9	28.5	27.8	27.2	27.1	27.3	28.0	28.4	28.4
	DBStd	1.27	1.34	1.30	1.20	1.00	1.03	0.95	0.91	0.89	0.98	1.22	1.24	1.25
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6601	564	517	587	567	572	534	532	529	519	557	551	572
	CDD18.3	3559	306	284	328	317	314	284	274	271	269	298	301	313
	CDH23.3	38112	3341	3206	3858	3712	3512	2905	2582	2497	2612	3112	3305	3470
	CDH26.7	11647	1075	1107	1466	1380	1150	735	526	484	579	892	1087	1166
(14) Wind	WSAvg	4.0	3.6	3.7	3.1	3.0	3.8	4.8	5.4	5.5	4.9	4.1	3.5	3.2
(15) Precipitation	PrecAvg	2784	361	316	230	202	206	166	122	130	244	283	277	264
	PrecMax	3799	607	539	380	436	387	442	420	431	685	571	584	580
	PrecMin	2037	190	168	87	28	55	38	18	19	43	20	28	15
	PrecStd	558	112	106	77	101	117	107	99	117	164	139	156	141
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.7	34.5	34.2	33.9	33.1	32.2	31.2	31.1	32.1	33.3	33.8	33.9
		MCWB	28.2	28.8	28.5	28.3	27.7	27.4	26.9	26.8	27.1	27.4	27.6	28.5
	2%	DB	32.3	32.9	33.1	32.7	32.0	31.1	30.2	30.2	30.9	32.1	32.5	32.5
		MCWB	27.5	27.7	28.0	27.7	27.5	27.0	26.4	26.2	26.7	27.0	27.1	27.4
	5%	DB	31.6	31.9	32.1	31.9	31.2	30.2	29.8	29.7	30.1	31.1	31.8	31.8
		MCWB	27.2	27.3	27.4	27.4	27.0	26.4	26.1	25.9	26.1	26.6	26.8	27.0
	10%	DB	30.9	31.0	31.2	31.1	30.7	29.8	29.1	29.1	29.3	30.2	30.9	31.0
		MCWB	26.8	27.0	27.0	27.0	26.8	26.1	25.7	25.5	25.6	26.2	26.6	26.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.0	29.4	29.5	29.2	28.6	28.2	28.0	27.9	28.1	28.5	28.7	29.0
		MCDB	32.7	33.1	33.0	32.5	31.9	31.0	30.2	30.1	30.5	31.5	32.3	32.4
	2%	WB	28.2	28.5	28.6	28.5	28.0	27.6	27.2	27.0	27.1	27.7	27.9	28.2
		MCDB	31.4	31.9	32.2	31.7	31.0	30.1	29.2	29.4	29.8	30.7	31.3	31.5
	5%	WB	27.7	27.9	28.0	28.0	27.5	27.0	26.6	26.4	26.6	27.0	27.3	27.5
		MCDB	30.5	31.0	31.4	30.9	30.3	29.3	28.6	28.7	29.2	30.1	30.6	30.6
	10%	WB	27.2	27.3	27.4	27.5	27.0	26.5	26.1	25.9	26.2	26.5	26.8	27.0
		MCDB	29.8	30.1	30.5	30.2	29.6	28.8	28.2	28.1	28.5	29.3	29.8	29.8
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	5.4	5.4	5.2	4.9	4.4	4.3	4.3	4.6	5.1	5.4	5.4
		MCDBR	6.3	6.5	6.3	6.0	5.5	5.0	4.9	4.9	5.4	6.1	6.4	6.4
		MCWBR	3.5	3.5	3.5	3.3	3.0	2.9	2.9	2.8	3.1	3.3	3.3	3.5
	5% WB	MCDBR	5.8	6.0	6.0	5.5	5.3	4.7	4.5	4.7	5.1	5.6	6.0	5.9
		MCWBR	3.5	3.6	3.6	3.4	3.1	3.1	3.0	3.0	3.2	3.4	3.4	3.4
(40) Clear-Sky Solar Irradiance	taub	0.393	0.400	0.389	0.390	0.400	0.414	0.426	0.430	0.441	0.434	0.415	0.393	
	taud	2.606	2.580	2.624	2.624	2.574	2.519	2.464	2.456	2.428	2.458	2.524	2.600	
	Ebn at Noon	946	936	932	905	867	839	835	856	872	893	918	943	
	Edh at Noon	103	106	100	96	96	99	106	112	119	118	111	103	
(44) All-Sky Solar Radiation	RadAvg	5.54	5.81	6.06	5.67	5.28	4.88	4.88	5.37	5.26	5.68	5.85	5.63	
	RadStd	0.56	0.63	0.34	0.26	0.33	0.33	0.37	0.26	0.42	0.43	0.50	0.48	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	+0.31	+1.09	+0.47	+0.79	+0.65	N/A	N/A	+110	+110
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A