

ILES GLORIEUSES, French Southern Territories

WMO: 619680

Lat: 11.583S

Lon: 47.290E

Elev: 13

StdP: 14.69

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	67.1	68.5	60.8	79.5	79.0	62.1	83.4	78.1	16.0	79.6	14.2	79.5	0.9	100	0.340

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	10.6	90.2	79.1	89.6	78.9	88.9	78.6	80.9	87.8	80.4	87.2	79.9	86.7	7.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.1	151.1	85.2	78.4	147.7	84.7	78.0	145.3	84.4	44.6	88.0	44.0	87.4	43.5	87.0	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.7	14.2	13.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			62.2	82.6	2.6	1.5	60.3	83.6	58.8	84.5	57.4	85.3	55.5	86.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.8	82.8	83.0	83.3	83.1	81.1	78.6	76.3	77.1	78.9	80.5	82.4	82.7
	DBStd	2.98	1.85	1.72	1.64	1.68	2.14	1.94	1.87	1.83	1.62	1.49	1.51	1.72
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11239	1017	923	1032	993	965	857	816	840	866	945	972	1013
	CDD65	5764	552	503	567	543	500	407	351	375	416	480	522	548
	CDH74	58224	6297	5781	6613	6264	5240	3575	2529	2710	3263	4336	5492	6124
	CDH80	18138	2216	2074	2548	2349	1669	805	376	448	663	1094	1747	2149
Wind	WSAvg	5.9	5.5	5.5	5.0	5.1	4.8	4.7	4.3	5.8	8.0	8.5	8.2	5.4
Precipitation	PrecAvg	41.1	9.3	7.3	6.2	4.4	3.1	2.5	2.0	1.7	0.5	0.2	0.7	4.4
	PrecMax	55.7	22.8	15.9	21.5	13.7	7.7	7.8	4.9	4.2	1.7	1.6	3.0	13.2
	PrecMin	31.0	1.9	2.6	0.5	1.1	0.5	0.4	0.6	0.3	0.1	0.0	0.0	0.0
	PrecStd	7.2	4.9	3.7	3.7	3.0	1.8	1.7	1.1	0.9	0.5	0.4	0.8	3.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.4	90.6	91.0	91.0	89.3	86.8	84.7	84.9	86.1	87.4	89.7	90.7
		MCWB	79.2	80.1	79.7	79.2	77.0	74.8	72.1	72.0	72.8	75.3	78.2	78.8
	2%	DB	89.3	89.6	90.0	89.8	88.3	85.7	83.7	83.9	85.1	86.4	88.5	89.4
		MCWB	78.9	79.6	79.5	78.8	76.8	74.2	71.9	71.6	72.4	74.7	77.1	78.3
	5%	DB	88.5	88.7	89.2	88.9	87.4	85.0	83.0	83.2	84.3	85.7	87.7	88.6
		MCWB	78.7	79.3	79.4	78.5	76.5	73.8	71.8	71.5	72.1	74.2	76.4	78.0
	10%	DB	87.7	87.7	88.4	88.0	86.4	84.2	82.3	82.5	83.5	84.9	86.9	87.7
		MCWB	78.5	79.0	79.2	78.2	76.1	73.3	71.7	71.3	71.9	73.9	76.0	77.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	81.9	81.8	81.0	79.2	77.4	75.3	75.5	75.4	77.3	79.8	80.6
		MCDB	87.8	88.5	88.8	88.1	86.5	83.9	81.5	82.3	83.4	85.1	88.0	88.1
	2%	WB	80.1	80.8	80.9	80.2	78.5	76.5	74.4	74.3	74.3	76.3	78.8	79.7
		MCDB	87.0	87.2	87.8	87.4	85.7	83.2	80.7	81.1	82.5	84.3	86.3	87.0
	5%	WB	79.6	80.1	80.4	79.7	77.9	75.6	73.7	73.4	73.6	75.6	78.0	79.1
		MCDB	86.3	86.3	87.1	86.8	85.0	82.2	80.1	80.2	81.8	83.6	85.4	86.3
	10%	WB	79.0	79.6	79.8	79.0	77.2	74.9	73.0	72.7	72.9	74.9	77.2	78.5
		MCDB	85.5	85.8	86.4	86.1	84.2	81.5	79.6	79.8	81.0	82.9	84.5	85.4
Mean Daily Temperature Range	5% DB	MDBR	9.5	9.6	10.6	10.5	11.3	11.8	12.4	11.6	10.3	9.9	10.0	10.4
		MCDBR	10.5	10.7	11.7	11.2	11.7	12.3	13.0	12.1	10.9	10.3	10.6	11.4
		MCWBR	4.0	4.1	4.4	4.1	4.5	4.8	5.3	4.8	4.2	3.9	3.8	4.1
	5% WB	MCDBR	9.9	9.8	10.8	11.1	10.8	11.5	11.4	11.6	10.7	10.4	10.7	10.9
	MCWBR	4.2	4.3	4.5	4.5	4.6	5.1	5.4	5.3	4.5	4.5	4.3	4.3	
Clear-Sky Solar Irradiance	taub	0.418	0.425	0.402	0.388	0.380	0.369	0.362	0.372	0.391	0.410	0.422	0.407	
	taud	2.525	2.501	2.588	2.613	2.610	2.615	2.628	2.586	2.508	2.468	2.461	2.539	
	Ebn at Noon	294	290	291	285	278	277	281	286	290	291	291	296	
	Edh at Noon	36	36	33	30	29	28	28	30	35	37	38	35	
All-Sky Solar Radiation	RadAvg	1833	1852	1932	1893	1733	1595	1636	1866	2086	2213	2224	2090	
	RadStd	115	148	115	76	57	47	43	57	36	48	76	141	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page