

ILES GLORIEUSES, French Southern Territories

WMO: 619680

Lat: 11.583S

Lon: 47.290E

Elev: 4

StdP: 101.28

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.5	20.3	16.0	11.4	26.1	16.7	11.9	25.6	7.1	26.5	6.4	26.4	0.4	100	0.340

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	5.9	32.4	26.2	32.0	26.1	31.6	25.9	27.2	31.0	26.9	30.7	26.6	30.4	3.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	21.6	29.5	25.8	21.1	29.3	25.5	20.8	29.1	85.9	31.1	84.4	30.8	83.3	30.6	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
7.0	6.3	5.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			16.8	28.1	1.4	0.8	15.7	28.7	14.9	29.2	14.1	29.6	13.0	30.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.1	28.2	28.3	28.5	28.4	27.3	25.9	24.6	25.0	26.0	26.9	28.0	28.1
	DBStd	1.66	1.03	0.96	0.91	0.93	1.19	1.08	1.04	1.02	0.90	0.83	0.84	0.95
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6244	565	513	573	552	536	476	453	467	481	525	540	563
	CDD18.3	3202	307	279	315	302	278	226	195	208	231	267	290	304
	CDH23.3	32347	3498	3212	3674	3480	2911	1986	1405	1506	1813	2409	3051	3402
(13)	CDH26.7	10077	1231	1152	1416	1305	927	447	209	249	368	608	971	1194
(14)	Wind	WSAvg	2.6	2.5	2.4	2.3	2.3	2.1	1.9	2.6	3.6	3.8	3.7	2.4
(15) Precipitation	PrecAvg	1045	237	186	157	113	79	64	51	42	13	6	18	112
	PrecMax	1416	578	404	547	347	195	197	125	106	42	41	76	336
	PrecMin	787	49	65	13	29	12	10	16	8	2	0	0	0
	PrecStd	184	124	95	94	75	46	42	28	23	12	10	20	80
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.4	32.6	32.8	32.8	31.9	30.4	29.3	29.4	30.1	30.8	32.1	32.6
		MCWB	26.2	26.7	26.5	26.2	25.0	23.8	22.3	22.2	22.6	24.1	25.7	26.0
	2%	DB	31.8	32.0	32.2	32.1	31.3	29.9	28.7	28.8	29.5	30.2	31.4	31.9
		MCWB	26.1	26.4	26.4	26.0	24.9	23.5	22.2	22.0	22.5	23.7	25.0	25.7
	5%	DB	31.4	31.5	31.8	31.6	30.8	29.4	28.3	28.5	29.1	29.8	31.0	31.4
		MCWB	25.9	26.3	26.3	25.9	24.7	23.2	22.1	21.9	22.3	23.5	24.7	25.5
	10%	DB	30.9	30.9	31.3	31.1	30.2	29.0	27.9	28.1	28.6	29.4	30.5	31.0
		MCWB	25.8	26.1	26.2	25.7	24.5	22.9	22.1	21.8	22.2	23.3	24.4	25.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.7	27.7	27.2	26.2	25.2	24.0	24.1	24.1	25.2	26.6	27.0
		MCDB	31.0	31.4	31.5	31.2	30.3	28.8	27.5	27.9	28.6	29.5	31.1	31.1
	2%	WB	26.7	27.1	27.2	26.8	25.8	24.7	23.5	23.5	23.5	24.6	26.0	26.5
		MCDB	30.5	30.6	31.0	30.8	29.8	28.4	27.1	27.3	28.0	29.0	30.2	30.6
	5%	WB	26.4	26.7	26.9	26.5	25.5	24.2	23.2	23.0	23.1	24.2	25.5	26.1
		MCDB	30.2	30.2	30.6	30.4	29.4	27.9	26.7	26.8	27.7	28.7	29.7	30.2
	10%	WB	26.1	26.4	26.6	26.1	25.1	23.8	22.8	22.6	22.7	23.8	25.1	25.8
		MCDB	29.7	29.9	30.2	30.0	29.0	27.5	26.5	26.6	27.2	28.3	29.2	29.7
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	5.3	5.9	5.8	6.3	6.6	6.9	6.5	5.7	5.5	5.6	5.8
		MCDBR	5.8	5.9	6.5	6.2	6.5	6.8	7.2	6.7	6.0	5.7	5.9	6.3
		MCWBR	2.2	2.3	2.4	2.3	2.5	2.7	2.9	2.7	2.3	2.2	2.1	2.3
	5% WB	MCDBR	5.5	5.4	6.0	6.2	6.0	6.4	6.3	6.4	6.0	5.8	5.9	6.0
		MCWBR	2.3	2.4	2.5	2.5	2.6	2.8	3.0	3.0	2.5	2.5	2.4	2.4
(40) Clear-Sky Solar Irradiance	taub		0.418	0.425	0.402	0.388	0.380	0.369	0.362	0.372	0.391	0.410	0.422	0.407
	taud		2.525	2.501	2.588	2.613	2.610	2.615	2.628	2.586	2.508	2.468	2.461	2.539
	Ebn at Noon		926	914	918	900	877	872	887	903	913	916	916	934
	Edh at Noon		112	115	103	95	91	87	88	96	109	117	119	110
(44) All-Sky Solar Radiation	RadAvg		5.78	5.84	6.09	5.97	5.46	5.03	5.16	5.88	6.58	6.98	7.01	6.59
	RadStd		0.36	0.47	0.36	0.24	0.18	0.15	0.14	0.18	0.11	0.15	0.24	0.45

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page