

ILE JUAN DE NOVA, French Southern Territories

WMO: 619700

Lat: 17.055S

Lon: 42.712E

Elev: 10

StdP: 101.20

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.4	22.2	14.7	10.5	25.1	15.7	11.2	25.1	10.7	24.7	10.1	24.5	1.3	100	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	4.9	32.6	26.8	32.1	26.6	31.7	26.4	27.6	31.3	27.2	30.9	27.0	30.7	3.6	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.6	22.2	30.1	26.2	21.6	29.8	25.9	21.3	29.6	87.8	31.5	86.3	31.1	85.1	30.9	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	9.0	8.0	DB	19.6	33.9	1.4	2.0	18.7	35.3	17.9	36.5	17.1	37.6	16.1	39.0	(4)
(5)			WB	16.7	28.4	1.3	0.6	15.7	28.9	15.0	29.2	14.2	29.6	13.3	30.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.4	28.5	28.5	28.9	28.6	27.4	26.2	25.4	25.2	25.9	26.9	28.2	28.8	(6)
(7)		DBStd	1.62	1.15	1.08	0.97	0.88	0.91	0.79	0.83	0.78	0.71	0.84	0.79	0.98	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6341	575	518	586	557	540	486	478	471	477	524	545	584	(10)
(11)		CDD18.3	3299	317	285	328	307	282	236	220	212	227	266	295	326	(11)
(12)		CDH23.3	33718	3808	3420	4022	3582	2801	1847	1372	1302	1747	2517	3332	3970	(12)
(13)		CDH26.7	10422	1428	1276	1617	1261	656	263	119	131	307	640	1137	1587	(13)
(14)	Wind	WSAvg	4.0	3.7	3.5	3.4	4.3	4.7	4.8	4.9	4.2	3.9	3.8	3.5	3.0	(14)
(15)	Precipitation	PrecAvg	813	248	233	118	42	11	9	7	5	3	7	11	93	(15)
(16)		PrecMax	1458	871	895	318	220	56	60	62	30	30	109	74	548	(16)
(17)		PrecMin	262	24	35	10	0	0	0	0	0	0	0	0	10	(17)
(18)		PrecStd	316	186	193	81	47	15	15	13	8	7	22	20	106	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.8	32.7	33.0	32.4	31.0	29.7	28.9	29.0	29.7	30.9	32.1	33.1	(19)
(20)			MCWB	27.0	27.0	27.4	26.9	25.1	23.3	22.7	22.6	23.8	25.0	26.1	26.7	(20)
(21)		2%	DB	32.3	32.1	32.3	31.7	30.4	29.1	28.2	28.4	29.2	30.4	31.6	32.5	(21)
(22)			MCWB	26.8	26.8	27.0	26.3	24.7	23.2	22.3	22.4	23.5	24.7	25.8	26.5	(22)
(23)		5%	DB	31.7	31.5	31.8	31.2	30.0	28.6	27.8	27.9	28.8	29.9	31.2	32.0	(23)
(24)			MCWB	26.6	26.6	26.7	26.0	24.4	22.9	22.1	22.3	23.3	24.5	25.6	26.4	(24)
(25)		10%	DB	31.1	31.0	31.3	30.7	29.5	28.2	27.4	27.5	28.4	29.5	30.7	31.5	(25)
(26)			MCWB	26.4	26.4	26.4	25.7	24.1	22.6	21.8	22.1	23.1	24.2	25.4	26.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.8	28.0	28.2	27.7	26.2	24.8	23.9	24.0	25.0	25.9	26.8	27.6	(27)
(28)			MCD B	31.5	31.2	32.0	31.4	30.0	28.4	27.7	27.6	28.8	29.9	31.2	31.9	(28)
(29)		2%	WB	27.3	27.5	27.5	27.1	25.6	24.2	23.3	23.5	24.4	25.5	26.4	27.1	(29)
(30)			MCD B	31.0	30.8	31.4	30.7	29.4	27.8	27.0	27.1	28.2	29.3	30.6	31.4	(30)
(31)		5%	WB	27.0	27.1	27.1	26.7	25.1	23.8	23.0	23.1	24.0	25.1	26.1	26.8	(31)
(32)			MCD B	30.7	30.4	30.9	30.2	28.9	27.5	26.6	26.7	27.7	28.9	30.2	30.9	(32)
(33)		10%	WB	26.7	26.8	26.8	26.3	24.7	23.4	22.6	22.7	23.7	24.7	25.7	26.5	(33)
(34)			MCD B	30.2	30.0	30.5	29.8	28.4	27.1	26.3	26.3	27.3	28.4	29.7	30.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.7	4.8	4.9	4.3	4.3	4.3	4.2	4.9	5.3	5.4	5.4	5.3	(35)
(36)			MCDBR	5.5	5.3	5.3	4.8	4.5	4.6	4.6	5.4	5.7	5.8	5.8	5.7	(36)
(37)			MCWBR	2.2	2.3	2.3	2.1	2.0	2.3	2.3	2.4	2.3	2.3	2.2	2.1	(37)
(38)		5% WB	MCD BR	4.8	5.0	5.0	4.6	4.4	4.4	4.3	5.0	5.4	5.5	5.4	5.5	(38)
(39)			MCWBR	2.3	2.4	2.4	2.1	2.1	2.2	2.3	2.3	2.3	2.3	2.1	2.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.431	0.417	0.394	0.374	0.358	0.346	0.350	0.368	0.416	0.442	0.439	0.414	(40)	
(41)		taud	2.478	2.521	2.594	2.627	2.625	2.628	2.604	2.537	2.392	2.347	2.392	2.509	(41)	
(42)		Ebn at Noon	916	920	919	903	884	878	882	895	884	886	902	931	(42)	
(43)		Edh at Noon	118	112	101	92	86	83	87	99	121	132	128	114	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.85	6.12	6.06	5.74	5.17	4.72	4.90	5.64	6.50	7.08	7.32	6.90	(44)	
(45)		RadStd	0.61	0.53	0.43	0.29	0.12	0.14	0.15	0.17	0.11	0.20	0.35	0.46	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page