

ILE EUROPA, French Southern Territories

WMO: 619720

Lat: 22.344S

Lon: 40.341E

Elev: 20

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	64.0	65.1	51.6	56.7	70.8	53.4	60.7	71.3	24.9	72.7	23.0	73.1	5.1	160	0.378

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.2	90.1	78.9	89.1	78.6	88.2	78.3	81.0	87.1	80.3	86.4	79.8	85.9	8.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.2	151.7	84.9	78.6	148.5	84.5	78.0	145.4	84.1	44.7	87.3	43.9	86.7	43.3	86.1	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.6	21.1	19.1	DB	60.5	94.3	2.1	3.0	59.0	96.4	57.7	98.2	56.5	99.9	55.0	102.0
			WB	55.8	82.4	1.1	1.1	55.0	83.2	54.3	83.8	53.7	84.4	52.8	85.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	77.7	83.1	83.0	82.2	79.3	76.1	73.7	72.3	72.6	74.2	76.3	79.1	81.3
	DBStd	4.38	1.85	1.91	1.94	2.33	2.00	1.91	1.77	1.76	1.98	2.12	2.08	2.06
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10121	1026	924	997	880	808	711	690	700	725	816	874	970
	CDD65	4646	561	504	532	430	343	261	225	235	275	351	424	505
	CDH74	38863	6633	5862	5813	3729	1958	971	589	732	1311	2150	3733	5382
	CDH80	10489	2460	2121	1876	856	202	28	6	19	98	293	864	1666
(14) Wind	WSAvg	9.4	9.7	10.1	9.8	9.8	8.8	8.9	9.7	8.9	9.5	9.9	9.5	8.9
(15) Precipitation	PrecAvg	21.9	5.2	4.6	2.7	1.1	0.9	0.6	0.4	0.2	0.3	0.3	1.1	4.0
	PrecMax	33.9	19.6	23.7	8.4	4.8	4.5	2.0	1.5	1.4	2.6	1.1	4.8	11.6
	PrecMin	8.4	0.0	0.4	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2
	PrecStd	7.4	4.6	4.8	2.3	1.1	1.1	0.5	0.4	0.3	0.5	0.3	1.2	3.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.3	91.7	90.9	89.5	84.7	82.0	80.8	82.0	84.3	85.7	88.5	90.0
		MCWB	79.4	79.7	79.6	79.1	74.2	71.9	70.6	69.9	72.0	74.1	76.3	78.5
	2%	DB	89.9	89.9	89.4	87.5	83.3	80.8	79.3	80.0	82.2	84.1	86.7	88.6
		MCWB	79.0	78.8	79.0	77.7	73.3	71.0	69.9	70.2	72.7	74.5	76.7	78.1
	5%	DB	88.8	88.8	88.1	85.8	82.1	79.7	78.3	78.8	81.0	82.9	85.4	87.4
		MCWB	78.7	78.4	78.4	76.2	72.6	70.3	69.2	69.8	72.4	73.8	76.3	77.7
	10%	DB	87.8	87.7	86.9	84.3	81.0	78.6	77.2	77.7	79.7	81.7	84.2	86.2
		MCWB	78.4	78.2	77.7	75.1	71.8	69.5	68.4	69.1	71.7	73.1	75.6	77.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.8	81.8	81.5	80.1	77.4	75.3	73.5	73.8	76.1	77.7	80.2	81.0
		MCDB	88.2	88.3	87.5	87.3	82.0	80.1	78.1	78.0	80.8	82.7	84.7	86.6
	2%	WB	80.9	80.9	80.2	78.8	75.5	73.4	72.0	72.6	74.9	76.4	79.1	80.0
		MCDB	87.1	87.2	87.1	86.0	81.2	78.5	77.2	77.3	79.6	81.6	83.7	85.5
	5%	WB	80.1	80.1	79.5	77.6	74.3	72.1	70.9	71.6	73.8	75.4	78.2	79.1
		MCDB	86.2	86.3	86.3	84.0	80.4	77.9	76.6	76.9	78.8	80.9	83.0	85.0
	10%	WB	79.6	79.4	78.8	76.5	73.2	70.9	69.8	70.6	72.9	74.3	77.2	78.4
		MCDB	85.8	85.4	85.4	82.5	79.5	77.1	75.9	76.2	78.2	80.1	82.5	84.4
(35) Mean Daily Temperature Range	5% DB	MDBR	9.2	9.5	9.4	9.9	10.3	10.3	10.4	11.0	11.5	10.5	10.2	9.9
		MCDBR	10.7	11.0	11.1	11.6	11.5	11.7	12.0	12.5	13.4	12.1	11.6	10.9
	5% WB	MCWBR	4.0	4.3	4.3	4.9	5.4	5.7	5.9	5.9	6.3	5.5	5.0	4.5
		MCWBR	8.9	9.5	10.2	11.1	10.4	10.8	11.2	11.2	12.2	11.4	10.0	9.5
(40) Clear-Sky Solar Irradiance	taub		0.430	0.423	0.403	0.375	0.348	0.334	0.337	0.363	0.417	0.440	0.421	0.411
		taud	2.456	2.470	2.525	2.574	2.606	2.624	2.604	2.500	2.326	2.300	2.414	2.485
	Ebn at Noon		291	289	286	282	278	276	279	281	278	281	292	297
		Edh at Noon	38	37	34	30	27	25	26	31	40	43	40	37
(44) All-Sky Solar Radiation	RadAvg		2290	2222	2031	1721	1470	1336	1406	1688	1964	2178	2338	2360
	RadStd		153	132	121	58	46	36	31	32	46	88	89	121

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page