

AGALEGA, Mauritius

WMO: 619740

Lat: 10.380S

Lon: 56.610E

Elev: 13

StdP: 14.69

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	71.6	73.0	64.8	91.9	77.2	65.9	95.7	77.3	19.4	79.0	18.5	79.1	3.7	150	0.397

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.1	89.8	80.3	89.1	79.9	88.5	79.6	81.6	88.0	81.0	87.3	80.6	87.0	6.9	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.8	154.5	85.8	79.1	151.2	85.2	78.7	148.9	84.7	45.2	88.2	44.6	87.9	44.2	87.1	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.9	16.4	15.4	67.2	91.7	1.7	1.7	66.0	93.0	65.0	94.0	64.1	94.9	62.8	96.2		
			65.2	82.7	1.9	1.0	63.8	83.4	62.7	84.0	61.6	84.6	60.2	85.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.1	82.1	82.2	82.5	82.6	82.2	80.3	78.9	78.8	79.6	80.8	81.8	82.1
	DBStd	2.15	1.64	1.66	1.64	1.80	1.86	1.63	1.47	1.56	1.52	1.54	1.80	1.73
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11365	995	900	1008	979	998	908	895	892	889	954	953	994
	CDD65	5890	530	480	543	529	533	458	430	427	439	489	503	529
	CDH74	57790	5771	5182	5972	5839	5699	4094	3194	3069	3484	4498	5188	5800
	CDH80	15830	1858	1683	2105	2022	1647	719	397	399	598	986	1459	1957
Wind	WSAvg	7.8	4.1	4.4	4.0	5.5	8.3	10.5	10.4	11.4	11.5	10.0	8.1	5.1
Precipitation	PrecAvg	67.0	10.5	10.1	7.4	6.5	5.0	3.7	3.6	2.2	2.2	3.2	4.4	8.4
	PrecMax	109.8	19.6	17.9	14.2	19.8	13.3	8.8	8.1	5.7	5.4	14.8	12.8	28.0
	PrecMin	40.8	4.3	3.3	2.6	1.5	1.0	1.0	1.2	0.7	0.4	0.8	0.8	0.6
	PrecStd	13.7	3.8	4.1	2.7	3.9	3.3	2.0	1.9	1.2	1.3	2.7	2.9	6.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.8	90.5	90.7	90.3	88.9	86.8	85.2	85.3	86.2	87.8	89.5	90.3
		MCWB	80.0	81.1	80.8	80.9	79.6	77.7	75.8	75.1	75.8	78.6	79.6	79.8
	2%	DB	88.8	89.1	89.6	89.2	87.9	85.7	84.1	84.1	85.1	86.5	88.2	89.2
		MCWB	79.7	80.3	80.5	80.3	79.2	77.0	75.2	74.5	75.3	77.2	78.8	79.3
	5%	DB	88.0	88.1	88.7	88.3	87.1	84.8	83.2	83.2	84.3	85.6	87.3	88.4
		MCWB	79.3	79.8	80.1	79.9	78.7	76.4	74.7	74.2	74.8	76.5	78.2	78.9
	10%	DB	87.1	87.2	87.8	87.5	86.2	83.8	82.3	82.3	83.4	84.7	86.2	87.5
		MCWB	79.1	79.5	79.8	79.5	78.2	75.8	74.3	73.9	74.6	76.1	77.7	78.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.4	82.4	82.2	82.4	81.0	79.6	78.0	77.7	78.6	80.1	80.9	81.7
		MCDB	87.9	88.9	88.7	88.6	86.8	84.7	82.9	82.4	83.5	85.9	87.7	88.0
	2%	WB	80.7	81.1	81.3	81.3	80.4	78.6	76.8	76.4	77.3	79.0	80.1	80.7
		MCDB	87.0	87.5	87.8	87.7	86.3	83.7	82.0	81.4	82.4	84.2	86.5	87.2
	5%	WB	80.1	80.5	80.8	80.7	79.7	77.7	76.0	75.6	76.4	78.1	79.2	80.0
		MCDB	86.1	86.8	87.2	87.1	85.3	82.8	81.1	80.8	81.7	83.2	85.2	86.2
	10%	WB	79.6	79.8	80.2	80.0	79.1	77.0	75.3	74.9	75.6	77.3	78.6	79.4
		MCDB	85.4	85.8	86.4	86.0	84.4	82.0	80.3	80.4	81.2	82.2	84.2	85.3
Mean Daily Temperature Range	5% DB	MDBR	9.5	9.6	10.5	10.1	8.1	7.4	7.5	7.8	8.2	8.5	9.1	10.6
		MCDBR	10.7	11.3	11.7	10.7	8.7	8.2	8.2	8.4	8.8	9.2	10.2	12.0
		MCWBR	4.4	4.8	4.8	4.6	3.9	3.9	3.8	3.8	4.0	4.1	4.4	4.9
	5% WB	MCDBR	10.0	10.4	10.6	10.2	8.0	7.4	7.3	7.7	8.1	9.2	10.4	10.4
	MCWBR	4.4	4.8	4.7	4.7	4.0	4.0	4.0	4.0	4.3	4.1	4.2	4.6	
Clear-Sky Solar Irradiance	taub	0.399	0.407	0.392	0.387	0.397	0.413	0.414	0.409	0.416	0.420	0.404	0.391	
	taud	2.588	2.557	2.619	2.627	2.566	2.475	2.464	2.476	2.459	2.469	2.540	2.590	
	Ebn at Noon	299	295	294	286	274	264	266	276	283	288	295	301	
	Edh at Noon	33	34	32	30	30	32	33	34	36	37	35	33	
All-Sky Solar Radiation	RadAvg	1888	1894	1941	1853	1656	1531	1584	1794	1980	2030	2100	2078	
	RadStd	91	184	94	89	98	98	75	62	82	108	164	177	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page