

RODRIGUES POINTE CANON, Mauritius

WMO: 619880

Lat: 19.6811S

Lon: 63.4264E

Elev: 62

StdP: 100.58

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.1	19.7	12.5	9.1	21.4	13.4	9.7	21.7	12.6	22.7	12.0	22.4	5.3	130	0.480

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.4	31.1	25.9	30.4	25.6	30.0	25.3	26.8	29.6	26.3	29.1	26.0	28.7	6.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.0	21.6	28.7	25.6	21.0	28.3	25.2	20.4	27.8	84.5	29.7	82.6	29.4	81.0	28.8	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 11.9	10.9	10.1	DB	17.7	32.4	1.5	0.8	16.6	33.0	15.8	33.5	14.9	33.9	13.9	34.5	(4)
(5)			WB	14.7	27.8	0.9	0.4	14.1	28.1	13.5	28.4	13.0	28.6	12.3	28.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	25.2	27.4	27.6	27.4	26.6	25.1	23.8	22.8	22.6	23.0	24.0	25.3	26.7	(6)
(7)		DBStd	2.10	1.02	1.05	1.04	0.93	1.08	1.07	1.06	0.96	0.93	1.11	1.13	1.03	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	5537	539	492	539	497	468	414	397	389	390	433	461	517	(10)
(11)		CDD18.3	2495	281	258	281	247	210	164	138	131	140	175	211	258	(11)
(12)		CDH23.3	16723	2766	2627	2749	2096	1155	512	249	213	304	623	1248	2181	(12)
(13)	CDH26.7	3072	671	654	632	337	101	16	4	1	3	37	169	446	(13)	
(14)	Wind	WSAvg	6.0	6.0	5.6	5.6	5.8	5.5	6.0	6.3	6.5	6.4	6.3	6.0	6.0	(14)
(15)	Precipitation	PrecAvg	1053	138	181	147	122	87	72	83	63	47	43	61	(15)	
(16)		PrecMax	1699	409	852	465	339	208	224	210	154	131	185	172	273	(16)
(17)		PrecMin	433	29	10	29	21	26	14	13	28	6	9	5	9	(17)
(18)		PrecStd	268	98	162	100	78	46	35	35	25	25	31	34	54	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.9	31.8	31.8	30.6	29.2	27.9	27.1	26.7	27.1	28.2	30.0	31.1	(19)
MCWB			25.7	26.2	26.6	25.7	24.8	23.1	22.5	21.6	21.6	22.7	24.3	25.3	(20)	
2%		DB	31.0	31.0	30.8	29.8	28.4	27.1	26.1	25.9	26.2	27.8	29.1	30.2	(21)	
		MCWB	25.6	26.3	26.1	25.2	23.9	22.1	21.6	21.1	21.1	22.4	23.8	24.8	(22)	
5%		DB	30.1	30.2	30.0	29.1	27.9	26.3	25.2	25.1	25.8	26.9	28.2	29.7	(23)	
		MCWB	25.2	25.8	25.7	24.7	23.4	21.7	21.0	20.5	20.8	22.0	23.3	24.6	(24)	
10%		DB	29.6	29.7	29.3	28.5	27.1	25.8	24.8	24.5	25.0	26.1	27.7	28.9	(25)	
		MCWB	24.9	25.6	25.2	24.3	22.8	21.4	20.7	20.1	20.4	21.5	23.0	24.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.8	27.5	27.3	26.5	25.9	24.1	23.7	22.9	22.7	24.0	25.5	26.4	(27)
MCD B			30.0	30.1	30.1	29.1	28.2	26.6	25.7	25.2	25.6	26.6	28.1	29.3	(28)	
2%		WB	26.2	26.9	26.7	26.0	25.1	23.1	22.7	22.1	22.0	23.2	24.7	25.8	(29)	
		MCD B	29.2	29.7	29.5	28.5	27.4	25.8	24.9	24.5	25.1	26.0	27.6	28.7	(30)	
5%		WB	25.9	26.4	26.2	25.5	24.3	22.6	22.1	21.4	21.5	22.7	24.2	25.3	(31)	
		MCD B	28.9	29.1	28.9	27.9	26.7	25.3	24.3	24.0	24.5	25.6	27.1	28.2	(32)	
10%		WB	25.5	26.0	25.9	25.1	23.7	22.0	21.4	20.8	21.0	22.2	23.6	24.9	(33)	
		MCD B	28.4	28.6	28.5	27.4	26.2	24.8	23.8	23.6	24.0	25.2	26.6	27.8	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.7	4.4	4.3	4.2	4.3	4.4	4.2	4.4	4.6	4.9	5.0	5.0	(35)
MCDBR			5.5	5.0	4.9	4.8	4.9	4.8	4.7	4.9	5.2	5.5	5.6	5.7	(36)	
MCWBR			2.4	2.3	2.4	2.5	2.6	2.7	2.8	2.7	2.6	2.6	2.6	2.4	(37)	
5% WB		MCDBR	5.0	4.6	4.5	4.4	4.6	4.5	4.4	4.5	4.9	5.1	5.3	5.1	(38)	
		MCWBR	2.4	2.4	2.4	2.4	2.6	2.8	2.8	2.9	2.7	2.7	2.7	2.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.400	0.415	0.411	0.390	0.364	0.346	0.353	0.353	0.367	0.376	0.374	0.384	(40)	
taud		2.542	2.507	2.498	2.558	2.613	2.615	2.598	2.584	2.525	2.519	2.558	2.564	(41)		
Ebn at Noon		946	920	899	880	869	867	872	904	927	946	963	960	(42)		
Edh at Noon		111	113	110	97	85	82	86	93	105	111	109	109	(43)		
(44)	All-Sky Solar Radiation	RadAvg	7.25	6.70	6.23	5.28	4.53	4.15	4.26	5.06	5.97	6.75	7.40	7.58	(44)	
(45)		RadStd	0.50	0.42	0.28	0.30	0.21	0.15	0.14	0.14	0.16	0.26	0.24	0.34	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.63	+0.72	+0.97	+0.78	+0.40	+0.29	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page