

MAURITIUS VACOAS, MauritiusWMO: **619950**Lat: **20.2971S**Lon: **57.4969E**Elev: **1394**StdP: **13.97**Time Zone: **4.00 (E04)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	59.0	60.1	52.6	61.9	63.6	54.2	65.8	64.2	19.2	67.0	17.9	67.0	5.2	130	0.298

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.9	83.6	74.6	82.6	74.1	81.7	73.6	76.6	80.5	76.0	79.9	75.3	79.3	7.2	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.5	140.9	78.5	74.8	137.3	78.0	74.1	134.2	77.5	41.2	81.0	40.5	80.1	39.9	79.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.7	15.9	14.3	DB	55.1	86.4	2.0	1.4	53.7	87.4	52.5	88.2	51.4	89.0	50.0	90.0	(4)
(5)			WB	53.1	78.5	2.6	1.3	51.2	79.5	49.7	80.3	48.2	81.0	46.3	82.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	71.5	76.3	76.6	76.0	74.4	70.8	68.0	66.4	66.4	67.3	69.6	72.2	74.9	(6)	
	DBStd	4.31	1.62	1.71	1.73	1.81	2.31	2.26	2.07	1.98	2.02	2.10	2.19	1.81	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	25	0	0	0	0	0	3	8	8	5	1	0	0	(9)	
	CDD50	7867	816	746	805	732	646	539	510	508	518	607	667	773	(10)	
	CDD65	2416	351	326	340	282	181	92	53	51	73	142	217	308	(11)	
	CDH74	8159	1675	1608	1496	884	284	50	17	13	28	172	614	1318	(12)	
	CDH80	686	191	186	138	34	5	2	1	0	0	2	15	112	(13)	
(14) Wind	WSAvg	7.6	7.5	7.2	7.2	7.5	7.0	7.8	8.7	8.7	8.1	7.8	6.9	6.9	(14)	
(15) Precipitation	PrecAvg	57.0	8.4	9.7	8.6	5.4	4.4	2.8	3.5	2.6	2.3	1.7	2.5	5.1	(15)	
	PrecMax	89.1	25.4	25.2	25.6	13.9	11.8	6.9	6.1	4.4	9.8	8.1	12.5	21.1	(16)	
	PrecMin	29.2	0.0	2.2	0.2	0.0	0.9	0.8	1.0	0.2	0.1	0.3	0.4	0.0	(17)	
	PrecStd	11.9	6.3	6.1	5.6	3.2	2.7	1.5	1.3	1.3	1.9	1.7	2.4	5.0	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.5	84.9	84.2	82.5	80.7	77.7	75.9	75.5	76.6	79.2	81.8	84.0	(19)	
		MCWB	74.9	75.7	75.3	73.9	72.4	69.2	67.0	66.7	67.0	68.8	71.7	73.8	(20)	
	2%	DB	83.3	83.5	82.7	81.0	78.6	75.3	73.5	73.3	74.7	77.3	80.1	82.4	(21)	
		MCWB	74.4	75.3	74.5	73.1	71.0	67.7	66.2	65.4	66.1	68.2	70.6	72.8	(22)	
	5%	DB	82.1	82.3	81.6	79.8	77.0	73.8	71.9	71.8	73.3	75.9	78.9	81.3	(23)	
		MCWB	73.9	74.8	74.0	72.5	70.1	66.9	65.4	64.7	65.3	67.5	70.0	72.1	(24)	
	10%	DB	80.9	81.0	80.4	78.6	75.6	72.4	70.5	70.5	72.0	74.6	77.6	80.1	(25)	
		MCWB	73.4	74.5	73.5	72.0	69.2	66.1	64.7	64.1	64.7	66.8	69.3	71.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.1	77.9	77.3	75.8	74.8	71.1	69.2	68.9	69.2	71.5	73.8	75.9	(27)	
		MCDB	81.6	81.5	81.0	79.6	78.2	75.7	72.7	72.4	72.8	75.6	78.7	81.2	(28)	
	2%	WB	76.1	77.0	76.2	74.7	72.7	69.1	67.7	67.3	67.5	70.0	72.5	74.6	(29)	
		MCDB	80.5	80.7	80.0	78.5	76.5	72.9	71.2	70.9	71.9	74.4	77.3	79.9	(30)	
	5%	WB	75.4	76.2	75.4	73.8	71.3	68.2	66.6	66.2	66.6	69.0	71.5	73.8	(31)	
		MCDB	79.6	79.9	79.3	77.5	75.0	71.8	70.0	69.7	71.1	73.5	76.2	78.6	(32)	
	10%	WB	74.6	75.5	74.6	73.0	70.3	67.3	65.8	65.1	65.8	68.0	70.5	73.0	(33)	
		MCDB	78.6	79.0	78.4	76.6	73.9	70.8	69.1	68.7	70.1	72.5	75.3	77.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.3	8.9	9.0	8.8	9.4	9.0	8.7	8.9	9.7	10.3	10.9	10.6	(35)	
		MCDBR	11.0	10.6	10.7	10.2	11.3	10.9	10.7	10.6	11.4	11.8	12.2	12.0	(36)	
	5% WB	MCWBR	3.9	4.3	4.2	4.0	5.0	5.1	5.0	4.7	4.5	4.4	4.3	4.2	(37)	
		MCWBR	9.4	9.2	9.0	9.0	9.9	9.5	9.4	9.4	10.2	10.4	10.8	10.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.384	0.396	0.383	0.361	0.342	0.324	0.326	0.328	0.339	0.353	0.354	0.363	(40)	
		taud	2.559	2.521	2.558	2.608	2.641	2.648	2.643	2.625	2.560	2.536	2.573	2.595	(41)	
	Ebn at Noon		305	297	294	288	282	282	285	295	302	307	312	311	(42)	
		Edh at Noon	35	36	33	29	26	25	26	28	32	35	34	33	(43)	
(44) All-Sky Solar Radiation	RadAvg		2145	2012	1864	1632	1375	1254	1301	1536	1844	2092	2265	2287	(44)	
	RadStd		141	120	109	85	58	40	46	41	63	61	77	120	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)		+1.08	+1.17	+0.72	+0.49	N/A	N/A	N/A	N/A	+389	+389

Nomenclature: See separate page