

ILE DE LA POSSESSION, French Southern Territories

WMO: 619970

Lat: 46.4325S

Lon: 51.8567E

Elev: 479

StdP: 14.44

Time Zone: 5.00 (E05)

Period: 95-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	29.1	30.3	18.3	14.0	34.7	20.4	15.6	33.7	57.9	41.9	54.2	43.0	27.5	200	1.196

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.8	61.0	57.5	58.5	55.5	56.4	53.6	58.4	60.2	56.2	57.9	54.1	55.9	27.4	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.3	71.4	59.6	55.2	66.0	57.4	53.1	61.1	55.1	25.6	60.3	24.2	58.0	22.9	56.0	66.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 52.0	47.6	44.2	25.8	67.8	1.5	3.5	24.7	70.3	23.9	72.4	23.1	74.4	22.0	76.9		
(5)			24.1	61.6	1.1	2.3	23.4	63.3	22.7	64.6	22.1	65.9	21.4	67.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	41.8	46.2	46.7	46.0	43.9	41.0	39.1	38.4	38.4	38.5	39.4	40.9	43.3		
	DBStd	5.37	4.14	4.27	4.27	4.86	4.48	4.66	4.41	4.65	4.58	4.20	4.02	3.99		
	HDD50	3069	134	111	140	192	280	328	361	359	347	330	276	211		
	HDD65	8472	584	513	589	632	743	777	826	823	796	794	724	671		
	CDD50	71	15	19	15	10	3	0	1	0	0	1	2	5		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	22.8	21.3	20.0	20.4	21.7	24.5	24.8	25.2	21.9	23.8	23.7	23.3	22.6		
	PrecAvg	80.9	6.1	5.6	6.7	6.1	7.3	7.1	7.0	7.3	7.1	6.6	6.3	6.4		
(15) Precipitation	PrecMax	118.8	10.7	12.7	13.5	13.6	15.2	12.0	9.5	17.4	13.0	11.4	11.9	15.8		
	PrecMin	36.4	0.0	0.0	1.5	0.0	0.0	1.0	1.9	2.0	0.1	1.6	1.4	0.0		
	PrecStd	18.9	2.7	2.4	3.0	3.4	3.5	2.9	1.9	3.0	2.7	2.0	2.5	3.7		
	PrecStd	18.9	2.7	2.4	3.0	3.4	3.5	2.9	1.9	3.0	2.7	2.0	2.5	3.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.8	64.1	62.2	61.1	58.2	54.7	53.8	53.2	53.9	57.3	58.3	60.4		
		MCWB	59.8	60.4	59.4	58.0	53.9	51.4	50.8	48.6	50.2	53.0	52.0	55.2		
	2%	DB	60.1	59.5	59.3	58.1	53.9	51.7	51.0	50.6	50.9	52.2	53.3	55.7		
		MCWB	56.0	56.8	57.8	55.6	51.0	49.3	49.2	48.1	48.0	48.8	50.7	52.5		
	5%	DB	56.7	56.8	56.6	55.4	51.5	49.6	48.5	48.7	48.5	49.3	50.2	52.6		
		MCWB	53.8	54.4	54.6	53.4	49.2	47.8	47.0	46.7	46.4	46.8	47.7	50.1		
	10%	DB	53.6	54.2	53.5	52.2	48.6	47.2	46.0	46.4	46.0	46.6	47.4	49.9		
		MCWB	50.9	52.1	51.4	50.4	46.8	45.7	44.5	45.0	44.2	44.2	44.8	47.2		
	0.4%	WB	60.3	60.6	60.3	59.1	54.7	52.3	51.9	50.7	51.8	53.2	54.0	56.1		
		MCDB	64.0	62.7	61.5	61.0	56.4	53.7	53.3	51.7	53.5	56.4	56.9	59.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	56.8	57.3	58.1	56.4	52.2	49.9	49.5	48.9	48.8	49.4	51.0	53.3		
		MCDB	59.2	58.5	59.4	58.0	54.0	50.8	50.8	50.1	49.9	51.5	53.0	55.4		
	5%	WB	54.1	54.3	55.0	54.0	49.9	47.9	47.3	47.1	46.5	47.1	47.9	50.5		
		MCDB	56.3	55.7	56.2	55.7	51.4	49.2	48.6	48.3	48.0	49.1	49.4	52.3		
	10%	WB	51.2	52.0	51.7	51.4	47.3	45.6	44.8	44.8	44.3	44.4	44.9	47.9		
		MCDB	53.0	53.5	53.0	52.8	48.7	47.0	45.8	46.0	46.0	46.3	46.7	49.5		
	5% DB	MDBR	10.7	9.8	9.6	8.9	8.3	8.1	8.1	8.3	8.8	9.0	9.1	9.6		
		MCDBR	16.2	14.7	14.5	14.4	13.6	13.3	12.6	11.6	13.3	13.5	14.2	14.9		
		MCWBR	14.0	12.9	14.4	13.6	13.5	13.1	12.6	11.7	12.6	11.8	13.0	12.9		
		MCWBR	16.0	14.3	14.5	14.0	13.5	12.9	12.5	11.9	13.2	13.5	13.6	14.7		
(35) Mean Daily Temperature Range	5% WB	MCWBR	15.2	13.5	14.5	13.3	13.8	13.1	12.7	12.2	13.1	12.5	13.3	13.3		
		MCWBR	15.2	13.5	14.5	13.3	13.8	13.1	12.7	12.2	13.1	12.5	13.3	13.3		
	Clear-Sky Solar Irradiance	taub	0.340	0.335	0.332	0.323	0.330	0.331	0.339	0.351	0.364	0.348	0.344	0.346		
		taud	2.524	2.555	2.559	2.559	2.404	2.319	2.323	2.355	2.342	2.437	2.476	2.481		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	311	303	287	264	227	207	218	245	269	294	307	311		
		Edh at Noon	34	31	28	23	22	21	23	28	34	34	35	36		
(44) All-Sky Solar Radiation	RadStd	RadAvg	1718	1417	1042	626	393	273	316	534	865	1241	1560	1769		
		RadStd	130	116	56	38	23	19	19	42	66	95	128	145		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page