

ILE DE LA POSSESSION, French Southern Territories

WMO: 619970

Lat: 46.4325S

Lon: 51.8567E

Elev: 146

StdP: 99.58

Time Zone: 5.00 (E05)

Period: 95-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	-1.6	-0.9	-7.6	2.0	1.5	-6.4	2.2	0.9	25.9	5.5	24.2	6.1	12.3	200	1.196

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.5	16.1	14.1	14.7	13.0	13.5	12.0	14.7	15.7	13.4	14.4	12.3	13.3	12.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.1	10.2	15.3	12.9	9.4	14.1	11.7	8.7	12.8	41.6	15.7	38.3	14.5	35.4	13.3	19.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.3	21.3	19.7	-3.4	19.9	0.8	2.0	-4.0	21.3	-4.5	22.4	-5.0	23.5	-5.5	25.0	
			DB												
			WB	-4.4	16.4	0.6	1.3	-4.8	17.4	-5.1	18.1	-5.5	18.9	-5.9	19.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.4	7.9	8.2	7.8	6.6	5.0	3.9	3.5	3.6	3.6	4.1	4.9	6.3
	DBStd	2.98	2.30	2.37	2.37	2.70	2.49	2.59	2.45	2.59	2.54	2.33	2.24	2.22
	HDD10.0	1705	74	62	78	107	156	182	201	199	193	183	153	117
	HDD18.3	4707	324	285	327	351	413	432	459	457	442	441	402	373
	CDD10.0	39	8	11	8	6	2	0	1	0	0	1	1	3
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	10.2	9.5	8.9	9.1	9.7	11.0	11.1	11.3	9.8	10.6	10.6	10.4	10.1
Precipitation	PrecAvg	2056	154	142	171	156	185	180	177	185	181	168	161	163
	PrecMax	3017	271	323	344	345	387	305	241	442	329	290	301	402
	PrecMin	924	0	0	39	0	0	25	49	51	3	40	36	0
	PrecStd	480	69	61	75	87	90	74	48	75	68	51	64	93
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.8	17.8	16.8	16.2	14.6	12.6	12.1	11.8	12.2	14.1	14.6	15.8
		MCWB	15.4	15.8	15.2	14.4	12.1	10.8	10.5	9.2	10.1	11.7	11.1	12.9
	2%	DB	15.6	15.3	15.2	14.5	12.2	10.9	10.6	10.3	10.5	11.2	11.8	13.2
		MCWB	13.4	13.8	14.3	13.1	10.6	9.6	9.6	8.9	8.9	9.3	10.4	11.4
	5%	DB	13.7	13.8	13.6	13.0	10.8	9.8	9.2	9.3	9.2	9.6	10.1	11.5
		MCWB	12.1	12.5	12.5	11.9	9.6	8.8	8.3	8.2	8.0	8.2	8.7	10.1
	10%	DB	12.0	12.3	11.9	11.2	9.2	8.4	7.8	8.0	7.8	8.1	8.6	9.9
		MCWB	10.5	11.2	10.8	10.2	8.2	7.6	7.0	7.2	6.8	6.8	7.1	8.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.7	15.9	15.7	15.0	12.6	11.3	11.1	10.4	11.0	11.8	12.2	13.4
		MCDB	17.8	17.0	16.4	16.1	13.5	12.1	11.9	10.9	11.9	13.6	13.8	15.1
	2%	WB	13.8	14.0	14.5	13.5	11.2	9.9	9.7	9.4	9.3	9.7	10.6	11.8
		MCDB	15.1	14.7	15.2	14.4	12.2	10.5	10.4	10.1	10.0	10.8	11.7	13.0
	5%	WB	12.3	12.4	12.8	12.2	9.9	8.8	8.5	8.4	8.1	8.4	8.9	10.3
		MCDB	13.5	13.2	13.5	13.2	10.8	9.5	9.2	9.1	8.9	9.5	9.7	11.3
	10%	WB	10.7	11.1	11.0	10.8	8.5	7.6	7.1	7.1	6.8	6.9	7.2	8.8
		MCDB	11.7	11.9	11.7	11.6	9.3	8.3	7.7	7.8	7.8	8.0	8.2	9.7
Mean Daily Temperature Range	5% DB	MDBR	6.0	5.5	5.3	4.9	4.6	4.5	4.5	4.6	4.9	5.0	5.0	5.3
		MCDBR	9.0	8.2	8.1	8.0	7.5	7.4	7.0	6.4	7.4	7.5	7.9	8.3
		MCWBR	7.8	7.2	8.0	7.5	7.5	7.3	7.0	6.5	7.0	6.5	7.2	7.2
	5% WB	MCDBR	8.9	8.0	8.1	7.8	7.5	7.1	6.9	6.6	7.4	7.5	7.6	8.2
		MCWBR	8.4	7.5	8.0	7.4	7.7	7.3	7.1	6.8	7.3	7.0	7.4	7.4
Clear-Sky Solar Irradiance	taub	0.340	0.335	0.332	0.323	0.330	0.331	0.339	0.351	0.364	0.348	0.344	0.346	
	taud	2.524	2.555	2.559	2.559	2.404	2.319	2.323	2.355	2.342	2.437	2.476	2.481	
	Ebn at Noon	979	954	905	831	716	653	687	773	848	928	968	979	
	Edh at Noon	107	97	87	73	68	66	72	87	106	108	111	113	
All-Sky Solar Radiation	RadAvg	5.42	4.47	3.29	1.98	1.24	0.86	0.99	1.69	2.73	3.91	4.92	5.58	
	RadStd	0.41	0.36	0.18	0.12	0.07	0.06	0.06	0.13	0.21	0.30	0.41	0.46	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page