

PORT-AUX-FRANCAIS, French Southern Territories

WMO: 619980

Lat: 49.3522S

Lon: 70.2433E

Elev: 30

StdP: 100.97

Time Zone: 5.00 (E05)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	-3.2	-2.3	-7.5	2.0	-0.9	-6.6	2.2	-0.2	25.2	6.3	23.2	5.7	9.8	270	1.159

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.7	16.3	12.2	15.0	11.5	13.6	10.7	13.0	15.4	12.0	14.3	11.1	13.2	9.9	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.5	8.5	14.5	10.6	8.0	13.4	9.7	7.5	12.4	36.9	15.5	34.4	14.4	32.1	13.3	19.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.7	19.4	17.7	DB	-5.3	19.9	1.2	1.2	-6.2	20.8	-6.9	21.5	-7.6	22.1	-8.5	23.0	(4)
(5)			WB	-6.1	15.3	1.2	0.9	-7.0	16.0	-7.7	16.5	-8.4	17.0	-9.3	17.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.0	8.1	8.4	7.7	6.2	3.9	2.6	2.3	2.3	2.7	3.8	5.0	7.0		
	DBStd	3.30	2.28	2.36	2.41	2.58	2.38	2.48	2.45	2.58	2.28	2.38	2.18	2.18		
	HDD10.0	1866	68	56	79	117	191	221	239	238	220	192	149	97		
	HDD18.3	4867	317	277	328	363	448	471	497	497	470	449	399	351		
	CDD10.0	40	9	12	9	4	1	0	0	0	0	1	1	4		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	9.6	9.4	8.8	9.1	9.0	9.6	9.6	9.7	10.2	10.4	10.0	9.8	9.2		
(15) Precipitation	PrecAvg	673	50	44	60	57	71	73	65	54	52	48	49	51		
	PrecMax	924	83	83	132	188	149	171	120	118	125	116	101	137		
	PrecMin	444	6	10	29	11	17	13	21	9	19	11	16	13		
	PrecStd	150	21	21	29	38	37	40	27	23	26	25	22	26		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.1	18.6	17.4	15.7	12.4	11.0	10.6	10.7	11.5	13.0	14.8	16.8		
		MCWB	13.1	13.9	13.2	12.9	10.4	9.2	8.6	8.4	9.0	9.5	9.8	12.0		
	2%	DB	15.7	16.1	15.2	14.0	10.9	9.5	9.3	9.3	9.5	10.7	11.8	14.2		
		MCWB	11.5	12.1	12.1	11.9	9.3	8.0	7.8	7.6	7.4	8.1	8.6	10.5		
	5%	DB	14.1	14.5	13.5	12.3	9.6	8.1	8.2	8.2	8.1	9.1	10.2	12.4		
		MCWB	10.7	11.3	11.1	10.5	8.1	6.7	6.9	6.6	6.4	6.9	7.6	9.3		
	10%	DB	12.5	12.9	12.1	10.9	8.2	6.7	6.7	6.8	6.8	7.9	8.9	11.1		
		MCWB	9.4	10.3	10.0	9.1	6.6	5.3	5.3	5.3	5.0	5.9	6.5	8.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.0	14.7	13.7	13.2	10.8	9.3	9.0	8.8	9.3	10.2	10.6	12.4		
		MCDB	16.8	18.0	16.4	15.1	12.1	10.7	10.3	10.1	10.9	12.2	13.4	15.5		
	2%	WB	12.4	12.9	12.4	11.9	9.5	8.1	8.0	7.7	7.7	8.4	9.2	11.0		
		MCDB	15.0	15.4	14.7	13.8	10.7	9.4	9.1	9.0	9.1	10.3	11.3	13.6		
	5%	WB	10.9	11.7	11.3	10.6	8.3	6.9	7.0	6.7	6.5	7.2	8.0	9.8		
		MCDB	13.5	13.9	13.3	12.2	9.6	8.0	8.1	7.9	8.0	8.8	9.9	12.1		
	10%	WB	9.7	10.6	10.2	9.3	6.7	5.5	5.6	5.3	5.1	6.0	6.9	8.6		
		MCDB	12.2	12.7	12.0	10.8	8.1	6.6	6.8	6.6	6.6	7.8	8.7	10.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.7	6.7	6.5	5.8	4.8	4.6	4.8	4.9	5.2	5.9	6.1	6.5		
		MCDBR	9.6	9.4	8.9	8.2	7.6	7.1	7.0	7.2	7.5	8.0	8.4	8.8		
	5% WB	MCWBR	7.0	6.8	7.3	7.2	7.3	6.9	6.8	6.6	6.9	6.8	6.7	6.7		
		MCWBR	9.0	8.8	8.7	8.1	7.6	7.2	7.0	7.2	7.4	8.0	8.0	8.6		
(40) Clear-Sky Solar Irradiance	taub		0.344	0.336	0.334	0.322	0.326	0.327	0.336	0.350	0.347	0.349	0.338	0.341		
		taud	2.484	2.524	2.518	2.520	2.330	2.233	2.228	2.264	2.366	2.401	2.466	2.477		
	Ebn at Noon		967	942	887	806	673	596	638	740	852	916	967	979		
		Edh at Noon	109	98	88	71	66	63	72	89	100	110	111	112		
(44) All-Sky Solar Radiation	RadAvg		5.24	4.41	3.11	1.84	1.04	0.70	0.81	1.44	2.61	3.88	4.95	5.61		
	RadStd		0.30	0.24	0.17	0.09	0.06	0.03	0.06	0.10	0.17	0.20	0.30	0.33		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page