

AJDABIYA, Libyan Arab Jamahiriya

WMO: 620550

Lat: 30.717N

Lon: 20.167E

Elev: 7

StdP: 101.24

Time Zone: 2.00 (E02)

Period: 90-11

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.5	7.5	-4.3	2.6	22.1	-2.0	3.2	20.3	11.4	16.8	10.1	17.5	0.5	180	0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.3	38.9	21.2	36.9	21.1	35.2	20.9	25.2	31.4	24.5	30.1	23.9	29.3	4.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.6	18.5	27.5	23.0	17.7	27.0	22.3	17.0	27.0	76.9	31.5	73.8	30.2	71.7	29.1	32.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.4	9.3	8.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.5	13.9	14.2	16.9	20.5	24.2	27.3	27.4	28.0	27.4	24.0	18.9	14.9
	DBStd	6.01	1.78	2.76	3.18	3.78	3.88	3.24	1.78	1.58	2.71	2.78	2.58	2.33
	HDD10.0	1	0	1	0	0	0	0	0	0	0	0	0	0
	HDD18.3	473	137	122	68	16	1	0	0	0	0	1	21	109
	CDD10.0	4196	122	117	213	314	441	518	539	558	522	433	267	153
	CDD18.3	1627	1	4	23	80	182	268	281	299	272	176	38	3
	CDH23.3	16718	3	39	207	783	1839	2998	2903	3274	2934	1458	260	19
Wind	WSAvg	3.3	2.5	3.1	3.3	4.1	4.1	3.7	3.9	3.7	3.2	2.9	2.5	2.6
	PrecAvg	150	45	19	10	4	1	0	0	0	2	8	18	37
	PrecMax	287	197	61	34	30	14	1	0	0	36	48	66	103
	PrecMin	82	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	50	34	17	8	7	3	0	0	0	6	10	19	30
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.2	27.9	31.5	37.3	40.0	41.3	39.1	38.0	40.6	36.4	31.5	25.8
		MCWB	12.5	14.1	15.7	17.0	20.9	21.7	20.9	22.8	22.6	20.2	17.9	14.2
	2%	DB	20.9	23.9	27.7	33.1	36.5	38.9	36.2	35.6	37.7	33.8	28.3	22.6
		MCWB	12.6	13.1	14.4	17.3	19.3	21.2	21.9	22.4	23.1	19.4	16.7	13.8
	5%	DB	19.4	21.0	25.4	30.6	34.1	36.7	33.9	33.8	35.4	31.9	26.2	21.0
		MCWB	12.7	13.1	13.8	16.0	19.1	20.4	21.7	22.4	22.2	19.2	16.3	13.8
	10%	DB	18.3	19.2	23.2	28.0	31.8	34.3	32.2	32.4	33.3	29.9	24.3	19.7
		MCWB	12.5	12.4	13.3	15.6	18.3	20.3	21.7	22.6	21.4	19.0	16.0	13.5
	0.4%	WB	15.5	16.2	17.9	20.2	24.0	25.1	25.3	25.9	28.1	23.2	20.3	17.1
		MCDB	19.5	23.9	25.6	31.7	34.1	35.4	32.7	30.8	36.4	30.3	24.9	21.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	14.4	15.0	16.5	18.4	21.5	23.3	24.4	25.1	25.2	21.9	18.8	15.7
		MCDB	18.3	21.3	23.0	28.3	31.9	31.8	30.0	30.1	31.7	28.5	24.5	20.0
	5%	WB	13.6	14.1	15.4	17.3	20.3	22.2	23.9	24.5	24.1	21.2	17.7	15.0
		MCDB	17.7	18.8	21.7	26.8	30.2	30.4	28.8	29.5	30.3	27.6	24.1	19.2
	10%	WB	13.1	13.3	14.5	16.4	19.3	21.4	23.4	24.0	23.2	20.4	16.9	14.2
		MCDB	17.2	17.8	20.9	25.2	28.2	29.7	28.4	28.9	29.4	26.9	22.9	18.5
Mean Daily Temperature Range	5% DB	MDBR	9.4	9.7	11.1	11.6	11.6	12.0	10.3	10.3	11.2	11.2	10.7	9.2
		MCDBR	10.8	12.5	14.6	15.4	15.2	15.3	13.1	12.0	13.5	13.7	12.6	11.1
		MCWBR	5.7	5.8	5.8	5.8	6.0	5.5	4.6	4.2	5.5	5.4	6.1	5.9
	5% WB	MCDBR	9.6	10.3	12.2	13.4	12.9	12.7	10.4	10.4	11.2	11.2	11.5	9.6
		MCWBR	6.0	6.1	6.1	6.1	6.1	5.4	4.2	4.3	5.9	5.6	6.8	6.2
Clear-Sky Solar Irradiance	taub		0.394	0.437	0.486	0.549	0.546	0.478	0.450	0.453	0.493	0.456	0.411	0.399
	taud		2.131	1.990	1.856	1.730	1.763	1.972	2.070	2.078	1.951	2.042	2.114	2.135
	Ebn at Noon		811	809	796	763	768	818	839	834	781	780	784	781
	Edh at Noon		128	162	198	233	227	183	166	162	178	152	129	122
All-Sky Solar Radiation	RadAvg		3.43	4.29	5.69	6.67	7.36	8.01	7.99	7.33	6.22	4.86	3.71	3.04
	RadStd		0.15	0.26	0.21	0.24	0.35	0.21	0.08	0.10	0.14	0.21	0.15	0.15

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page