

BALTIM, EgyptWMO: **623250**Lat: **31.5539N**Lon: **31.0844E**Elev: **2**StdP: **101.30**Time Zone: **2.00 (E02)**Period: **94-17**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.8	9.8	3.6	4.9	11.7	4.8	5.3	12.3	10.1	12.1	8.6	13.8	2.4	180	0.318

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.9	32.6	24.7	31.6	24.9	30.8	24.6	26.4	30.7	25.8	30.1	25.3	29.5	3.2	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	20.2	29.2	24.5	19.5	28.8	24.0	18.9	28.4	82.2	30.8	79.8	30.2	77.7	29.6	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	7.0	5.9	6.5	37.6	2.2	1.6	4.9	38.8	3.6	39.8	2.3	40.7	0.7	41.8		
(5)			5.4	27.4	1.8	1.3	4.2	28.4	3.1	29.1	2.1	29.9	0.8	30.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.3	14.5	15.0	16.7	19.2	22.1	25.3	27.2	27.9	26.5	23.8	20.3	16.4
	DBStd	5.05	1.83	2.11	2.26	2.29	2.14	1.74	1.12	1.06	1.32	1.74	2.16	2.04
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	363	119	97	61	14	1	0	0	0	0	0	7	65
	CDD10.0	4111	139	139	207	276	373	460	533	554	495	427	309	199
	CDD18.3	1433	1	2	9	39	116	210	275	296	245	168	66	6
	CDH23.3	11644	2	13	52	163	510	1608	2779	3256	2221	891	143	7
CDH26.7	3292	0	2	14	43	113	412	852	1114	593	136	13	0	
Wind	WSAvg	2.4	2.3	2.5	2.6	2.7	2.5	2.9	3.0	2.9	2.3	1.9	1.8	1.9
Precipitation	PrecAvg	161	42	38	14	4	1	0	0	0	0	7	20	37
	PrecMax	308	91	86	48	19	14	0	0	0	6	38	82	112
	PrecMin	37	5	7	0	0	0	0	0	0	0	0	0	0
	PrecStd	63	27	25	13	5	3	0	0	0	1	10	21	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.7	25.3	28.0	31.3	33.7	33.8	33.6	33.2	33.3	31.1	28.5	24.3
		MCWB	16.1	17.7	19.0	20.6	22.4	24.0	24.9	25.9	24.7	23.8	20.8	19.1
	2%	DB	20.2	21.6	24.1	27.2	29.5	31.4	31.7	32.1	31.4	29.2	26.0	22.1
		MCWB	15.3	15.8	17.2	19.2	20.8	23.5	25.2	25.8	24.7	22.8	20.3	17.2
	5%	DB	19.0	19.7	21.8	24.8	27.2	30.0	30.9	31.4	30.3	28.1	24.9	21.0
		MCWB	14.5	14.9	16.3	18.2	20.4	23.6	24.8	25.5	24.2	22.2	19.5	16.4
	10%	DB	18.0	18.5	20.2	23.0	25.8	28.8	30.1	30.7	29.5	27.2	23.8	20.0
		MCWB	13.9	14.3	15.7	17.6	20.1	23.0	24.6	25.2	23.7	21.7	18.8	15.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.3	18.4	19.9	21.4	22.9	25.6	26.8	27.2	26.5	25.0	22.3	20.0
		MCDB	20.8	23.9	26.9	29.4	31.1	30.7	31.3	31.5	30.8	29.1	25.9	23.2
	2%	WB	16.0	16.6	17.9	19.8	21.8	24.8	26.0	26.6	25.4	23.7	21.2	18.2
		MCDB	19.3	20.3	22.8	25.8	27.2	29.7	30.5	30.8	29.8	27.8	24.8	21.1
	5%	WB	15.1	15.5	16.9	18.8	21.1	24.1	25.5	26.1	24.8	22.9	20.2	17.0
		MCDB	18.2	18.8	20.6	23.6	26.1	28.8	29.8	30.3	29.1	26.9	23.9	20.1
	10%	WB	14.3	14.7	16.1	17.9	20.5	23.5	25.0	25.6	24.3	22.2	19.4	16.1
		MCDB	17.4	18.0	19.6	22.2	25.1	27.9	29.2	29.7	28.5	26.2	23.1	19.4
Mean Daily Temperature Range	5% DB	MDBR	6.9	6.8	6.9	7.2	7.1	6.5	5.9	5.9	6.2	6.5	6.7	6.8
		MCDBR	8.5	9.2	10.1	10.9	10.1	8.6	6.9	6.6	7.4	7.6	7.6	7.9
		MCWBR	4.7	4.7	4.7	4.7	3.7	3.2	2.6	2.4	2.9	3.2	3.5	4.3
	5% WB	MCDBR	8.1	8.2	8.7	9.7	8.5	7.6	6.5	6.3	6.9	7.3	7.0	7.3
		MCWBR	4.7	4.6	4.5	4.7	3.7	3.3	2.8	2.6	3.0	3.4	3.5	4.2
Clear-Sky Solar Irradiance	taub	0.395	0.436	0.467	0.506	0.500	0.431	0.426	0.435	0.435	0.436	0.401	0.389	
	taud	2.241	2.100	2.018	1.942	2.001	2.250	2.263	2.241	2.245	2.232	2.308	2.295	
	Ebn at Noon	810	808	813	797	804	858	860	849	835	801	800	795	
	Edh at Noon	114	144	168	188	179	139	136	138	132	125	106	104	
All-Sky Solar Radiation	RadAvg	3.06	3.84	5.20	6.37	7.31	7.85	7.61	6.91	5.93	4.55	3.38	2.77	
	RadStd	0.13	0.26	0.19	0.26	0.23	0.13	0.10	0.11	0.09	0.16	0.15	0.09	