

EL ARISH INTL, Egypt

WMO: 623370

Lat: 31.073N

Lon: 33.836E

Elev: 104

StdP: 14.64

Time Zone: 2.00 (E02)

Period: 95-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	42.4	44.3	28.1	22.1	58.4	31.9	26.4	59.0	23.0	57.2	20.6	57.2	4.5	160	0.334

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.7	95.2	71.1	92.3	73.3	90.2	74.4	79.4	87.6	78.2	86.9	77.2	86.2	7.4	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.2	142.1	83.9	75.5	134.1	83.2	74.5	129.6	82.7	43.1	87.8	41.8	87.1	40.8	85.8	91.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	14.4	12.2	36.6	106.4	2.8	4.2	34.6	109.3	32.9	111.8	31.3	114.1	29.3	117.1
			34.6	82.8	3.5	3.2	32.1	85.1	30.0	87.0	28.1	88.8	25.5	91.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.1	56.2	57.7	61.1	66.2	71.3	76.4	80.4	81.2	78.5	73.5	66.4	59.2		
	DBStd	9.57	3.86	4.35	5.43	5.63	4.54	3.37	2.19	2.05	2.73	3.53	4.30	3.53		
	HDD50	4	3	1	0	0	0	0	0	0	0	0	0	0		
	HDD65	897	276	211	150	44	2	0	0	0	0	0	32	182		
	CDD50	6963	194	216	345	485	660	793	942	967	854	728	493	286		
	CDD65	2379	2	6	30	79	197	343	477	502	404	263	74	2		
	CDH74	23873	28	77	362	792	1726	3342	5254	5676	4057	2040	474	45		
	CDH80	9334	3	20	159	352	568	1225	2308	2524	1541	535	94	5		
(14) Wind	WSAvg	4.9	5.8	6.2	5.9	5.7	5.0	4.6	4.3	3.9	4.2	4.1	4.5	4.9		
(15) Precipitation	PrecAvg	4.6	1.2	0.7	0.7	0.2	0.0	0.0	0.0	0.0	0.0	0.2	0.5	0.9		
	PrecMax	8.2	2.7	2.0	2.4	0.6	0.2	0.0	0.0	0.0	0.0	1.6	3.0	2.7		
	PrecMin	1.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	1.8	0.7	0.5	0.6	0.2	0.0	0.0	0.0	0.0	0.0	0.4	0.7	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.3	82.8	94.9	98.3	97.6	98.0	96.8	95.7	97.1	93.5	87.8	79.4		
		MCWB	57.8	60.3	62.8	64.6	65.6	70.2	73.8	77.4	71.5	69.6	63.3	58.4		
	2%	DB	71.6	75.2	83.8	90.0	90.1	91.5	93.1	92.7	91.3	87.5	82.2	73.8		
		MCWB	55.4	57.5	60.7	62.9	66.6	71.1	75.5	77.1	74.7	72.4	66.4	58.8		
	5%	DB	67.8	70.0	76.1	82.6	85.6	88.3	91.0	90.8	88.7	84.6	78.7	70.9		
		MCWB	56.4	56.2	60.0	61.9	66.6	72.5	75.7	76.9	75.0	71.8	65.2	58.4		
	10%	DB	65.2	66.7	71.2	76.9	82.2	86.1	89.2	89.4	86.8	82.7	76.2	68.5		
		MCWB	55.3	55.8	58.7	62.0	66.9	72.3	75.5	76.3	74.0	70.8	64.8	57.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.2	63.0	66.4	67.4	72.6	76.9	80.1	82.5	80.6	77.4	72.3	64.5		
		MCDB	68.7	74.4	79.0	82.1	83.3	86.1	88.3	89.8	87.3	84.4	78.6	71.2		
	2%	WB	59.6	60.3	63.7	65.7	70.8	75.5	78.7	80.0	77.9	75.4	69.9	62.1		
		MCDB	66.6	69.2	76.2	80.1	80.7	85.2	87.8	87.9	86.3	83.3	76.7	68.8		
	5%	WB	57.8	58.5	62.0	64.4	69.6	74.4	77.5	78.7	76.4	73.7	67.7	60.4		
		MCDB	65.3	66.5	71.6	76.6	79.6	84.0	86.9	87.2	85.5	81.6	74.9	67.5		
	10%	WB	56.1	57.0	60.5	63.2	68.5	73.4	76.6	77.6	75.2	72.2	66.0	58.9		
		MCDB	63.6	64.8	69.0	74.4	78.4	82.6	86.0	86.3	84.2	80.4	73.5	66.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	19.1	19.3	20.4	21.5	21.6	20.0	18.4	17.7	18.3	19.2	20.6	20.3		
		MCDBR	24.0	26.0	29.6	32.3	28.6	24.4	21.5	19.3	20.7	21.9	23.7	24.0		
		MCWBR	13.2	12.3	12.7	12.0	10.6	9.2	8.6	7.4	8.4	10.3	11.8	13.3		
	5% WB	MCDBR	21.4	22.2	23.9	25.4	22.7	20.9	19.5	18.2	18.9	20.1	20.2	21.3		
		MCWBR	13.4	12.0	11.7	11.3	10.6	9.0	8.5	7.6	8.6	10.3	11.3	13.3		
(40) Clear-Sky Solar Irradiance	taub		0.380	0.416	0.460	0.504	0.501	0.426	0.432	0.434	0.436	0.446	0.394	0.378		
	taud		2.169	2.052	1.933	1.840	1.879	2.125	2.124	2.125	2.114	2.070	2.192	2.195		
	Ebn at Noon		262	263	260	253	255	273	271	270	264	250	255	255		
	Edh at Noon		39	48	58	66	64	50	50	49	48	47	38	36		
(44) All-Sky Solar Radiation	RadAvg		1023	1297	1715	2058	2332	2531	2435	2240	1920	1491	1139	948		
	RadStd		46	66	77	73	83	38	37	39	46	57	42	42		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (15 neighbors)	+0.83	N/A	-3.74	N/A	N/A	N/A	N/A	-108	+256	+189

Nomenclature: See separate page