

TABA INTL, Egypt

WMO: 624560

Lat: 29.588N

Lon: 34.778E

Elev: 2457

StdP: 13.44

Time Zone: 2.00 (E02)

Period: 03-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.4	37.5	12.4	11.3	66.1	17.4	14.4	66.1	23.1	50.4	21.6	52.5	1.9	300	0.502

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.6	98.7	64.4	96.8	64.1	95.0	63.7	69.1	87.7	68.0	85.8	66.9	84.4	10.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.6	99.8	72.7	62.9	94.2	71.9	62.2	91.7	71.8	34.7	88.8	33.6	85.9	32.8	85.1	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.9	21.3	19.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB	28.0	73.9	2.7	2.3	26.1	75.5	24.5	76.8	23.0	78.1	21.0	79.8
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.4	50.5	53.3	59.4	66.5	73.4	78.3	81.2	81.2	76.9	71.4	62.0	53.6	(6)
	DBStd	11.99	4.96	5.65	7.34	6.78	5.50	3.95	3.16	2.82	3.23	4.93	5.78	5.11	(7)
	HDD50	100	50	25	5	0	0	0	0	0	0	0	0	20	(8)
	HDD65	1550	449	329	212	64	4	0	0	0	0	7	129	356	(9)
	CDD50	6450	66	118	296	495	727	850	968	968	807	664	361	130	(10)
	CDD65	2426	0	3	38	109	266	400	503	503	357	206	40	1	(11)
	CDH74	29097	4	46	548	1445	3283	5078	6381	6158	3696	1992	418	48	(12)
	CDH80	14560	0	6	169	564	1498	2726	3598	3414	1733	747	100	5	(13)
(14) Wind	WSAvg	8.9	5.8	7.1	8.8	9.2	9.8	11.6	11.3	11.6	11.6	8.5	6.1	5.6	(14)
(15) Precipitation	PrecAvg	0.8	0.2	0.1	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.2	0.1	0.1	(15)
	PrecMax	2.2	0.9	0.9	0.9	0.6	0.3	0.0	0.0	0.0	0.1	1.2	1.0	1.1	(16)
	PrecMin	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	0.5	0.2	0.2	0.2	0.1	0.1	0.0	0.0	0.0	0.0	0.3	0.2	0.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.8	79.2	90.0	94.7	98.3	101.9	101.9	100.6	97.2	95.1	86.4	80.3	(19)
		MCWB	53.5	56.5	57.0	61.2	62.3	62.5	67.0	67.6	65.6	63.8	59.3	55.2	(20)
	2%	DB	70.1	74.8	84.2	89.6	95.0	97.1	98.6	97.1	94.6	91.2	82.6	73.7	(21)
		MCWB	51.9	52.8	56.4	59.0	62.0	62.5	64.7	65.2	64.9	63.0	58.7	52.9	(22)
	5%	DB	66.0	71.2	80.2	86.2	91.5	94.9	96.6	95.3	91.5	87.7	78.8	69.7	(23)
		MCWB	49.7	51.5	54.7	57.3	61.3	62.0	64.7	64.6	64.3	62.4	57.8	51.1	(24)
	10%	DB	62.3	66.6	75.3	82.5	87.9	92.5	94.6	93.5	89.3	84.1	74.9	65.8	(25)
		MCWB	48.0	50.1	53.0	55.8	59.6	61.4	64.1	64.3	64.1	61.8	56.2	50.5	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.6	58.9	61.1	63.5	65.9	67.9	71.9	70.7	70.4	68.6	62.1	59.7	(27)
		MCDB	70.6	69.1	79.8	88.8	89.1	90.4	91.1	89.7	87.2	86.1	76.2	71.2	(28)
	2%	WB	53.1	55.4	58.2	60.8	64.1	65.7	68.8	68.9	68.2	66.2	60.6	55.4	(29)
		MCDB	67.5	71.6	79.0	85.6	88.7	86.6	88.5	87.7	83.7	80.6	76.5	70.4	(30)
	5%	WB	50.7	52.3	55.7	59.0	62.7	64.4	67.2	67.9	67.0	64.9	59.0	52.8	(31)
		MCDB	63.2	67.7	77.6	83.3	86.8	86.3	87.0	85.7	82.6	79.3	76.6	65.5	(32)
	10%	WB	48.6	50.4	53.5	57.2	61.1	63.4	66.0	66.8	66.0	63.6	57.2	51.0	(33)
		MCDB	59.5	64.8	72.7	78.3	84.0	85.9	85.8	84.1	81.6	78.2	72.3	62.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	21.6	22.8	24.5	26.3	27.1	27.8	26.6	26.0	25.3	24.2	22.5	22.7	(35)
		MCDBR	27.4	28.9	29.9	30.0	30.0	29.9	27.9	26.9	27.3	28.1	26.9	29.0	(36)
		MCWBR	15.2	14.0	12.7	12.3	10.8	9.7	8.8	7.8	7.8	9.8	11.4	14.3	(37)
	5% WB	MCDBR	23.7	26.1	28.2	29.0	28.4	28.3	27.1	26.0	25.9	24.8	24.7	24.6	(38)
		MCWBR	14.2	13.6	13.3	12.4	11.3	9.7	9.3	7.7	8.0	9.3	10.9	13.2	(39)
(40) Clear-Sky Solar Irradiance	taub		0.319	0.350	0.398	0.418	0.424	0.362	0.366	0.372	0.371	0.375	0.326	0.305	(40)
	taud		2.351	2.240	2.066	2.035	2.050	2.270	2.277	2.268	2.272	2.246	2.379	2.421	(41)
	Ebn at Noon		290	289	280	278	276	292	290	288	286	276	285	290	(42)
	Edh at Noon		33	40	51	55	54	43	43	43	41	39	32	29	(43)
(44) All-Sky Solar Radiation	RadAvg		1208	1508	1941	2265	2492	2698	2609	2423	2116	1695	1343	1138	(44)
	RadStd		48	57	65	51	80	29	38	31	46	49	39	33	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47)	Regional (13 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+243	+263

Nomenclature: See separate page