

TABATA INTL, Egypt

WMO: 624560

Lat: 29.588N

Lon: 34.778E

Elev: 749

StdP: 92.64

Time Zone: 2.00 (E02)

Period: 03-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.9	3.0	-10.9	1.6	18.9	-8.1	2.1	19.0	10.3	10.2	9.7	11.4	0.9	300	0.502

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.8	37.0	18.0	36.0	17.8	35.0	17.6	20.6	31.0	20.0	29.9	19.4	29.1	4.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	14.3	22.6	17.2	13.5	22.2	16.8	13.1	22.1	62.9	31.5	60.4	29.9	58.4	29.5	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
10.2	9.5	8.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB												
			WB	-2.2	23.3	1.5	1.3	-3.3	24.2	-4.2	24.9	-5.0	25.6	-6.1	26.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.7	10.3	11.9	15.2	19.2	23.0	25.7	27.4	27.3	24.9	21.9	16.7	12.0
	DBStd	6.66	2.76	3.14	4.08	3.77	3.06	2.20	1.75	1.57	1.79	2.74	3.21	2.84
	HDD10.0	56	28	14	3	0	0	0	0	0	0	0	0	11
	HDD18.3	861	249	183	118	36	2	0	0	0	0	4	72	198
	CDD10.0	3583	37	66	164	275	404	472	538	538	448	369	201	72
	CDD18.3	1348	0	2	21	61	148	222	279	279	198	114	22	1
	CDH23.3	16165	2	26	304	803	1824	2821	3545	3421	2053	1107	232	27
Wind	WSAvg	4.0	2.6	3.2	3.9	4.1	4.4	5.2	5.0	5.2	5.2	3.8	2.7	2.5
	PrecAvg	21	4	3	3	2	1	0	0	0	0	4	2	3
	PrecMax	56	23	23	24	15	8	0	0	0	3	30	26	28
	PrecMin	1	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	13	5	5	5	3	2	0	0	0	1	7	6	6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.2	26.2	32.2	34.8	36.8	38.8	38.8	38.1	36.2	35.1	30.2	26.8
		MCWB	11.9	13.6	13.9	16.2	16.8	17.0	19.5	19.8	18.7	17.7	15.1	12.9
	2%	DB	21.2	23.8	29.0	32.0	35.0	36.1	37.0	36.2	34.8	32.9	28.1	23.1
		MCWB	11.0	11.5	13.6	15.0	16.7	16.9	18.2	18.5	18.3	17.2	14.9	11.6
	5%	DB	18.9	21.8	26.8	30.1	33.0	35.0	35.9	35.2	33.0	30.9	26.0	20.9
		MCWB	9.8	10.8	12.6	14.1	16.3	16.7	18.2	18.1	18.0	16.9	14.3	10.6
	10%	DB	16.8	19.2	24.1	28.0	31.1	33.6	34.8	34.1	31.9	29.0	23.8	18.8
		MCWB	8.9	10.0	11.7	13.2	15.3	16.3	17.8	17.9	17.8	16.5	13.5	10.3
	0.4%	WB	13.7	15.0	16.1	17.5	18.8	20.0	22.2	21.5	21.3	20.3	16.7	15.4
		MCDB	21.4	20.6	26.5	31.6	31.7	32.4	32.8	32.1	30.7	30.0	24.6	21.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	11.7	13.0	14.5	16.0	17.8	18.7	20.5	20.5	20.1	19.0	15.9	13.0
		MCDB	19.7	22.0	26.1	29.8	31.5	30.3	31.4	30.9	28.7	27.0	24.7	21.3
	5%	WB	10.4	11.3	13.1	15.0	17.0	18.0	19.6	20.0	19.5	18.3	15.0	11.6
		MCDB	17.3	19.8	25.3	28.5	30.5	30.1	30.5	29.8	28.1	26.3	24.8	18.6
	10%	WB	9.2	10.2	11.9	14.0	16.2	17.4	18.9	19.3	18.9	17.6	14.0	10.6
		MCDB	15.3	18.2	22.6	25.7	28.9	30.0	29.9	29.0	27.5	25.7	22.4	17.1
Mean Daily Temperature Range	5% DB	MDBR	12.0	12.7	13.6	14.6	15.0	15.5	14.8	14.4	14.0	13.4	12.5	12.6
		MCDBR	15.2	16.1	16.6	16.7	16.7	16.6	15.5	15.0	15.2	15.6	15.0	16.1
		MCWBR	8.4	7.8	7.1	6.8	6.0	5.4	4.9	4.3	4.3	5.5	6.3	8.0
	5% WB	MCDBR	13.2	14.5	15.7	16.1	15.8	15.7	15.1	14.5	14.4	13.8	13.7	13.7
		MCWBR	7.9	7.5	7.4	6.9	6.3	5.4	5.2	4.3	4.4	5.2	6.0	7.4
Clear-Sky Solar Irradiance	taub		0.319	0.350	0.398	0.418	0.424	0.362	0.366	0.372	0.371	0.375	0.326	0.305
	taud		2.351	2.240	2.066	2.035	2.050	2.270	2.277	2.268	2.272	2.246	2.379	2.421
	Ebn at Noon		913	910	884	877	870	920	915	909	901	871	898	914
	Edh at Noon		103	127	161	172	171	136	135	135	129	124	100	92
All-Sky Solar Radiation	RadAvg		3.81	4.75	6.12	7.14	7.86	8.51	8.23	7.64	6.67	5.34	4.23	3.59
	RadStd		0.15	0.18	0.20	0.16	0.25	0.09	0.12	0.10	0.14	0.16	0.12	0.10

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+135	+146

Nomenclature: See separate page