

ABURDEES, Egypt

WMO: 624580

Lat: 28.9099N

Lon: 33.1955E

Elev: 25

StdP: 14.68

Time Zone: 2.00 (E02)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	46.8	49.2	24.4	18.6	60.5	28.2	22.2	60.8	20.5	67.4	18.4	64.9	1.3	40	0.401

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.1	98.5	68.7	95.3	70.1	93.3	70.7	77.3	88.5	76.4	88.1	75.7	87.8	7.8	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.5	124.6	86.6	72.4	120.2	86.3	71.5	116.2	86.1	40.8	88.7	40.0	88.1	39.3	88.0	89.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.9	18.9	17.6	40.9	108.3	3.5	3.1	38.4	110.5	36.3	112.3	34.4	114.0	31.8	116.3		
			35.4	81.2	1.9	4.1	34.0	84.1	32.8	86.5	31.8	88.8	30.3	91.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	74.4	59.5	61.8	67.3	73.0	79.2	83.7	86.0	86.9	83.9	78.0	70.4	62.9
	DBStd	10.34	3.94	4.72	5.37	5.47	4.79	3.49	2.61	2.38	2.92	3.65	4.35	4.00
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	418	178	114	31	1	0	0	0	0	0	0	5	89
	CDD50	8923	295	330	538	690	905	1010	1117	1143	1016	869	611	399
	CDD65	3866	7	24	103	241	440	560	652	678	566	404	167	24
	CDH74	45905	37	138	658	1841	4544	7117	9122	9794	7473	4121	976	84
	CDH80	20591	3	24	209	600	1741	3253	4735	5362	3383	1133	144	4
Wind	WSAvg	7.6	5.2	5.7	7.4	7.4	8.0	9.5	9.5	9.8	9.8	7.3	5.8	5.4
Precipitation	PrecAvg	0.6	0.2	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1
	PrecMax	2.1	1.3	0.2	0.6	0.4	0.6	0.0	0.1	0.0	0.0	0.4	1.0	0.5
	PrecMin	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	0.5	0.3	0.0	0.2	0.1	0.1	0.0	0.0	0.0	0.0	0.1	0.2	0.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.7	83.4	92.6	97.9	103.0	102.7	102.3	100.0	98.0	93.7	88.1	79.9
		MCWB	62.1	62.3	64.7	64.7	66.7	67.5	71.6	70.3	70.2	69.6	66.6	63.7
	2%	DB	73.3	78.0	85.9	91.2	96.2	96.7	95.6	96.0	93.1	88.8	83.5	76.3
		MCWB	59.5	61.5	63.1	62.9	65.8	69.1	71.3	72.2	70.9	71.4	67.4	61.3
	5%	DB	70.3	74.2	80.6	86.5	91.4	93.3	93.5	93.7	91.0	86.6	81.1	73.7
		MCWB	58.2	59.2	60.8	63.1	66.0	69.4	71.7	73.0	72.0	71.7	66.7	60.1
	10%	DB	68.2	71.2	76.7	82.6	87.8	90.8	91.7	92.1	89.4	85.0	79.1	71.7
		MCWB	56.5	58.4	60.0	62.5	66.1	69.6	72.0	73.2	72.6	71.5	65.6	58.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.1	67.4	69.2	69.3	71.9	75.3	77.7	78.9	77.8	77.1	72.3	67.1
		MCDB	73.8	78.7	83.5	83.5	86.2	88.1	89.2	89.9	88.3	86.4	81.2	77.0
	2%	WB	61.9	63.8	65.6	67.4	70.8	73.8	76.4	77.4	76.6	75.4	70.7	64.2
		MCDB	71.3	73.9	79.4	81.7	84.9	87.3	88.7	88.9	87.6	85.6	80.6	74.2
	5%	WB	59.3	61.3	63.6	66.0	69.7	72.9	75.5	76.7	75.8	74.2	68.9	61.7
		MCDB	69.0	71.8	77.1	80.1	83.7	86.8	88.0	88.5	87.1	84.5	79.5	72.2
	10%	WB	57.3	59.3	61.7	64.8	68.7	72.0	74.7	76.0	74.9	73.0	66.8	59.5
		MCDB	67.3	70.2	74.7	79.0	83.0	86.3	87.5	88.3	86.7	83.4	77.9	70.1
Mean Daily Temperature Range	5% DB	MDBR	16.2	16.4	16.0	16.3	15.4	14.0	12.3	11.1	10.8	12.3	15.5	16.4
		MCDBR	19.7	21.8	23.8	24.2	23.6	19.5	15.7	14.3	14.0	15.2	17.5	18.9
		MCWBR	13.9	13.8	12.5	10.8	9.2	9.0	8.5	8.5	9.4	10.9	12.4	13.4
	5% WB	MCDBR	18.9	18.3	19.5	17.5	16.2	15.2	13.0	11.2	10.9	12.7	16.1	18.4
		MCWBR	15.0	13.5	12.1	9.7	8.4	8.3	8.0	8.0	8.8	10.6	13.7	15.1
Clear-Sky Solar Irradiance	taub	0.372	0.410	0.463	0.528	0.541	0.448	0.450	0.446	0.451	0.458	0.390	0.368	
	taud	2.240	2.109	1.945	1.802	1.802	2.069	2.093	2.108	2.081	2.041	2.216	2.268	
	Ebn at Noon	270	269	261	249	245	268	267	267	262	250	261	266	
	Edh at Noon	37	46	58	69	69	53	51	50	50	49	38	35	
All-Sky Solar Radiation	RadAvg	1257	1561	1992	2316	2531	2699	2624	2444	2136	1725	1374	1173	
	RadStd	49	58	60	52	64	28	33	29	43	43	37	32	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)		+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+243	+263

Nomenclature: See separate page