

EL TOR, Egypt

WMO: 624590

Lat: 28.209N

Lon: 33.646E

Elev: 115

StdP: 14.63

Time Zone: 2.00 (E02)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	48.1	50.1	26.4	20.5	57.8	29.6	23.7	57.1	32.1	64.6	30.1	65.3	9.3	10	0.611

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.9	98.5	72.0	95.4	72.3	93.2	72.7	79.1	87.6	78.3	87.0	77.5	86.5	15.3	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.8	140.1	84.7	75.5	134.2	84.5	74.8	130.9	84.4	42.8	87.9	41.9	87.1	41.1	86.6	90.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
32.4	30.1	28.1	DB	43.5	106.0	2.5	2.8	41.7	108.0	40.2	109.6	38.8	111.2	37.0	113.2	
			WB	37.2	81.8	2.1	2.8	35.7	83.8	34.5	85.4	33.3	86.9	31.8	88.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	74.4	60.3	62.4	67.6	73.1	79.4	83.2	85.6	86.7	83.5	77.6	69.9	63.2	(6)
(7)		DBStd	9.86	3.46	4.07	4.80	4.62	4.02	3.43	2.75	2.51	2.86	3.44	3.72	3.44	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	352	152	92	24	2	0	0	0	0	0	0	5	77	(9)
(10)		CDD50	8919	319	349	546	693	911	995	1105	1138	1004	854	596	409	(10)
(11)		CDD65	3795	6	21	105	245	446	545	640	673	554	389	150	21	(11)
(12)		CDH74	40774	30	100	525	1492	3998	6121	8120	8998	6881	3623	808	78	(12)
(13)		CDH80	16786	1	10	125	432	1428	2557	3843	4579	2854	876	80	1	(13)
(14)	Wind	WSAvg	14.5	11.8	12.4	14.1	14.6	15.8	18.2	16.7	18.2	17.3	12.7	11.1	11.1	(14)
(15)	Precipitation	PrecAvg	0.3	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	(15)
(16)		PrecMax	1.2	0.7	0.3	0.7	0.4	0.1	0.0	0.0	0.0	0.0	0.5	1.2	0.5	(16)
(17)		PrecMin	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	0.3	0.1	0.0	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.5	81.6	88.5	93.7	99.8	102.1	102.4	102.3	97.4	91.8	85.4	79.0	(19)
(20)			MCWB	63.6	64.2	64.6	66.4	69.1	70.6	72.3	72.5	72.3	71.6	69.8	65.7	(20)
(21)		2%	DB	73.6	77.0	83.4	88.7	93.8	96.9	97.0	97.0	93.3	87.8	82.2	76.1	(21)
(22)			MCWB	61.9	62.4	63.8	65.6	68.5	70.6	72.7	74.1	72.8	72.9	69.2	63.3	(22)
(23)		5%	DB	71.1	73.8	79.4	84.7	90.3	93.0	94.0	94.2	90.7	85.7	80.2	73.9	(23)
(24)			MCWB	59.7	60.9	63.0	64.9	68.3	71.2	73.4	74.4	73.8	72.8	68.2	61.7	(24)
(25)		10%	DB	69.2	71.5	76.2	81.5	86.9	89.9	91.6	91.9	88.8	84.1	78.5	72.0	(25)
(26)			MCWB	57.8	59.5	62.2	64.2	68.1	71.5	73.8	74.9	74.5	72.6	67.0	60.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.3	68.5	70.2	71.2	75.4	77.3	79.3	81.0	79.8	78.3	73.6	69.1	(27)
(28)			MCDWB	73.9	77.0	79.9	81.8	87.4	87.3	88.4	88.9	87.5	84.6	81.2	76.6	(28)
(29)		2%	WB	63.9	65.2	67.3	69.5	73.3	75.8	78.2	79.4	78.5	76.9	71.8	65.6	(29)
(30)			MCDWB	71.5	73.6	77.6	80.9	84.3	86.2	87.6	88.1	86.4	83.8	80.2	74.2	(30)
(31)		5%	WB	61.0	62.9	65.4	68.2	71.9	74.8	77.3	78.7	77.5	75.6	70.0	63.2	(31)
(32)			MCDWB	70.0	71.7	75.6	78.9	82.9	85.4	86.8	87.5	85.9	82.8	78.6	72.7	(32)
(33)		10%	WB	58.6	60.7	63.8	67.0	71.0	73.9	76.6	77.9	76.8	74.5	68.0	60.9	(33)
(34)			MCDWB	68.1	70.2	74.0	77.5	81.9	84.7	86.2	87.1	85.6	82.1	77.2	71.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	16.9	16.1	15.1	15.2	15.2	15.1	14.2	12.9	11.2	12.7	15.9	17.2	(35)
(36)			MCDBR	19.3	19.7	20.6	21.6	21.9	20.7	18.2	16.6	14.8	14.2	17.3	18.7	(36)
(37)			MCWBR	14.6	14.6	13.1	11.0	9.4	8.0	7.2	7.4	8.9	10.8	13.4	14.6	(37)
(38)		5% WB	MCDWB	18.6	18.0	17.4	17.2	17.3	16.8	15.7	14.1	12.0	12.2	16.2	18.3	(38)
(39)			MCWBR	15.5	15.1	12.7	10.0	8.5	7.2	6.8	6.7	7.9	9.4	13.9	15.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.351	0.386	0.437	0.499	0.511	0.426	0.434	0.433	0.429	0.433	0.370	0.347	(40)	
(41)		taud	2.342	2.211	2.042	1.889	1.890	2.158	2.166	2.173	2.170	2.135	2.314	2.371	(41)	
(42)		Ebn at Noon	280	279	270	257	253	274	271	271	269	259	271	276	(42)	
(43)		Edh at Noon	34	42	53	63	64	49	48	47	46	45	35	32	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1308	1611	2032	2325	2521	2674	2597	2432	2143	1748	1407	1220	(44)	
(45)		RadStd	52	63	53	57	68	26	31	31	44	44	36	28	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.65	N/A	N/A	+1.82	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		+0.81	N/A	N/A	+0.86	+0.83	+0.81	N/A	N/A	+391	+356

Nomenclature: See separate page