

SHARM EL SHEIKH INTL, Egypt

WMO: 624639

Lat: 27.979N

Lon: 34.393E

Elev: 167

StdP: 14.61

Time Zone: 2.00 (E02)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	53.7	55.6	21.0	15.9	68.4	24.5	18.7	68.5	25.4	63.1	23.0	63.8	9.5	350	0.519

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.3	105.5	69.4	102.6	69.4	100.8	69.3	80.1	90.0	77.9	89.8	75.9	90.3	10.8	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.2	142.6	87.3	73.8	126.9	86.7	71.3	116.3	86.8	43.8	89.6	41.4	89.5	39.4	90.0	90.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.2	22.8	21.3	49.5	109.6	2.8	2.5	47.5	111.4	45.9	112.9	44.3	114.3	42.3	116.2
			39.8	80.9	2.0	3.6	38.4	83.4	37.2	85.5	36.0	87.5	34.6	90.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	79.8	64.7	67.2	72.3	78.4	85.2	90.2	92.2	92.6	88.7	82.8	75.0	67.8
	DBStd	10.62	4.02	4.66	5.12	4.83	4.89	3.72	2.87	2.68	2.90	4.05	4.42	3.88
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	98	54	25	4	0	0	0	0	0	0	0	0	15
	CDD50	10889	457	482	692	852	1090	1206	1309	1320	1162	1018	749	552
	CDD65	5512	45	87	231	402	625	756	844	855	712	553	300	102
	CDH74	71959	175	437	1526	3885	8275	11544	13365	13656	10420	6324	1999	353
	CDH80	41517	17	80	466	1563	4488	7304	8907	9197	6155	2753	544	43
(14) Wind	WSAvg	11.3	9.1	9.4	11.0	11.5	12.4	13.8	11.9	12.3	13.4	11.3	10.1	9.3
(15) Precipitation	PrecAvg	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0
	PrecMax	2.2	0.2	0.0	0.2	0.0	0.3	0.0	0.0	0.0	0.0	0.3	2.2	0.1
	PrecMin	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	0.5	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.5	0.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.4	86.2	93.2	98.7	105.8	109.1	107.4	107.5	103.6	100.1	91.8	84.3
		MCWB	60.0	59.7	61.2	64.3	68.3	67.2	69.1	70.7	70.6	67.6	65.2	63.7
	2%	DB	78.7	82.4	89.2	94.6	102.0	104.3	104.3	104.1	100.5	95.3	88.1	80.6
		MCWB	60.5	59.8	61.7	62.6	66.5	67.9	69.9	70.7	70.7	69.0	66.2	62.2
	5%	DB	75.3	79.0	84.6	91.2	98.4	102.1	102.3	102.2	98.4	93.1	85.8	77.3
		MCWB	59.9	59.2	60.9	62.6	65.7	67.7	69.9	70.7	70.4	69.0	66.2	61.0
	10%	DB	73.0	76.6	82.0	88.0	95.1	99.0	100.4	100.3	96.5	90.0	82.7	75.3
		MCWB	58.3	59.1	60.3	62.4	65.2	67.2	69.8	70.8	70.8	69.2	64.8	59.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.0	67.6	69.4	71.4	73.4	79.1	80.8	85.1	82.6	79.1	75.5	70.1
		MCDB	74.5	76.0	79.6	82.3	90.4	92.9	90.9	90.8	90.1	87.1	82.9	78.9
	2%	WB	63.7	64.8	66.3	69.0	71.0	75.0	78.3	80.0	79.7	75.7	71.4	66.1
		MCDB	73.8	75.2	79.6	82.4	89.6	89.6	90.0	91.0	88.5	86.4	80.3	75.2
	5%	WB	61.0	62.2	64.1	66.8	69.4	72.4	76.5	76.9	76.6	73.4	68.6	63.3
		MCDB	72.9	74.2	78.4	83.2	88.7	91.0	89.8	92.2	89.6	86.7	80.8	74.0
	10%	WB	59.0	60.1	62.4	65.0	67.9	70.5	74.6	75.0	74.2	71.6	66.6	61.0
		MCDB	71.3	74.0	78.3	82.7	89.0	91.2	91.0	92.0	90.4	85.7	80.4	73.3
(35) Mean Daily Temperature Range	5% DB	MDBR	14.7	15.7	15.8	17.0	17.9	18.3	17.1	16.3	15.6	14.4	14.3	14.5
		MCDBR	18.2	19.7	20.4	20.9	21.7	21.0	18.9	17.9	17.8	17.7	17.4	17.0
		MCWBR	11.7	12.1	11.7	10.3	8.7	7.6	8.2	8.0	8.1	9.7	10.8	11.3
	5% WB	MCDBR	17.0	16.7	17.2	17.6	18.8	18.3	17.0	16.0	14.9	14.2	14.9	15.2
		MCWBR	12.0	12.2	11.8	11.1	9.6	8.9	9.7	9.7	9.1	9.9	11.1	11.6
(40) Clear-Sky Solar Irradiance	taub		0.365	0.401	0.456	0.508	0.514	0.433	0.445	0.449	0.441	0.443	0.383	0.358
	taud		2.336	2.196	2.023	1.904	1.918	2.174	2.176	2.168	2.172	2.142	2.307	2.376
	Ebn at Noon		276	274	265	254	252	272	268	267	266	256	267	273
	Edh at Noon		34	43	54	63	62	48	48	48	46	45	35	32
(44) All-Sky Solar Radiation	RadAvg		1303	1604	2020	2293	2484	2632	2557	2399	2131	1736	1401	1220
	RadStd		56	69	53	56	79	30	35	39	48	50	42	25

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)		+0.85	N/A	N/A	+0.63	N/A	N/A	N/A	N/A	+391	+356

Nomenclature: See separate page