

SHARM EL SHEIKH INTL, Egypt

WMO: 624639

Lat: 27.979N

Lon: 34.393E

Elev: 51

StdP: 100.71

Time Zone: 2.00 (E02)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.1	13.1	-6.1	2.3	20.2	-4.2	2.7	20.3	11.4	17.3	10.3	17.7	4.3	350	0.519

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.1	40.8	20.8	39.2	20.8	38.2	20.7	26.7	32.2	25.5	32.1	24.4	32.4	4.8	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	20.4	30.7	23.2	18.1	30.4	21.9	16.6	30.4	84.1	32.0	78.4	32.0	73.8	32.2	32.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.8	10.2	9.5	DB	9.7	43.1	1.6	1.4	8.6	44.1	7.7	44.9	6.8	45.7	5.7	46.8
			WB	4.3	27.2	1.1	2.0	3.5	28.6	2.9	29.7	2.2	30.9	1.4	32.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.6	18.2	19.6	22.4	25.8	29.5	32.3	33.5	33.7	31.5	28.2	23.9	19.9	(6)
(7)		DBStd	5.90	2.23	2.59	2.84	2.68	2.72	2.07	1.59	1.49	1.61	2.25	2.45	2.16	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	54	30	14	2	0	0	0	0	0	0	0	0	8	(9)
(10)		CDD10.0	6049	254	268	384	473	606	670	727	733	646	566	416	307	(10)
(11)		CDD18.3	3062	25	48	128	223	347	420	469	475	396	307	167	57	(11)
(12)		CDH23.3	39977	97	243	848	2158	4597	6413	7425	7587	5789	3513	1111	196	(12)
(13)		CDH26.7	23065	9	44	259	868	2493	4058	4948	5109	3419	1529	302	24	(13)
(14)	Wind	WSAvg	5.0	4.1	4.2	4.9	5.1	5.6	6.2	5.3	5.5	6.0	5.0	4.5	4.2	(14)
(15)	Precipitation	PrecAvg	7	1	0	1	0	1	0	0	0	1	3	0	(15)	
(16)		PrecMax	55	6	0	6	1	7	0	0	1	8	55	3	(16)	
(17)		PrecMin	0	0	0	0	0	0	0	0	0	0	0	0	(17)	
(18)		PrecStd	12	1	0	1	0	2	0	0	0	2	12	1	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	28.0	30.1	34.0	37.1	41.0	42.8	41.9	41.9	39.8	37.8	33.2	29.0	(19)	
(20)		MCWB	15.5	15.4	16.2	18.0	20.2	19.6	20.6	21.5	21.4	19.8	18.4	17.6	(20)	
(21)		DB	26.0	28.0	31.8	34.8	38.9	40.1	40.1	40.0	38.0	35.2	31.2	27.0	(21)	
(22)		MCWB	15.8	15.4	16.5	17.0	19.2	19.9	21.1	21.5	21.5	20.5	19.0	16.8	(22)	
(23)		DB	24.0	26.1	29.2	32.9	36.9	38.9	39.1	39.0	36.9	33.9	29.9	25.2	(23)	
(24)		MCWB	15.5	15.1	16.1	17.0	18.7	19.8	21.0	21.5	21.3	20.6	19.0	16.1	(24)	
(25)		DB	22.8	24.8	27.8	31.1	35.1	37.2	38.0	38.0	35.8	32.2	28.2	24.1	(25)	
(26)		MCWB	14.6	15.1	15.7	16.9	18.5	19.6	21.0	21.5	21.5	20.6	18.2	15.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	20.0	19.8	20.8	21.9	23.0	26.1	27.1	29.5	28.1	26.2	24.1	21.2	(27)	
(28)		MDCB	23.6	24.4	26.4	27.9	32.4	33.8	32.7	32.7	32.3	30.6	28.3	26.0	(28)	
(29)		WB	17.6	18.2	19.1	20.6	21.7	23.9	25.7	26.7	26.5	24.3	21.9	18.9	(29)	
(30)		MDCB	23.2	24.0	26.5	28.0	32.0	32.0	32.2	32.8	31.4	30.2	26.9	24.0	(30)	
(31)		WB	16.1	16.8	17.8	19.3	20.8	22.5	24.7	25.0	24.8	23.0	20.4	17.4	(31)	
(32)		MDCB	22.7	23.4	25.8	28.4	31.5	32.8	32.1	33.4	32.0	30.4	27.1	23.4	(32)	
(33)		WB	15.0	15.6	16.9	18.3	20.0	21.4	23.7	23.9	23.5	22.0	19.2	16.1	(33)	
(34)		MDCB	21.8	23.4	25.7	28.1	31.7	32.9	32.8	33.3	32.4	29.8	26.9	23.0	(34)	
(35)	Mean Daily Temperature Range	MDBR	8.2	8.7	8.8	9.4	9.9	10.2	9.5	9.1	8.7	8.0	7.9	8.0	(35)	
(36)		5% DB	10.1	11.0	11.3	11.6	12.0	11.7	10.5	9.9	9.9	9.9	9.7	9.5	(36)	
(37)		MCWBR	6.5	6.7	6.5	5.7	4.8	4.2	4.6	4.4	4.5	5.4	6.0	6.3	(37)	
(38)		5% WB	9.4	9.3	9.6	9.8	10.5	10.1	9.4	8.9	8.3	7.9	8.3	8.4	(38)	
(39)		MCWBR	6.7	6.8	6.6	6.2	5.3	4.9	5.4	5.4	5.1	5.5	6.2	6.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.365	0.401	0.456	0.508	0.514	0.433	0.445	0.449	0.441	0.443	0.383	0.358	(40)	
(41)		taud	2.336	2.196	2.023	1.904	1.918	2.174	2.176	2.168	2.172	2.142	2.307	2.376	(41)	
(42)		Ebn at Noon	870	863	835	802	796	857	846	842	838	808	841	860	(42)	
(43)		Edh at Noon	108	135	170	198	195	150	150	150	145	141	111	100	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.11	5.06	6.37	7.23	7.83	8.30	8.06	7.56	6.72	5.47	4.42	3.85	(44)	
(45)		RadStd	0.18	0.22	0.17	0.18	0.25	0.10	0.11	0.12	0.15	0.16	0.13	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.47	N/A	N/A	+0.35	N/A	N/A	N/A	N/A	+217	+198

Nomenclature: See separate page