

EL DORET INTL, Kenya

WMO: 636880

Lat: 0.404N

Lon: 35.239E

Elev: 2150

StdP: 78.02

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.0	8.9	-0.9	4.5	24.0	1.0	5.3	22.3	7.8	19.3	6.5	19.5	3.2	100	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	13.9	27.1	13.2	26.2	13.4	25.9	13.5	17.2	21.9	16.8	21.6	16.4	21.2	5.5	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	14.8	18.7	15.2	14.1	17.8	15.0	13.9	17.6	57.9	21.5	56.0	21.6	54.7	21.4	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.3	7.3	DB	6.1	29.5	1.0	1.4	5.3	30.4	4.7	31.2	4.1	32.0	3.4	33.0	(4)
(5)			WB	4.8	19.9	1.1	1.9	4.0	21.3	3.3	22.4	2.7	23.4	1.9	24.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.6	17.6	18.3	18.8	18.5	17.8	17.1	16.5	16.6	17.0	17.7	17.4	17.3
	DBStd	1.21	1.06	1.24	1.20	1.02	0.92	0.92	0.90	0.85	0.91	0.93	0.91	1.03
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	357	27	14	9	9	21	39	57	55	41	23	29	34
	CDD10.0	2757	237	232	272	256	242	212	202	203	211	239	223	227
	CDD18.3	73	5	13	23	16	5	1	0	0	1	4	2	3
	CDH23.3	1342	193	303	363	152	73	22	5	7	54	67	32	70
CDH26.7	48	2	14	27	4	1	0	0	0	0	0	0	1	
Wind	WSAvg	3.2	3.8	4.0	3.9	3.2	2.7	2.3	2.3	2.6	3.4	3.6	3.8	
Precipitation	PrecAvg	742	29	25	55	111	80	58	69	77	41	70	81	45
	PrecMax	1118	172	110	147	281	177	134	119	123	104	150	238	129
	PrecMin	459	2	3	7	31	25	13	32	31	6	21	17	0
	PrecStd	150	35	27	38	62	36	28	22	24	23	32	53	36
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.9	28.0	28.2	27.2	26.0	25.1	24.0	24.1	25.4	25.9	25.1	26.0
		MCWB	12.9	13.0	13.4	13.6	14.8	14.2	14.9	14.8	14.4	14.3	14.1	13.0
	2%	DB	26.0	27.0	27.2	26.1	25.0	24.0	23.0	23.1	24.9	24.9	24.1	25.0
		MCWB	12.8	12.9	13.3	14.2	14.7	14.5	15.1	15.2	14.2	14.4	14.3	13.3
	5%	DB	25.1	26.1	26.8	25.1	24.1	23.0	22.1	22.2	24.0	24.1	23.2	24.1
		MCWB	13.0	12.9	13.4	14.4	14.8	15.1	15.1	15.2	14.2	14.4	14.6	13.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	24.5	25.2	25.7	24.1	23.1	22.0	21.2	21.2	23.0	23.1	22.4	23.1
		MCWB	13.2	13.1	13.8	14.8	15.2	15.2	15.0	15.2	14.7	14.7	14.7	13.8
	0.4%	WB	17.0	17.0	17.4	17.7	17.5	17.2	16.6	16.8	17.0	17.1	16.9	17.0
		MCDB	22.2	21.6	22.9	22.1	21.7	21.6	21.4	21.5	22.4	21.7	21.3	20.9
	2%	WB	16.1	16.1	16.6	17.0	16.9	16.4	16.1	16.1	16.2	16.2	16.1	16.0
		MCDB	21.0	21.3	22.0	21.8	21.4	21.0	20.8	21.1	21.5	21.2	20.7	20.3
Mean Daily Temperature Range	5%	WB	15.5	15.5	15.9	16.4	16.3	16.0	15.7	15.8	15.8	15.7	15.7	15.5
		MCDB	20.8	21.1	21.2	21.1	20.9	20.7	20.4	20.7	21.1	20.9	20.4	20.1
	10%	WB	14.8	14.9	15.4	16.0	15.9	15.6	15.4	15.5	15.4	15.3	15.3	15.0
		MCDB	20.6	20.9	20.8	20.5	20.5	20.1	20.0	20.2	20.6	20.7	20.1	19.8
	5% DB	MDBR	14.4	14.8	13.9	11.6	11.6	11.1	11.0	11.1	12.7	12.0	11.0	12.4
		MCDBR	16.0	16.2	16.1	13.7	13.4	12.7	12.0	12.3	14.5	13.3	12.5	14.3
MCWBR		6.3	5.8	5.6	5.0	5.5	5.6	5.7	5.9	6.2	5.2	4.8	5.4	
MCDBR		13.1	13.5	13.2	11.3	11.2	10.7	11.0	11.2	12.3	11.6	10.6	11.0	
Clear-Sky Solar Irradiance	taub	0.317	0.335	0.340	0.331	0.339	0.393	0.405	0.383	0.349	0.337	0.325	0.320	
		taud	2.567	2.501	2.509	2.580	2.548	2.356	2.300	2.366	2.466	2.508	2.570	2.568
	Ebn at Noon	1013	995	981	969	938	873	867	907	958	980	997	1005	
	Edh at Noon	104	113	112	102	101	120	128	124	115	111	103	103	
All-Sky Solar Radiation	RadAvg	6.32	6.63	6.50	5.98	5.82	5.38	5.18	5.44	6.12	6.00	5.71	5.98	
	RadStd	0.45	0.35	0.45	0.36	0.20	0.30	0.28	0.28	0.25	0.23	0.32	0.38	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page