

NAKURU, Kenya

WMO: 637140

Lat: 0.2710S

Lon: 36.1042E

Elev: 1901

StdP: 80.48

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	11.1	-0.8	4.5	26.4	1.3	5.2	25.4	8.5	20.4	7.7	20.9	0.2	270	0.326

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	14.5	29.1	13.8	28.2	13.9	27.4	14.1	17.9	23.1	17.5	22.6	17.2	22.2	5.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.4	14.8	19.2	16.1	14.4	18.8	15.7	14.1	18.5	59.1	23.1	57.5	22.7	56.3	22.4	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.6	7.4	5.9	DB	7.2	31.0	3.1	0.9	4.9	31.6	3.1	32.2	1.3	32.6	-0.9	33.3	(4)
(5)			WB	5.6	20.3	1.8	1.1	4.3	21.1	3.2	21.7	2.2	22.4	0.9	23.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.1	19.6	20.6	20.5	19.9	19.1	18.8	18.2	18.4	18.7	18.8	18.4	18.9	(6)	
	DBStd	1.39	1.22	1.27	1.43	1.30	0.96	1.02	1.03	1.03	1.11	1.17	1.10	1.18	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	78	3	1	1	2	3	7	14	12	8	8	12	7	(9)	
	CDD10.0	3339	298	296	326	297	282	263	256	259	262	274	251	277	(10)	
	CDD18.3	375	43	63	68	48	27	19	11	13	20	23	14	26	(11)	
	CDH23.3	2725	449	644	617	276	97	63	39	57	141	123	61	158	(12)	
(13)	CDH26.7	354	44	121	132	37	2	1	1	7	4	1	1	3	(13)	
(14)	Wind	WSAvg	1.6	2.0	2.3	2.0	1.3	1.2	1.3	1.4	1.4	1.4	1.3	1.8	(14)	
(15) Precipitation	PrecAvg	940	39	35	75	134	109	82	89	99	88	88	79	58	(15)	
	PrecMax	1412	158	151	195	392	255	164	175	202	222	194	214	191	(16)	
	PrecMin	615	7	2	1	32	40	21	7	31	24	27	9	0	(17)	
	PrecStd	183	33	37	43	78	49	37	43	40	46	41	44	52	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.8	30.0	30.2	29.3	26.8	26.2	25.8	26.1	27.5	27.1	26.1	27.1	(19)	
		MCWB	13.6	13.4	13.7	14.6	15.8	16.2	15.5	15.0	14.7	15.0	15.3	14.4	(20)	
	2%	DB	27.9	29.0	29.2	27.7	25.4	25.0	24.3	24.8	26.2	25.9	24.9	26.0	(21)	
		MCWB	13.5	13.5	13.9	15.1	16.1	16.1	15.7	15.6	15.2	15.4	15.5	14.5	(22)	
	5%	DB	27.0	28.2	28.2	26.3	24.5	24.0	23.4	23.8	25.0	24.8	23.9	25.1	(23)	
		MCWB	13.7	13.5	14.1	15.4	16.2	16.2	15.7	15.7	15.2	15.5	15.7	14.8	(24)	
	10%	DB	26.0	27.2	27.1	25.0	23.4	22.9	22.3	22.7	23.9	23.6	22.8	24.2	(25)	
		MCWB	13.9	13.7	14.4	15.8	16.2	16.1	15.5	15.5	15.4	15.5	15.7	14.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.3	17.9	17.6	18.2	18.4	18.2	17.6	17.5	17.6	17.8	17.7	17.7	(27)	
		MCDB	22.6	24.0	23.9	23.6	23.3	23.2	23.1	23.1	23.6	23.1	22.0	21.8	(28)	
	2%	WB	16.6	16.7	16.9	17.6	17.7	17.5	16.9	16.8	16.8	17.0	17.1	17.1	(29)	
		MCDB	21.8	22.2	23.2	22.6	22.7	22.7	22.3	22.5	22.8	22.1	21.4	21.4	(30)	
	5%	WB	16.0	15.9	16.4	17.2	17.2	17.0	16.4	16.3	16.3	16.5	16.7	16.6	(31)	
		MCDB	21.5	22.0	22.5	22.1	22.0	22.3	21.6	21.8	22.1	21.5	20.9	21.0	(32)	
	10%	WB	15.5	15.3	16.0	16.7	16.7	16.5	15.9	15.8	15.8	16.1	16.3	16.1	(33)	
		MCDB	21.4	22.2	21.9	21.5	21.2	21.4	20.9	21.0	21.4	20.8	20.3	20.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	14.5	13.6	11.2	10.1	10.0	10.0	10.7	12.0	11.0	9.8	11.4	(35)	
		MCDBR	15.7	15.9	15.8	13.6	11.7	11.3	11.3	11.9	13.7	12.8	11.7	13.1	(36)	
	5% WB	MCWBR	4.7	4.3	4.2	3.9	4.2	4.3	4.4	4.5	4.9	4.4	4.1	4.1	(37)	
		MCWBR	12.0	13.2	12.0	10.1	9.8	10.0	10.1	10.7	11.8	10.7	9.5	9.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.337	0.359	0.359	0.328	0.330	0.391	0.409	0.383	0.350	0.346	0.337	0.336	(40)	
		taud	2.521	2.439	2.469	2.615	2.601	2.376	2.300	2.374	2.469	2.490	2.547	2.542	(41)	
	Ebn at Noon		993	971	963	971	946	874	863	906	956	972	985	990	(42)	
		Edh at Noon	110	121	117	98	96	117	128	123	115	113	106	106	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.18	6.54	6.35	5.66	5.56	5.14	4.93	5.18	5.88	5.74	5.27	5.68	(44)	
	RadStd		0.49	0.38	0.48	0.38	0.22	0.31	0.37	0.30	0.26	0.29	0.34	0.42	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	+0.47	+0.69	N/A	+0.57	+0.39	+0.16	N/A	N/A	N/A	N/A

Nomenclature: See separate page