

KIGOMA, Tanzania, United Republic ofWMO: **638010**Lat: **4.883S**Lon: **29.633E**Elev: **2904**StdP: **13.22**Time Zone: **3.00 (E03)**Period: **02-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	60.8	62.3	49.7	58.7	80.9	51.6	63.2	80.0	22.6	80.3	21.1	81.1	0.3	90	0.245

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	19.4	88.8	68.4	87.7	68.9	86.4	69.5	75.6	83.2	75.0	82.6	74.4	82.0	12.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.5	139.0	80.3	72.6	134.8	79.4	71.9	131.5	78.6	41.6	83.4	40.8	82.9	40.1	81.9	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.2	18.0	14.6	DB	57.4	92.3	2.2	1.4	55.8	93.3	54.5	94.1	53.3	94.8	51.7	95.8	(4)
(5)			WB	54.5	80.1	1.7	2.1	53.3	81.6	52.3	82.8	51.3	83.9	50.1	85.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	75.4	75.3	75.8	75.6	75.6	75.9	74.1	73.4	75.4	77.2	76.9	74.7	74.5
	DBStd	2.10	1.59	1.87	2.02	1.88	1.63	1.60	1.68	1.72	1.83	2.20	2.19	1.61
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	9257	785	722	794	769	801	722	725	788	815	834	742	760
	CDD65	3782	320	302	329	319	336	272	260	323	365	369	292	295
	CDH74	25619	1751	1829	1985	1939	2301	2058	2134	2755	3251	2772	1484	1360
	CDH80	6847	323	441	486	466	623	491	511	924	1237	880	289	176
Wind	WSAvg	4.0	3.2	3.4	3.4	3.6	4.1	4.5	4.6	4.9	5.1	4.3	3.5	2.9
Precipitation	PrecAvg	38.5	5.1	4.6	5.0	6.6	2.1	0.2	0.1	0.2	0.7	2.6	5.8	5.6
	PrecMax	53.6	11.7	9.2	10.3	14.0	6.6	1.4	1.1	2.6	3.2	6.4	13.3	9.6
	PrecMin	28.3	1.5	1.3	1.4	2.3	0.0	0.0	0.0	0.0	0.0	0.1	1.1	2.1
	PrecStd	6.4	2.2	2.0	2.4	2.6	1.6	0.4	0.2	0.5	0.8	1.6	2.7	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.9	87.9	88.0	87.9	87.9	86.4	87.1	89.5	90.9	91.0	87.6	84.6
		MCWB	73.8	74.1	74.0	72.3	70.6	67.4	65.6	65.8	67.2	68.2	70.4	73.6
	2%	DB	84.4	85.8	86.0	85.7	86.1	85.6	85.0	87.5	88.7	88.2	84.6	83.2
		MCWB	73.6	73.9	74.3	72.4	70.4	67.6	66.4	66.5	67.6	68.8	72.6	73.2
	5%	DB	83.2	84.3	84.4	84.3	84.5	84.1	84.1	86.0	87.6	86.4	83.0	82.1
		MCWB	73.3	73.8	73.6	72.9	71.0	68.6	67.0	66.9	67.9	69.8	72.4	72.8
	10%	DB	82.1	82.8	82.9	82.8	83.6	82.7	82.7	84.5	86.2	85.0	81.3	80.6
		MCWB	72.9	73.4	73.1	72.7	71.0	68.4	67.2	67.2	68.3	70.5	72.1	72.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.8	76.5	76.4	75.6	75.0	74.3	73.5	73.7	74.7	75.5	75.3	75.5
		MCDB	82.8	83.7	84.6	83.1	82.6	81.8	82.0	82.1	83.4	83.6	82.5	82.6
	2%	WB	74.8	75.4	75.3	74.5	73.5	72.6	71.7	72.2	73.2	74.0	74.0	74.3
		MCDB	82.0	83.2	83.4	82.1	81.8	81.5	81.3	81.5	82.9	82.4	81.5	81.2
	5%	WB	74.1	74.6	74.4	73.7	72.7	71.4	70.5	71.1	72.2	73.1	73.2	73.4
		MCDB	81.2	82.3	82.3	81.4	81.0	80.7	80.0	80.8	82.1	81.6	80.7	80.1
	10%	WB	73.4	73.8	73.6	73.1	71.9	70.1	69.1	69.7	71.3	72.3	72.4	72.7
		MCDB	80.5	81.3	81.2	80.5	80.2	79.4	79.1	79.7	81.4	80.6	79.4	78.9
Mean Daily Temperature Range	5% DB	MDBR	13.7	14.7	15.0	14.8	17.1	19.9	21.5	21.0	19.4	15.9	13.2	12.9
		MCDBR	15.7	16.8	17.1	17.4	18.8	21.0	22.5	22.6	21.7	19.5	16.1	15.1
		MCWBR	7.3	7.7	7.7	7.1	6.8	8.2	9.2	9.4	8.9	7.6	7.2	7.0
	5% WB	MCDBR	14.7	15.7	16.4	15.7	17.0	18.6	19.9	19.5	18.0	15.7	14.6	14.2
		MCWBR	7.5	8.0	8.0	7.2	7.4	9.4	10.9	10.2	9.6	7.8	7.2	7.0
Clear-Sky Solar Irradiance	taub	0.463	0.438	0.403	0.361	0.380	0.407	0.450	0.488	0.470	0.448	0.405	0.428	
	taud	2.258	2.349	2.472	2.605	2.488	2.357	2.203	2.103	2.185	2.255	2.410	2.359	
	Ebn at Noon	279	285	292	297	282	269	259	256	269	279	293	287	
	Edh at Noon	46	42	37	31	33	37	44	51	48	46	39	41	
All-Sky Solar Radiation	RadAvg	1536	1654	1649	1624	1657	1707	1798	1840	1862	1697	1437	1447	
	RadStd	86	94	101	125	107	108	67	102	111	105	117	63	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page