

TABORA, Tanzania, United Republic of

WMO: 638320

Lat: 5.083S

Lon: 32.833E

Elev: 3904

StdP: 12.74

Time Zone: 3.00 (E03)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	57.5	59.3	42.5	46.2	79.4	44.5	50.0	77.4	21.0	72.5	19.6	72.0	2.6	90	0.300

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	21.3	91.6	65.5	90.7	65.6	89.6	65.7	72.6	82.3	71.7	81.6	71.0	81.0	8.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.1	128.1	75.6	69.2	124.3	74.7	68.3	120.4	74.0	39.1	83.1	38.2	81.3	37.6	81.2	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.4	17.9	15.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	48.7	78.1	1.2	3.1	47.9	80.3	47.2	82.1	46.5	83.8	45.7	86.0	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	75.0	74.5	74.8	74.6	74.0	73.6	72.6	72.3	75.1	77.8	79.0	77.3	74.7
	DBStd	2.91	2.37	2.40	2.14	1.44	1.41	1.94	2.06	1.61	1.83	2.09	3.02	2.92
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	9134	760	695	763	720	730	678	692	778	835	899	818	766
	CDD65	3659	295	275	298	270	265	228	227	313	385	434	368	301
	CDH74	30088	1902	1913	2066	1737	2142	2060	2087	2815	3851	4461	3169	1885
	CDH80	10711	563	639	656	423	622	619	631	1017	1659	1985	1302	595
(14) Wind	WSAvg	5.5	3.3	3.5	4.0	5.0	6.0	5.6	6.2	7.2	8.4	8.1	5.4	3.8
(15) Precipitation	PrecAvg	36.2	5.8	5.5	6.7	5.0	1.1	0.0	0.0	0.0	0.2	1.1	4.9	7.3
	PrecMax	54.7	12.2	12.7	18.4	19.2	4.6	0.5	0.2	0.6	1.6	5.6	17.0	15.6
	PrecMin	21.1	1.2	0.6	1.0	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.7	0.0
	PrecStd	8.0	2.6	2.5	3.3	3.1	1.2	0.1	0.0	0.1	0.4	1.3	3.4	3.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.9	89.7	89.3	87.9	87.8	88.1	88.1	89.8	92.9	93.3	93.0	91.3
		MCWB	67.0	69.1	69.3	69.1	66.1	64.6	64.6	64.3	63.4	65.1	65.4	66.8
	2%	DB	87.8	87.9	87.5	86.0	86.2	86.3	86.4	88.1	91.1	91.7	91.3	88.2
		MCWB	68.4	69.4	70.0	69.2	67.1	64.7	63.9	64.2	64.6	65.5	66.0	67.6
	5%	DB	85.9	86.2	86.0	84.3	85.2	85.3	85.7	87.4	89.7	90.9	89.6	86.1
		MCWB	69.2	69.8	69.8	69.7	67.0	64.6	63.5	64.1	64.6	65.5	66.5	68.2
	10%	DB	83.9	84.3	84.2	82.7	84.0	84.0	84.1	85.8	88.2	89.5	87.7	83.9
		MCWB	69.7	70.1	70.0	69.5	66.8	64.2	62.8	63.7	64.5	65.4	66.7	68.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.4	73.7	73.8	73.7	72.5	68.5	67.0	67.8	69.2	70.9	71.9	72.0
		MCDB	82.3	82.9	82.5	83.4	83.5	82.4	84.3	84.8	86.0	83.1	81.7	81.1
	2%	WB	72.0	72.3	71.7	71.7	69.4	66.9	65.6	66.4	67.4	69.4	70.4	70.9
		MCDB	81.2	82.2	82.2	81.0	81.4	81.8	83.2	83.6	84.8	82.9	81.0	80.2
	5%	WB	71.1	71.4	70.9	70.8	68.3	65.9	64.6	65.4	66.3	68.4	69.7	70.2
		MCDB	80.4	81.5	81.6	80.2	80.5	81.2	83.0	83.3	85.0	81.8	80.6	79.4
	10%	WB	70.3	70.6	70.2	70.0	67.5	65.0	63.6	64.4	65.3	67.5	69.0	69.6
		MCDB	79.6	80.5	81.0	79.6	79.7	80.6	81.8	83.1	84.7	81.5	79.5	78.6
(35) Mean Daily Temperature Range	5% DB	MDBR	17.5	18.5	18.8	18.6	22.1	24.5	24.9	22.9	22.7	21.3	19.4	16.9
		MCDBR	21.2	22.0	21.7	21.0	23.7	25.6	26.3	24.2	24.0	23.2	22.7	21.0
		MCWBR	7.0	7.2	7.7	7.9	8.9	9.1	9.7	8.6	8.2	7.4	7.0	6.3
	5% WB	MCDBR	18.2	18.9	19.4	18.5	21.7	24.4	25.1	22.8	22.6	20.6	18.3	17.0
		MCWBR	7.4	7.8	7.7	7.9	8.9	9.3	9.6	8.8	8.5	7.5	6.4	6.3
(40) Clear-Sky Solar Irradiance	taub		0.414	0.411	0.383	0.335	0.335	0.354	0.369	0.392	0.390	0.389	0.368	0.392
	taud		2.355	2.375	2.475	2.656	2.591	2.447	2.357	2.284	2.297	2.312	2.433	2.413
	Ebn at Noon		293	293	298	305	296	285	283	283	291	296	305	298
	Edh at Noon		42	41	37	30	30	34	38	42	43	43	38	39
(44) All-Sky Solar Radiation	RadAvg		1808	1938	1924	1855	1864	1882	1947	2034	2135	2092	1899	1745
	RadStd		147	124	92	96	82	56	48	55	76	104	106	124

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page