

TABORA, Tanzania, United Republic of

WMO: 638320

Lat: 5.083S

Lon: 32.833E

Elev: 1190

StdP: 87.82

Time Zone: 3.00 (E03)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	15.2	5.8	6.6	26.4	6.9	7.1	25.2	9.4	22.5	8.8	22.2	1.1	90	0.300

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	11.8	33.1	18.6	32.6	18.7	32.0	18.7	22.6	27.9	22.1	27.5	21.7	27.2	3.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.1	18.3	24.2	20.7	17.8	23.7	20.2	17.2	23.3	73.1	28.4	71.0	27.4	69.7	27.3	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 8.7	8.0	7.1	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			WB	9.3	25.6	0.6	1.7	8.8	26.8	8.4	27.8	8.1	28.8	7.6	30.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.9	23.6	23.8	23.7	23.3	23.1	22.6	22.4	23.9	25.5	26.1	25.2	23.7
	DBStd	1.62	1.32	1.34	1.19	0.80	0.78	1.08	1.14	0.90	1.01	1.16	1.68	1.62
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5074	422	386	424	400	406	377	384	432	464	499	454	426
	CDD18.3	2033	164	153	166	150	147	127	126	174	214	241	204	167
	CDH23.3	16716	1057	1063	1148	965	1190	1144	1159	1564	2139	2478	1761	1047
	CDH26.7	5951	313	355	364	235	346	344	351	565	922	1103	723	331
Wind	WSAvg	2.5	1.5	1.6	1.8	2.2	2.7	2.5	2.8	3.2	3.8	3.6	2.4	1.7
Precipitation	PrecAvg	919	147	140	171	126	29	1	0	1	5	27	125	186
	PrecMax	1389	310	323	467	487	117	13	5	14	41	141	432	396
	PrecMin	536	30	15	25	28	0	0	0	0	0	0	18	0
	PrecStd	203	67	64	85	80	30	3	1	3	9	33	86	80
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	32.0	31.8	31.1	31.0	31.1	31.2	32.1	33.8	34.1	33.9	32.9
		MCWB	19.5	20.6	20.7	20.6	18.9	18.1	18.1	17.9	17.5	18.4	18.6	19.3
	2%	DB	31.0	31.0	30.8	30.0	30.1	30.1	30.2	31.2	32.9	33.2	32.9	31.2
		MCWB	20.2	20.8	21.1	20.7	19.5	18.2	17.7	17.9	18.1	18.6	18.9	19.8
	5%	DB	29.9	30.1	30.0	29.1	29.6	29.6	29.8	30.8	32.1	32.7	32.0	30.1
		MCWB	20.7	21.0	21.0	20.9	19.4	18.1	17.5	17.8	18.1	18.6	19.2	20.1
	10%	DB	28.8	29.1	29.0	28.2	28.9	28.9	28.9	29.9	31.2	31.9	30.9	28.8
		MCWB	20.9	21.2	21.1	20.8	19.3	17.9	17.1	17.6	18.0	18.6	19.3	20.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.0	23.1	23.2	23.2	22.5	20.3	19.5	19.9	20.7	21.6	22.2	22.2
		MCDB	27.9	28.3	28.1	28.6	28.6	28.0	29.1	29.3	30.0	28.4	27.6	27.3
	2%	WB	22.2	22.4	22.0	22.1	20.8	19.4	18.7	19.1	19.6	20.8	21.3	21.6
		MCDB	27.3	27.9	27.9	27.2	27.4	27.7	28.5	28.7	29.3	28.3	27.2	26.8
	5%	WB	21.7	21.9	21.6	21.5	20.2	18.8	18.1	18.5	19.1	20.2	20.9	21.2
		MCDB	26.9	27.5	27.6	26.8	26.9	27.4	28.3	28.5	29.4	27.6	27.0	26.3
	10%	WB	21.3	21.5	21.2	21.1	19.7	18.3	17.5	18.0	18.5	19.7	20.5	20.9
		MCDB	26.4	27.0	27.2	26.4	26.5	27.0	27.7	28.4	29.3	27.5	26.4	25.9
Mean Daily Temperature Range	5% DB	MDBR	9.7	10.3	10.5	10.3	12.3	13.6	13.9	12.7	12.6	11.8	10.8	9.4
		MCDBR	11.8	12.2	12.1	11.7	13.2	14.2	14.6	13.4	13.3	12.9	12.6	11.6
		MCWBR	3.9	4.0	4.3	4.4	4.9	5.0	5.4	4.8	4.6	4.1	3.9	3.5
	5% WB	MCDBR	10.1	10.5	10.8	10.3	12.1	13.6	13.9	12.7	12.6	11.4	10.2	9.5
		MCWBR	4.1	4.3	4.3	4.4	5.0	5.2	5.3	4.9	4.7	4.2	3.5	3.5
Clear-Sky Solar Irradiance	taub		0.414	0.411	0.383	0.335	0.335	0.354	0.369	0.392	0.390	0.389	0.368	0.392
	taud		2.355	2.375	2.475	2.656	2.591	2.447	2.357	2.284	2.297	2.312	2.433	2.413
	Ebn at Noon		923	925	938	960	933	899	891	892	918	934	960	941
	Edh at Noon		131	130	116	93	95	107	119	133	136	136	121	123
All-Sky Solar Radiation	RadAvg		5.70	6.11	6.06	5.85	5.88	5.93	6.14	6.41	6.73	6.59	5.99	5.50
	RadStd		0.46	0.39	0.29	0.30	0.26	0.18	0.15	0.17	0.24	0.33	0.34	0.39

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page