

DODOMA, Tanzania, United Republic ofWMO: **638620**Lat: **6.170S**Lon: **35.753E**Elev: **3673**StdP: **12.85**Time Zone: **3.00 (E03)**Period: **02-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	57.6	59.0	43.5	47.7	78.8	45.8	52.1	76.7	25.0	71.6	23.2	71.7	4.1	90	0.405

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	20.8	90.0	66.3	89.3	66.3	87.9	66.4	71.9	82.0	71.1	81.1	70.5	80.4	9.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.3	123.8	75.3	68.3	119.4	74.3	67.9	117.7	73.9	38.3	82.5	37.5	81.2	36.9	80.4	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.8	21.0	19.2	DB	53.3	93.0	2.0	1.2	51.9	93.8	50.8	94.5	49.6	95.1	48.2	96.0	(4)
(5)			WB	50.0	76.9	2.0	2.8	48.5	78.9	47.3	80.5	46.2	82.1	44.7	84.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	74.0	76.1	76.2	75.5	74.2	72.5	70.4	69.2	70.7	72.8	75.7	77.4	76.9	(6)	
	DBStd	3.32	2.48	2.40	2.15	1.63	1.45	1.95	1.76	1.57	1.75	1.81	1.83	2.70	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD50	8742	810	732	790	726	698	613	595	642	684	795	823	834	(10)	
	CDD65	3267	345	312	325	276	233	163	130	177	234	330	373	369	(11)	
	CDH74	23193	2413	2231	2122	1579	1302	998	793	1127	1804	2777	3205	2842	(12)	
	CDH80	6610	768	732	611	308	166	101	51	141	459	991	1265	1017	(13)	
(14) Wind	WSAvg	9.7	5.6	6.2	6.7	8.8	10.5	9.9	10.7	12.1	13.1	13.3	11.6	7.8	(14)	
(15) Precipitation	PrecAvg	21.0	5.1	4.3	3.8	2.6	0.1	0.0	0.0	0.0	0.0	0.0	1.1	4.4	(15)	
	PrecMax	30.7	9.8	10.7	8.7	7.0	1.0	0.2	0.0	0.0	0.0	0.1	3.8	10.4	(16)	
	PrecMin	9.9	1.5	1.1	0.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	5.7	2.3	2.8	2.2	2.3	0.2	0.0	0.0	0.0	0.0	0.0	1.3	2.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.2	91.1	89.8	86.4	84.6	84.5	83.2	85.9	88.0	90.9	91.5	91.4	(19)	
		MCWB	66.7	67.8	69.2	68.1	66.1	65.1	63.2	63.6	63.7	64.5	66.1	66.2	(20)	
	2%	DB	88.8	88.4	87.6	84.5	83.1	82.4	81.1	82.8	86.0	88.5	89.8	89.6	(21)	
		MCWB	67.2	68.0	68.9	68.3	65.8	64.3	62.4	62.9	63.2	64.4	65.8	66.5	(22)	
	5%	DB	86.7	86.8	85.7	83.5	82.1	80.8	80.2	81.6	84.3	87.4	88.2	87.9	(23)	
		MCWB	67.9	68.5	68.7	68.3	65.7	63.4	62.0	62.6	63.0	64.6	65.6	66.6	(24)	
	10%	DB	84.4	84.7	83.9	82.1	80.6	79.4	78.6	80.3	82.7	85.7	87.2	86.0	(25)	
		MCWB	68.6	68.8	69.0	68.1	65.2	62.6	61.2	62.0	62.9	64.4	65.6	66.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.6	73.6	72.8	71.7	69.4	67.3	66.3	66.8	67.4	69.3	70.6	71.8	(27)	
		MCDB	82.8	84.3	84.6	81.4	79.8	80.6	79.1	79.3	82.4	84.0	82.2	80.1	(28)	
	2%	WB	71.5	72.0	71.3	70.4	68.4	65.7	64.1	65.2	65.7	67.7	69.1	70.5	(29)	
		MCDB	81.2	82.1	82.4	80.4	78.7	79.0	78.5	79.3	81.0	81.6	81.3	79.8	(30)	
	5%	WB	70.7	71.0	70.6	69.7	67.4	64.7	63.0	63.8	64.6	66.6	68.2	69.7	(31)	
		MCDB	80.2	80.9	81.1	79.5	77.5	77.8	76.9	78.1	79.9	80.3	80.0	79.5	(32)	
	10%	WB	70.0	70.1	69.8	69.0	66.6	63.8	62.2	62.9	63.7	65.8	67.4	69.1	(33)	
		MCDB	79.3	79.8	80.0	78.3	76.4	76.1	75.3	76.8	78.6	79.3	79.2	78.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	17.0	18.2	17.5	16.8	17.9	20.3	20.6	20.8	22.1	21.9	20.8	18.1	(35)	
		MCDBR	20.2	20.7	19.9	18.5	19.6	21.1	21.7	22.2	23.4	23.4	22.3	20.9	(36)	
	5% WB	MCWBR	5.3	5.8	5.5	5.3	5.7	6.6	6.9	6.4	6.1	5.5	4.9	4.5	(37)	
		MCWBR	16.7	18.0	17.5	16.7	17.2	20.0	20.4	20.8	21.9	21.3	20.1	17.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.401	0.404	0.374	0.328	0.327	0.331	0.348	0.366	0.362	0.361	0.349	0.371	(40)	
		taud	2.385	2.382	2.481	2.687	2.608	2.515	2.409	2.338	2.351	2.362	2.460	2.461	(41)	
	Ebn at Noon		297	295	300	306	298	292	288	290	299	305	311	305	(42)	
		Edh at Noon	41	41	36	29	30	31	36	40	41	41	37	37	(43)	
(44) All-Sky Solar Radiation	RadAvg		1920	1998	1921	1751	1649	1731	1807	1935	2169	2199	2092	1947	(44)	
	RadStd		157	116	97	85	103	63	81	68	74	73	107	118	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page