

VICTORIA-SEYCHELLES, Seychelles

WMO: 639800

Lat: 4.674S

Lon: 55.522E

Elev: 3

StdP: 101.29

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	23.8	24.0	19.8	14.5	26.4	20.2	14.9	26.4	11.6	26.4	10.6	26.5	3.0	150	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	5.3	32.1	26.4	31.7	26.3	31.2	26.2	27.3	30.6	27.1	30.5	26.7	30.1	4.3	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	21.7	29.6	26.1	21.5	29.5	25.9	21.2	29.3	86.6	31.2	85.5	30.6	84.1	30.2	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.9	8.1	21.7	33.0	1.7	0.7	20.5	33.6	19.6	34.0	18.6	34.4	17.4	34.9		
(5)			19.9	28.2	1.5	0.6	18.8	28.6	17.9	29.0	17.1	29.3	15.9	29.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.7	27.4	28.0	28.5	28.8	28.6	27.5	26.7	26.7	27.2	27.6	27.6	27.6		
	DBStd	1.05	0.91	0.94	0.90	0.83	0.80	0.84	0.66	0.66	0.81	0.80	0.82	0.82		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6453	538	504	572	564	577	525	517	519	516	546	528	546		
	CDD18.3	3412	280	271	314	314	318	275	259	261	266	288	278	287		
	CDH23.3	36201	2881	3041	3697	3788	3771	2821	2306	2307	2612	3015	2945	3018		
	CDH26.7	10094	749	965	1344	1481	1356	624	312	318	498	765	825	856		
(14) Wind	WSAvg	3.9	3.0	3.2	2.7	2.4	3.8	5.1	5.4	6.1	5.8	3.9	2.8	2.9		
(15) Precipitation	PrecAvg	2321	407	268	196	187	148	77	72	89	153	191	210	291		
	PrecMax	3447	872	611	520	463	559	326	277	280	457	565	441	607		
	PrecMin	1656	60	9	55	37	7	10	18	1	11	9	31	58		
	PrecStd	407	168	149	94	81	125	59	50	69	110	123	105	125		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.2	31.9	32.3	33.0	32.1	31.0	29.9	29.9	30.6	31.2	31.5	31.8		
		MCWB	26.3	26.5	26.4	26.7	26.6	26.1	24.5	25.0	25.5	25.3	25.2	25.3		
	2%	DB	30.6	31.1	31.9	32.1	31.5	30.2	29.1	29.2	30.0	30.4	31.0	31.1		
		MCWB	26.2	26.5	26.5	26.5	26.4	25.6	24.6	24.5	25.3	25.3	25.4	25.7		
	5%	DB	30.1	30.8	31.2	31.8	31.1	29.8	28.8	28.9	29.4	30.1	30.2	30.5		
		MCWB	25.9	26.3	26.4	26.5	26.4	25.4	24.5	24.4	25.0	25.3	25.4	25.7		
	10%	DB	29.6	30.1	30.9	31.1	30.8	29.1	28.1	28.2	29.0	29.7	29.9	30.0		
		MCWB	25.7	25.9	26.3	26.5	26.3	25.0	24.2	24.1	24.8	25.2	25.4	25.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.1	27.4	27.6	27.9	27.7	26.9	26.1	26.0	26.5	26.7	27.0	26.8		
		MCDB	30.1	30.5	30.9	31.2	30.7	29.9	28.2	28.3	29.1	29.5	30.2	30.0		
	2%	WB	26.6	26.9	27.1	27.3	27.2	26.3	25.6	25.5	26.0	26.2	26.4	26.5		
		MCDB	29.5	30.3	30.7	30.8	30.4	29.0	27.9	27.8	28.7	29.1	29.5	29.6		
	5%	WB	26.2	26.6	26.7	27.0	26.8	26.0	25.2	25.1	25.6	25.9	26.1	26.1		
		MCDB	29.1	29.8	30.2	30.6	30.0	28.5	27.5	27.5	28.3	28.9	29.1	29.3		
	10%	WB	26.0	26.2	26.5	26.7	26.5	25.6	24.8	24.8	25.3	25.6	25.7	25.8		
		MCDB	28.8	29.4	29.9	30.1	29.6	28.2	27.3	27.2	27.9	28.5	28.8	28.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.6	4.6	5.0	5.3	4.4	3.7	3.6	3.7	3.8	4.4	4.9	5.1		
		MCDBR	5.0	4.9	5.4	5.7	4.8	4.1	4.0	4.0	4.2	4.7	5.3	5.5		
	5% WB	MCWBR	2.5	2.4	2.5	2.5	2.4	2.2	2.2	2.1	2.2	2.4	2.5	2.5		
		MCWBR	4.7	4.8	5.1	5.3	4.6	3.8	3.6	3.7	4.0	4.5	4.9	5.2		
(40) Clear-Sky Solar Irradiance	taub	taub	0.399	0.409	0.396	0.374	0.388	0.433	0.427	0.426	0.433	0.407	0.385	0.387		
		taud	2.587	2.540	2.600	2.679	2.614	2.436	2.440	2.453	2.443	2.539	2.618	2.625		
	Ebn at Noon	Ebn at Noon	938	927	926	923	884	827	839	863	879	917	944	946		
		Edh at Noon	104	110	102	91	93	109	110	113	118	109	100	100		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	5.59	6.25	6.33	6.20	5.62	5.19	5.35	5.75	5.95	6.38	6.43	5.93		
	RadStd	RadStd	0.36	0.35	0.28	0.33	0.33	0.35	0.32	0.37	0.38	0.51	0.31	0.33		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page