

KINSHASA N'DJILI INTL, Congo, the Democratic Republic of the

WMO: 642100

Lat: 4.386S

Lon: 15.445E

Elev: 313

StdP: 97.62

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	19.8	15.4	11.3	23.2	16.0	11.8	23.5	6.8	25.2	6.2	25.3	1.3	180	0.296

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	9.0	34.1	25.1	33.5	24.9	32.9	24.8	26.2	31.6	25.9	31.1	25.6	30.7	3.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.9	20.8	28.7	24.2	19.9	28.1	24.1	19.8	28.0	83.8	31.9	81.8	31.9	80.3	30.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.5	5.5	5.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			15.0	27.8	1.7	0.9	13.8	28.4	12.9	28.9	11.9	29.4	10.7	30.1	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.4	26.9	27.3	27.7	27.7	27.0	24.9	24.1	24.9	26.3	26.8	26.7	26.6	(6)	(7)
	DBStd	1.76	1.27	1.62	1.31	1.26	1.24	1.38	1.26	1.40	1.37	1.47	1.37	1.31	(7)	(8)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	(9)
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	(10)
	CDD10.0	5988	524	485	550	530	528	447	438	461	488	522	502	514	(10)	(11)
	CDD18.3	2947	266	252	292	280	269	197	179	202	238	264	252	256	(11)	(12)
	CDH23.3	24941	2383	2401	2833	2590	2320	1283	1034	1463	2077	2353	2097	2106	(12)	(13)
	CDH26.7	8602	812	927	1157	1034	805	307	224	423	713	829	709	662	(13)	(14)
(14) Wind	WSAvg	2.4	2.0	2.2	2.3	2.2	2.1	2.3	2.5	2.9	2.9	2.5	2.3	2.1	(14)	(15)
(15) Precipitation	PrecAvg	1486	156	141	173	211	142	6	1	8	32	154	269	200	(15)	(16)
	PrecMax	1924	343	305	306	467	394	47	8	52	74	290	461	369	(16)	(17)
	PrecMin	1087	27	28	60	101	12	1	0	0	7	68	141	83	(17)	(18)
	PrecStd	228	70	69	61	84	69	11	2	16	17	61	75	75	(18)	(19)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.8	34.9	35.1	35.0	34.1	32.1	31.0	32.1	33.9	34.2	33.2	33.1	(19)	(20)
		MCWB	25.3	25.2	25.2	25.6	25.4	23.5	22.9	22.5	23.5	24.4	24.6	24.7	(20)	(21)
	2%	DB	32.8	33.2	34.0	33.9	33.0	30.8	29.9	31.1	32.5	33.0	32.2	32.1	(21)	(22)
		MCWB	25.0	25.1	25.2	25.4	25.3	23.7	22.3	22.2	23.2	24.1	24.4	24.6	(22)	(23)
	5%	DB	31.8	32.7	33.0	33.0	31.9	29.8	29.0	30.1	31.6	32.0	31.6	31.1	(23)	(24)
		MCWB	24.7	24.9	25.0	25.3	24.9	23.3	22.0	21.9	23.0	23.9	24.3	24.5	(24)	(25)
	10%	DB	30.8	31.5	32.0	31.9	30.8	28.4	28.0	29.1	30.4	30.9	30.5	30.1	(25)	(26)
		MCWB	24.5	24.6	24.8	25.0	24.7	22.8	21.7	21.6	22.8	23.8	24.3	24.5	(26)	(27)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.2	26.5	26.6	26.5	26.4	25.2	23.9	23.6	24.7	25.5	25.8	25.9	(27)	(28)
		MCDB	31.2	32.0	32.6	32.5	31.6	29.2	29.1	30.1	30.7	31.5	30.7	30.4	(28)	(29)
	2%	WB	25.7	25.9	26.0	26.0	25.8	24.3	23.0	22.9	24.1	24.9	25.3	25.4	(29)	(30)
		MCDB	30.4	31.0	31.8	31.9	30.8	28.8	28.4	29.7	30.7	30.6	30.2	29.9	(30)	(31)
	5%	WB	25.3	25.5	25.6	25.7	25.4	23.8	22.5	22.3	23.5	24.5	24.9	25.1	(31)	(32)
		MCDB	29.7	30.4	31.0	31.2	30.2	28.2	27.5	28.7	29.9	30.0	29.7	29.5	(32)	(33)
	10%	WB	24.9	25.1	25.2	25.2	25.0	23.2	22.0	21.8	23.1	24.1	24.5	24.7	(33)	(34)
		MCDB	29.1	29.8	30.3	30.5	29.6	27.2	26.7	27.8	29.2	29.4	29.1	28.8	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.8	8.4	9.0	9.2	8.1	7.5	7.7	8.5	8.3	8.2	7.9	7.5	(35)	(36)
		MCDBR	9.3	9.8	10.4	10.3	9.6	9.0	9.4	10.2	10.2	9.8	9.4	8.9	(36)	(37)
	5% WB	MCWBR	3.3	3.4	3.7	3.7	3.7	3.7	3.9	3.9	3.6	3.3	3.2	3.3	(37)	(38)
		MCWBR	8.2	9.0	9.5	9.7	8.8	8.1	8.4	9.3	9.1	9.0	8.7	8.1	(38)	(39)
(40) Clear-Sky Solar Irradiance	taub		0.567	0.558	0.517	0.447	0.562	0.671	0.743	0.773	0.660	0.505	0.462	0.541	(40)	(41)
		taud	1.961	1.999	2.129	2.342	1.972	1.687	1.545	1.500	1.739	2.144	2.272	2.038	(41)	(42)
	Ebn at Noon		787	798	821	856	732	634	595	602	701	831	871	803	(42)	(43)
		Edh at Noon	195	189	164	128	177	230	269	293	238	161	142	179	(43)	(44)
(44) All-Sky Solar Radiation	RadAvg		4.77	4.77	5.09	4.95	4.41	3.98	4.15	4.25	4.38	4.29	4.58	4.45	(44)	(45)
	RadStd		0.20	0.22	0.26	0.26	0.21	0.20	0.18	0.31	0.18	0.20	0.18	0.21	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page