

BRAZZAVILLE MAYA MAYA INTL, CongoWMO: **644500**Lat: **4.252S**Lon: **15.253E**Elev: **1048**StdP: **14.15**Time Zone: **1.00 (E01)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	64.6	66.2	60.7	82.5	73.2	62.2	87.0	73.8	12.3	77.3	11.8	77.3	2.9	260	0.268

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	16.8	93.6	76.3	92.7	76.3	91.4	76.2	78.9	88.1	78.3	87.3	77.9	86.8	5.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.8	145.4	82.6	75.6	139.4	81.7	75.4	138.4	81.5	43.4	88.7	42.7	88.0	42.2	87.3	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.0	11.3	9.8	61.7	96.9	1.8	1.2	60.5	97.7	59.4	98.4	58.4	99.1	57.1	99.9		
(5)			60.5	80.9	1.2	2.0	59.7	82.4	58.9	83.5	58.3	84.7	57.4	86.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	79.2	80.2	80.7	81.6	81.7	80.4	76.2	74.6	76.3	79.2	79.9	79.9	79.5
	DBStd	3.27	2.26	2.77	2.45	2.29	2.22	2.44	2.37	2.64	2.52	2.61	2.43	2.33
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10652	937	860	979	951	943	787	762	816	876	928	897	916
	CDD65	5177	472	440	514	501	478	337	297	351	426	463	447	451
	CDH74	42076	4079	3978	4817	4589	4018	2020	1606	2389	3564	3948	3567	3501
	CDH80	14967	1435	1538	1995	1883	1444	486	350	706	1285	1438	1273	1134
(14) Wind	WSAvg	4.4	3.9	4.2	4.1	4.0	4.0	4.3	4.8	5.6	5.7	4.7	4.1	3.8
(15) Precipitation	PrecAvg	54.5	6.2	5.2	6.9	7.4	4.9	0.3	0.1	0.2	1.4	5.5	10.1	7.6
	PrecMax	76.0	12.8	15.4	13.9	16.4	15.1	2.4	1.1	1.7	4.0	14.1	19.3	14.1
	PrecMin	35.6	1.1	0.6	0.2	1.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.8
	PrecStd	9.9	2.6	2.8	3.2	3.3	2.7	0.6	0.2	0.4	1.0	2.6	3.7	3.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.2	94.8	95.4	95.2	93.5	89.8	88.1	91.0	93.5	93.6	93.0	91.8
		MCWB	76.6	76.7	76.0	76.7	76.7	73.2	72.6	72.8	74.0	75.1	75.7	76.2
	2%	DB	91.1	91.8	93.3	93.1	91.4	87.4	85.9	88.2	91.4	91.5	91.1	89.8
		MCWB	76.6	76.8	76.8	77.0	77.0	73.8	72.1	72.2	74.0	75.1	75.8	76.2
	5%	DB	89.3	90.0	91.4	91.3	89.5	84.6	84.0	86.3	89.4	89.6	89.4	88.0
		MCWB	76.3	76.7	76.8	77.0	76.7	73.6	71.5	71.7	73.4	74.9	75.8	76.1
	10%	DB	87.5	88.1	89.5	89.4	87.5	82.7	82.0	84.2	87.4	87.6	87.4	86.2
		MCWB	76.1	76.4	76.5	76.6	76.5	73.1	71.0	71.0	73.2	74.8	75.6	76.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.9	79.2	79.5	79.3	79.2	76.9	74.5	74.5	75.8	77.6	78.2	78.3
		MCDB	87.5	88.6	89.6	88.9	87.6	84.2	84.4	86.9	88.6	87.7	87.1	86.6
	2%	WB	78.0	78.3	78.5	78.5	78.3	75.6	73.1	73.2	74.8	76.5	77.3	77.6
		MCDB	86.5	87.4	88.3	88.1	86.6	82.9	82.6	86.0	87.3	86.7	86.4	85.8
	5%	WB	77.3	77.8	77.8	77.9	77.7	74.8	72.1	72.2	74.1	75.9	76.6	77.0
		MCDB	85.7	86.6	87.3	87.3	85.9	81.8	80.9	83.7	86.2	85.7	85.4	85.2
	10%	WB	76.7	77.1	77.1	77.3	77.0	73.8	71.4	71.4	73.4	75.3	76.1	76.4
		MCDB	84.7	85.7	86.3	86.4	85.1	80.4	79.6	82.0	85.2	84.7	84.4	83.9
(35) Mean Daily Temperature Range	5% DB	MDBR	14.6	15.7	16.8	16.8	15.2	14.4	15.1	15.6	16.0	15.6	15.2	14.0
		MCDBR	17.4	18.3	19.4	19.3	18.1	17.3	18.5	19.7	20.0	19.0	18.1	16.8
	5% WB	MCWBR	5.9	6.0	6.1	6.1	6.1	6.2	6.9	6.8	6.3	5.9	5.8	5.9
		MCWBR	15.6	17.0	17.7	17.6	16.3	14.9	16.4	17.6	17.7	17.0	16.4	15.2
(40) Clear-Sky Solar Irradiance	taub		0.557	0.547	0.510	0.443	0.550	0.651	0.719	0.747	0.639	0.495	0.457	0.535
		taud	1.989	2.030	2.151	2.358	2.008	1.729	1.587	1.545	1.786	2.169	2.288	2.059
	Ebn at Noon		252	256	262	273	235	206	194	196	227	266	278	257
		Edh at Noon	60	58	51	40	54	70	82	89	72	50	44	56
(44) All-Sky Solar Radiation	RadAvg		1505	1506	1610	1563	1382	1248	1295	1325	1362	1341	1439	1395
	RadStd		68	69	84	80	66	66	57	98	59	61	56	69

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page