

BANGUI M'POKO INTL, Central African RepublicWMO: **646500**Lat: **4.398N**Lon: **18.519E**Elev: **368**StdP: **96.98**Time Zone: **1.00 (E01)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.9	17.1	3.8	5.2	32.5	7.0	6.5	30.6	6.3	25.3	5.4	25.7	0.7	320	0.253

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	11.2	36.2	23.0	35.5	23.1	34.9	23.3	26.9	31.5	26.3	31.2	25.9	30.9	2.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	22.3	29.0	25.1	21.2	28.2	24.9	20.9	28.0	87.1	32.1	84.5	31.4	82.8	31.2	31.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.6	4.7	4.1	13.8	38.5	1.3	0.7	12.9	39.0	12.1	39.4	11.4	39.8	10.4	40.3
			12.2	29.3	1.8	1.7	10.9	30.5	9.9	31.5	8.9	32.5	7.6	33.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.7	26.2	28.2	28.4	27.7	27.3	26.5	25.8	25.9	26.2	26.2	26.5	26.2
	DBStd	1.70	1.79	1.55	1.69	1.56	1.67	1.43	1.41	1.31	1.25	1.30	1.25	1.33
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6109	502	508	569	532	536	494	489	492	487	503	496	502
	CDD18.3	3068	244	275	311	282	277	244	231	233	237	245	246	244
	CDH23.3	26991	2553	3020	3270	2762	2565	1959	1621	1597	1704	1717	1940	2283
	CDH26.7	12086	1347	1602	1633	1268	1126	750	554	556	653	668	827	1101
(14) Wind	WSAvg	1.4	1.4	1.6	1.8	1.7	1.5	1.4	1.3	1.3	1.4	1.3	1.2	1.2
(15) Precipitation	PrecAvg	1511	16	37	106	132	157	152	187	219	189	196	76	25
	PrecMax	1849	86	93	338	261	279	267	374	376	346	516	204	91
	PrecMin	1272	0	0	11	26	21	68	74	66	83	82	19	0
	PrecStd	165	20	28	54	56	60	55	56	73	57	74	37	24
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.2	37.9	37.2	36.1	36.1	34.2	33.2	33.1	33.9	34.0	34.8	35.1
		MCWB	20.8	21.4	23.4	25.2	24.7	25.1	25.1	25.0	25.1	25.2	23.6	21.8
	2%	DB	35.1	36.7	36.1	35.1	34.9	33.1	32.1	32.0	32.8	32.9	33.4	34.1
		MCWB	20.8	22.1	24.1	25.2	25.0	25.1	24.8	24.8	24.7	25.1	24.3	21.9
	5%	DB	34.2	35.8	35.0	34.0	33.4	32.0	31.0	31.0	31.8	31.9	32.6	33.1
		MCWB	20.7	22.1	24.3	24.9	25.1	24.8	24.6	24.6	24.6	24.8	24.4	22.1
	10%	DB	33.1	34.2	33.9	32.9	32.1	30.9	30.0	30.0	30.5	30.8	31.2	32.1
		MCWB	20.8	22.5	24.5	25.0	24.9	24.7	24.5	24.6	24.5	24.6	24.5	22.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.2	27.1	27.1	27.7	27.0	26.6	26.6	26.6	26.6	26.7	27.0	26.3
		MCDB	32.3	32.6	32.3	32.2	32.0	31.0	30.3	30.1	30.5	31.1	30.3	30.9
	2%	WB	25.4	25.9	26.2	26.5	26.1	25.9	25.7	25.7	25.7	25.8	26.0	25.6
		MCDB	31.2	32.0	32.3	31.9	31.2	30.4	29.8	29.6	29.9	30.4	30.7	30.4
	5%	WB	24.7	25.3	25.7	25.8	25.7	25.5	25.2	25.2	25.2	25.3	25.5	25.1
		MCDB	30.1	31.4	31.8	31.2	30.6	29.9	29.3	29.2	29.6	29.9	30.2	29.8
	10%	WB	24.2	24.8	25.2	25.4	25.3	25.1	24.8	24.7	24.8	24.9	25.0	24.6
		MCDB	29.2	30.7	31.1	30.7	30.1	29.4	28.6	28.6	29.1	29.3	29.8	29.0
(35) Mean Daily Temperature Range	5% DB	MDBR	15.4	13.2	11.2	10.1	9.6	8.9	8.2	8.4	9.2	9.3	10.2	13.2
		MCDBR	16.4	15.3	12.7	12.0	11.6	10.7	10.2	10.2	10.9	11.2	12.1	14.6
		MCWBR	5.4	5.1	3.8	4.1	4.0	3.9	4.2	4.3	4.3	4.6	4.7	5.2
	5% WB	MCDBR	12.8	12.0	11.5	10.8	10.4	9.5	9.2	9.2	10.0	10.2	10.6	11.5
		MCWBR	5.2	4.8	4.5	4.6	4.3	4.2	4.4	4.5	4.6	4.7	5.0	5.3
(40) Clear-Sky Solar Irradiance	taub		0.591	0.633	0.653	0.493	0.449	0.465	0.482	0.456	0.429	0.437	0.518	0.588
	taud		1.856	1.785	1.753	2.192	2.346	2.283	2.213	2.276	2.373	2.368	2.103	1.876
	Ebn at Noon		748	729	716	825	842	816	807	845	883	881	804	742
	Edh at Noon		210	230	238	151	125	131	142	137	126	127	163	203
(44) All-Sky Solar Radiation	RadAvg		5.78	5.50	5.43	5.34	5.11	4.66	4.40	4.52	5.00	4.94	5.13	5.50
	RadStd		0.31	0.33	0.29	0.25	0.20	0.18	0.22	0.25	0.18	0.25	0.21	0.24

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page