

YAOUNDE, Cameroon

WMO: 649500

Lat: 3.723N

Lon: 11.553E

Elev: 694

StdP: 93.26

Time Zone: 1.00 (E01)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.9	18.1	12.0	9.5	25.3	14.9	11.5	23.4	5.4	24.8	5.2	24.8	0.2	0	0.205

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	10.2	32.2	22.7	31.8	22.8	31.0	23.0	25.7	28.9	25.2	28.5	24.9	28.1	2.0	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.0	21.9	28.0	24.2	20.9	27.0	24.0	20.6	26.8	84.4	29.1	82.3	28.8	80.5	28.3	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
4.8	4.2	3.7	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	13.4	25.8	2.2	1.5	11.8	26.9	10.5	27.8	9.2	28.6	7.6	29.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.6	25.0	25.8	25.7	25.4	24.8	24.0	23.4	23.4	23.8	24.4	24.6	24.6
	DBStd	1.39	1.35	1.39	1.23	1.29	1.19	1.22	1.05	1.01	1.04	0.94	0.99	1.00
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5316	464	441	487	462	460	421	417	414	413	446	438	454
	CDD18.3	2274	206	208	228	212	202	171	158	156	163	188	188	196
	CDH23.3	12553	1450	1494	1542	1412	1173	740	527	483	624	857	997	1254
Wind	WSAvg	1.6	1.4	1.7	1.7	1.5	1.3	1.6	1.9	2.1	1.8	1.5	1.2	1.1
	PrecAvg	1651	23	52	132	185	202	133	99	130	225	289	149	32
	PrecMax	1944	54	169	213	267	317	195	178	244	338	356	297	91
	PrecMin	1295	3	4	55	112	128	59	32	21	128	221	42	4
	PrecStd	177	13	34	41	38	38	33	40	57	52	38	56	21
	DB	32.1	33.2	33.2	33.0	32.0	30.2	29.2	29.1	30.0	31.0	31.1	31.2	31.2
	MCWB	21.2	22.0	23.0	23.5	23.6	23.4	23.0	22.9	22.6	23.3	23.5	22.0	22.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	31.2	32.1	32.1	31.9	30.9	29.2	28.1	28.0	28.9	29.9	30.1	30.2	30.2
	2% MCWB	21.6	22.0	23.2	23.8	23.6	23.4	22.9	22.8	23.1	23.1	23.2	21.8	21.8
	5% DB	30.8	31.2	31.1	30.9	30.0	28.2	27.1	27.0	28.0	29.0	29.2	29.9	29.9
	5% MCWB	21.7	22.6	23.6	24.0	23.8	23.3	22.6	22.5	22.8	23.1	23.3	21.8	21.8
	10% DB	29.8	30.2	30.0	29.9	28.9	27.1	26.1	26.0	27.0	27.9	28.8	29.1	29.1
	10% MCWB	21.8	22.9	23.8	24.1	23.9	22.9	22.3	22.2	22.7	22.8	23.3	22.4	22.4
	WB	25.5	26.1	26.2	26.2	26.0	25.0	24.5	24.2	24.6	24.7	25.5	25.3	25.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% MCDB	28.3	29.5	29.6	29.2	28.7	27.6	26.9	26.8	27.3	28.5	28.5	28.0	28.0
	2% WB	24.4	25.2	25.4	25.6	25.3	24.3	23.8	23.7	24.1	24.1	24.7	24.6	24.6
	2% MCDB	27.7	28.6	29.0	29.0	28.2	27.3	26.4	26.3	26.8	28.0	27.9	27.5	27.5
	5% WB	23.7	24.7	24.8	25.1	24.7	23.8	23.2	23.1	23.5	23.6	24.2	24.1	24.1
	5% MCDB	27.3	28.0	28.5	28.6	27.8	27.0	26.0	25.8	26.4	27.4	27.5	27.3	27.3
	10% WB	23.1	24.1	24.2	24.5	24.1	23.3	22.6	22.5	22.9	23.0	23.7	23.4	23.4
	10% MCDB	26.8	27.4	28.0	28.0	27.4	26.4	25.4	25.2	25.9	26.8	27.0	26.9	26.9
Mean Daily Temperature Range	MDBR	10.6	10.2	9.9	9.8	9.1	7.4	6.4	6.4	7.6	8.7	9.0	10.2	10.2
	5% DB MCDBR	11.4	11.4	11.1	11.1	10.4	8.8	7.6	7.5	8.6	9.8	9.9	10.9	10.9
	5% DB MCWBR	3.8	3.9	4.2	4.4	4.4	3.7	3.3	3.3	3.7	4.1	4.3	4.1	4.1
	5% WB MCDBR	9.4	9.9	10.1	9.6	9.1	8.1	7.1	6.8	7.9	9.0	9.0	9.4	9.4
	5% WB MCWBR	3.8	4.3	4.9	4.8	5.1	4.1	3.5	3.6	4.2	4.2	4.7	4.5	4.5
Clear-Sky Solar Irradiance	taub	0.676	0.731	0.704	0.489	0.435	0.440	0.447	0.427	0.400	0.414	0.501	0.628	0.628
	taud	1.665	1.592	1.650	2.200	2.378	2.348	2.307	2.351	2.440	2.414	2.133	1.764	1.764
	Ebn at Noon	684	660	681	828	854	837	835	869	909	903	820	711	711
	Edh at Noon	255	279	264	149	121	123	129	127	118	121	158	228	228
All-Sky Solar Radiation	RadAvg	5.17	4.93	4.89	4.97	4.70	3.97	3.67	3.63	4.23	4.43	4.67	4.96	4.96
	RadStd	0.28	0.29	0.23	0.16	0.20	0.27	0.25	0.28	0.20	0.14	0.16	0.24	0.24

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page