

SOKODE, Togo

WMO: 653610

Lat: 8.983N

Lon: 1.150E

Elev: 1270

StdP: 14.03

Time Zone: 0.00 (E00)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	63.9	65.8	28.1	23.1	79.6	31.9	27.5	80.7	12.2	77.3	11.1	78.8	1.3	280	0.246

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	21.4	98.3	72.4	96.8	71.9	95.3	71.7	80.3	90.9	79.3	89.5	78.6	88.4	4.3	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.5	149.7	85.3	76.8	146.5	84.5	76.0	142.6	83.3	45.0	90.9	44.0	89.7	43.1	88.7	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.2	10.2	8.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB												
			WB	49.4	82.8	1.4	1.9	48.4	84.2	47.6	85.3	46.8	86.4	45.8	87.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.4	80.5	83.6	84.7	83.4	81.6	79.7	77.6	76.8	77.7	79.6	80.4	79.3
	DBStd	3.32	2.70	2.42	2.30	2.72	2.53	2.26	2.15	1.84	1.96	1.92	1.89	2.44
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11091	946	942	1077	1002	980	890	857	829	832	916	912	908
	CDD65	5616	481	522	612	552	515	440	392	364	382	451	462	443
	CDH74	54653	5282	6484	7689	6400	5331	3679	2438	1968	2364	3745	4701	4572
	CDH80	24648	2631	3519	4134	3090	2297	1274	597	379	628	1510	2370	2219
Wind	WSAvg	2.4	2.7	3.0	2.9	2.8	2.3	2.1	1.9	2.3	2.0	2.0	2.2	2.8
Precipitation	PrecAvg	53.4	0.3	0.7	2.2	4.1	5.2	6.9	8.8	10.4	9.5	4.3	0.7	0.2
	PrecMax	81.4	8.7	7.5	8.5	7.1	11.1	15.7	16.5	19.5	15.7	13.0	6.4	2.7
	PrecMin	33.5	0.0	0.0	0.0	1.7	2.2	2.9	0.7	2.4	3.6	0.8	0.0	0.0
	PrecStd	10.2	1.3	1.3	1.7	1.4	1.9	2.5	3.1	3.7	3.0	2.5	1.4	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.0	100.1	100.5	98.6	95.3	92.4	89.7	87.3	89.6	93.4	96.3	96.4
		MCWB	68.7	71.2	72.4	77.4	78.3	79.1	77.0	76.4	77.6	74.9	70.4	68.4
	2%	DB	95.4	98.1	98.5	96.2	93.1	90.0	87.3	85.6	87.4	91.4	94.6	94.4
		MCWB	67.3	70.6	73.0	77.0	77.8	77.8	76.4	75.7	76.8	75.9	71.2	68.0
	5%	DB	93.6	96.4	96.8	94.3	91.4	88.2	85.1	83.9	85.7	89.8	93.1	92.7
		MCWB	66.4	70.3	72.6	77.3	77.9	77.2	75.9	75.2	76.5	76.3	71.6	67.6
	10%	DB	91.7	94.6	95.0	92.4	89.7	86.5	83.4	82.2	83.8	87.9	91.4	90.6
		MCWB	65.6	69.7	72.9	77.4	77.6	76.8	75.4	74.8	75.9	76.2	72.3	67.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.2	79.7	80.6	81.4	81.6	80.6	78.9	77.9	79.1	80.2	78.2	76.7
		MCDB	91.2	94.4	94.9	92.8	90.8	90.2	86.3	84.4	86.7	89.3	89.3	89.6
	2%	WB	74.0	77.3	78.9	80.0	80.0	79.1	77.4	76.5	77.9	78.4	76.8	75.0
		MCDB	88.0	90.8	92.2	91.3	89.4	87.3	84.4	82.7	85.1	87.1	88.0	87.3
	5%	WB	71.7	75.9	77.7	79.0	79.0	78.1	76.5	75.9	77.1	77.6	75.8	73.2
		MCDB	85.0	89.1	90.4	90.1	88.3	85.9	82.9	81.7	83.9	86.2	87.1	85.1
	10%	WB	69.5	74.5	76.6	78.2	78.2	77.2	75.8	75.2	76.3	76.8	75.0	71.3
		MCDB	84.4	87.3	88.6	88.8	87.1	84.7	81.8	80.7	82.4	85.1	86.0	82.9
Mean Daily Temperature Range		MDBR	24.7	23.4	21.4	18.2	16.8	14.9	12.7	11.8	13.9	18.2	24.6	25.6
	5% DB	MCDBR	27.3	26.0	24.3	21.3	19.1	17.4	15.4	14.4	16.5	20.9	26.6	28.0
		MCWBR	11.4	10.0	8.3	6.4	6.4	6.2	5.5	5.5	6.7	7.5	8.1	10.2
	5% WB	MCDBR	25.9	22.8	20.8	19.0	17.8	16.2	14.1	13.1	15.3	18.5	22.8	24.7
		MCWBR	12.4	8.7	7.1	7.0	7.3	6.8	5.8	5.7	6.8	7.7	8.0	10.6
Clear-Sky Solar Irradiance	taub	0.723	0.762	0.815	0.685	0.584	0.535	0.496	0.485	0.492	0.569	0.586	0.621	
	taud	1.589	1.543	1.467	1.727	1.911	2.053	2.207	2.240	2.200	1.945	1.853	1.769	
	Ebn at Noon	201	199	192	216	234	243	254	261	262	241	232	221	
	Edh at Noon	85	92	100	76	62	53	46	45	47	61	65	70	
All-Sky Solar Radiation	RadAvg	1662	1715	1794	1803	1742	1576	1382	1295	1454	1693	1746	1645	
	RadStd	53	49	72	51	58	56	55	61	64	62	42	57	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page