

ACCRA, Ghana

WMO: 654720

Lat: 5.605N

Lon: 0.167W

Elev: 205

StdP: 14.59

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	72.3	73.2	53.3	60.8	83.6	60.6	79.7	81.6	22.7	80.5	21.1	80.4	7.6	270	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	12.2	92.6	78.3	91.6	78.4	91.0	78.4	81.6	87.1	81.0	86.5	80.5	86.1	13.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.1	157.4	84.6	79.2	152.8	84.1	79.1	151.9	84.0	45.5	87.4	44.8	87.4	44.3	87.6	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 20.4	18.8	17.9	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			WB	60.3	83.0	6.9	0.8	55.4	83.6	51.4	84.1	47.5	84.5	42.6	85.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.2	83.8	84.7	84.7	84.2	82.9	80.4	79.1	78.5	80.2	81.7	83.2	83.6
	DBStd	2.71	1.33	1.52	1.87	2.18	2.25	1.92	1.49	1.39	1.41	1.48	1.49	1.78
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11762	1047	970	1077	1026	1021	912	901	883	906	982	996	1041
	CDD65	6287	582	550	612	576	556	462	436	418	456	517	546	576
	CDH74	64952	6461	6548	7451	6925	6266	4225	3169	2600	3577	5082	6124	6524
	CDH80	22137	2442	2704	3223	2908	2319	961	411	311	689	1453	2229	2487
Wind	WSAvg	9.5	8.3	10.3	9.9	9.5	8.5	9.2	11.0	11.7	11.3	9.2	8.0	7.6
Precipitation	PrecAvg	31.5	0.6	1.0	2.2	3.7	5.2	8.0	2.9	1.0	2.3	2.4	1.3	1.1
	PrecMax	55.7	4.4	6.6	8.0	10.6	10.9	28.1	14.6	4.8	10.9	6.3	4.5	5.0
	PrecMin	13.1	0.0	0.0	0.1	0.2	1.6	0.7	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	9.6	0.9	1.3	1.7	2.5	2.6	5.3	3.0	1.1	2.2	1.6	1.1	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.2	93.3	93.5	93.6	92.1	89.7	86.3	86.0	88.1	90.0	91.7	91.8
		MCWB	71.5	79.2	78.5	80.5	79.5	78.6	76.4	75.7	77.8	78.6	79.0	76.4
	2%	DB	91.4	91.6	91.8	91.8	91.0	87.7	84.6	84.3	86.4	89.0	90.2	91.0
		MCWB	74.7	79.0	79.1	79.7	79.2	78.6	75.8	75.2	77.0	78.3	78.8	77.1
	5%	DB	89.9	90.9	91.2	91.0	89.7	86.1	83.9	82.8	85.6	87.8	89.5	89.8
		MCWB	75.8	78.9	79.1	79.5	79.0	78.0	75.6	74.7	76.6	78.1	78.6	77.3
	10%	DB	89.1	89.6	89.8	89.6	88.1	84.5	82.4	82.0	84.1	86.3	88.1	88.9
		MCWB	76.2	78.8	78.9	79.1	78.9	77.4	75.1	74.5	76.2	77.9	78.7	77.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	81.8	81.8	82.8	81.4	80.1	78.1	76.8	80.0	81.5	81.0	81.0
		MCDB	85.8	86.5	87.0	88.8	87.5	85.3	82.7	82.3	85.3	87.0	87.8	87.3
	2%	WB	80.1	81.0	81.0	81.6	80.5	79.2	77.2	76.2	78.1	79.6	80.1	80.1
		MCDB	84.9	85.9	86.6	87.4	86.7	84.2	81.5	81.2	83.6	85.2	86.6	86.1
	5%	WB	79.7	80.5	80.6	80.9	80.0	78.8	76.5	75.6	77.3	78.9	79.6	79.6
		MCDB	84.7	85.5	86.3	86.6	86.0	83.7	80.6	80.0	82.4	84.4	86.0	85.5
	10%	WB	79.2	80.0	80.1	80.1	79.5	78.2	76.2	75.2	76.6	78.3	79.1	79.1
		MCDB	84.3	85.2	85.9	85.9	85.4	82.9	80.2	79.2	81.3	83.6	85.3	84.9
Mean Daily Temperature Range	5% DB	MDBR	13.0	11.8	12.2	12.0	11.5	9.5	8.0	8.1	9.6	11.4	12.0	12.8
		MCDBR	13.7	12.8	12.8	13.1	12.6	11.2	9.5	9.4	11.1	12.5	12.9	13.4
		MCWBR	5.9	4.1	4.7	4.3	4.4	3.2	3.2	3.2	3.9	4.4	4.5	5.2
	5% WB	MCDBR	12.3	11.7	12.2	12.2	12.0	10.4	8.4	8.5	10.3	11.8	12.3	12.5
		MCWBR	4.7	4.0	4.7	4.6	4.7	4.5	3.2	3.2	4.1	4.6	4.7	4.7
Clear-Sky Solar Irradiance	taub		0.811	0.797	0.791	0.620	0.528	0.516	0.527	0.523	0.486	0.489	0.572	0.694
	taud		1.522	1.560	1.559	1.895	2.116	2.155	2.110	2.123	2.255	2.255	1.972	1.720
	Ebn at Noon		186	195	198	231	247	246	245	251	265	265	239	208
	Edh at Noon		93	91	92	64	50	48	50	50	45	45	59	75
All-Sky Solar Radiation	RadAvg		1644	1663	1710	1721	1581	1345	1428	1438	1538	1701	1699	1618
	RadStd		49	56	65	62	67	74	92	79	57	56	39	36

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page