

OUAHIGOUYA, Burkina Faso

WMO: 655020

Lat: 13.567N

Lon: 2.417W

Elev: 1102

StdP: 14.12

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	62.4	64.4	9.2	9.2	85.7	13.1	11.1	85.0	16.9	85.5	14.4	84.7	2.7	40	0.379

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	20.0	105.8	68.2	104.5	68.4	103.2	68.5	78.8	89.8	78.1	89.0	77.5	88.4	5.6	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.3	143.0	82.7	75.6	139.5	82.3	75.0	136.9	82.0	43.2	90.0	42.5	89.1	41.9	88.5	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.9	14.4	12.3	57.8	109.6	1.0	0.9	57.1	110.3	56.5	110.8	55.9	111.3	55.2	111.9		
			42.8	80.6	1.1	1.3	42.1	81.6	41.4	82.4	40.8	83.1	40.0	84.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	84.8	76.7	82.0	88.8	93.0	92.8	88.6	83.2	80.6	82.4	86.5	84.6	78.7	(6)
(7)		DBStd	6.17	3.79	5.23	4.32	3.05	3.69	4.12	3.47	2.72	2.98	2.57	2.52	3.54	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	12711	827	895	1204	1290	1328	1157	1030	950	972	1131	1038	889	(10)
(11)		CDD65	7236	362	475	739	840	863	707	565	485	522	666	588	424	(11)
(12)		CDH74	97953	3744	6084	11381	13808	14014	10389	6785	4804	5888	8914	7623	4519	(12)
(13)		CDH80	56793	1672	3360	7323	9527	9607	6325	3169	1717	2587	4941	4386	2179	(13)
(14)	Wind	WSAvg	4.9	4.3	5.3	4.8	5.6	6.7	7.3	6.0	4.4	4.1	3.8	3.1	3.9	(14)
(15)	Precipitation	PrecAvg	25.2	0.0	0.0	0.1	0.4	1.1	3.7	6.5	8.3	4.6	1.2	0.0	0.0	(15)
(16)		PrecMax	39.0	0.2	0.4	1.0	2.5	4.7	7.1	11.4	15.7	9.4	5.9	1.2	0.4	(16)
(17)		PrecMin	14.1	0.0	0.0	0.0	0.0	0.0	0.4	2.6	3.2	1.3	0.0	0.0	0.0	(17)
(18)		PrecStd	6.7	0.0	0.0	0.2	0.6	0.9	1.7	2.1	3.1	1.7	1.3	0.2	0.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	96.9	103.9	106.1	107.4	108.0	104.3	98.7	93.3	97.1	101.0	100.7	97.2	(19)	
(20)		MCWB	60.7	62.5	64.9	67.7	70.0	73.5	75.2	78.0	76.2	68.5	65.3	62.6	(20)	
(21)		DB	93.4	100.4	104.3	105.8	105.9	102.0	95.8	91.1	94.6	99.4	99.0	94.7	(21)	
(22)		MCWB	59.2	62.2	64.5	67.3	70.7	74.7	75.4	77.1	76.8	69.4	64.7	61.1	(22)	
(23)		DB	90.9	97.8	102.9	104.5	104.4	100.0	93.7	89.5	92.6	97.9	97.7	92.8	(23)	
(24)		MCWB	57.9	61.6	64.1	67.4	71.5	74.8	75.7	76.9	76.8	70.5	64.2	60.2	(24)	
(25)		DB	88.4	95.1	101.1	103.0	102.7	97.8	91.5	87.7	90.7	96.2	96.2	90.5	(25)	
(26)		MCWB	57.3	60.8	63.7	67.3	72.3	74.6	75.8	76.6	76.6	71.8	63.6	59.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	65.4	69.0	74.2	77.8	78.7	78.4	79.0	79.2	79.9	78.9	72.6	66.3	(27)	
(28)		MCD B	84.2	88.0	91.4	96.8	95.8	91.1	90.4	88.6	90.7	90.0	91.0	91.0	(28)	
(29)		WB	62.2	66.4	71.3	75.5	77.5	77.6	77.9	78.3	78.9	77.7	70.5	63.7	(29)	
(30)		MCD B	89.1	91.6	94.5	94.2	94.5	91.5	88.7	87.0	89.1	89.1	89.1	90.0	(30)	
(31)		WB	60.1	63.8	69.2	74.4	76.5	76.9	77.2	77.7	78.1	76.9	68.7	62.2	(31)	
(32)		MCD B	87.0	93.1	93.9	93.8	93.9	91.8	87.7	86.2	88.0	88.4	89.2	89.0	(32)	
(33)		WB	58.3	61.9	66.8	73.4	75.9	76.3	76.7	77.2	77.4	76.1	66.3	60.8	(33)	
(34)		MCD B	85.8	93.2	95.3	93.7	93.7	91.3	86.9	85.2	86.9	87.8	90.7	87.8	(34)	
(35)	Mean Daily Temperature Range	MDBR	23.2	23.6	23.1	20.0	18.6	16.9	14.8	13.0	15.4	20.3	25.2	24.0	(35)	
(36)		5% DB	26.2	26.6	24.7	21.9	20.6	18.6	17.4	15.2	18.3	22.4	25.8	26.3	(36)	
(37)		MCWBR	10.1	10.0	8.9	8.1	6.3	4.7	4.2	4.8	5.4	6.1	8.7	9.8	(37)	
(38)		5% WB	24.0	24.2	20.4	17.6	18.1	16.9	15.1	14.0	16.5	18.4	22.8	24.3	(38)	
(39)		MCWBR	10.3	10.5	9.8	6.7	5.7	4.9	5.2	5.5	6.4	5.7	8.4	10.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.534	0.580	0.700	0.713	0.710	0.681	0.610	0.565	0.554	0.586	0.526	0.500	(40)	
(41)		taud	1.825	1.708	1.497	1.563	1.564	1.644	1.826	1.930	1.937	1.828	1.850	1.901	(41)	
(42)		Ebn at Noon	242	237	213	211	207	211	227	241	245	233	242	247	(42)	
(43)		Edh at Noon	65	76	96	90	88	81	67	62	61	67	63	59	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1759	1926	2035	2071	2014	1898	1850	1788	1909	1912	1807	1708	(44)	
(45)		RadStd	87	95	112	106	73	68	65	92	55	44	44	65	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page