

OUAHIGOUYA, Burkina Faso

WMO: 655020

Lat: 13.567N

Lon: 2.417W

Elev: 336

StdP: 97.35

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.9	18.0	-12.7	1.3	29.8	-10.5	1.6	29.4	7.5	29.7	6.5	29.3	1.2	40	0.379

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	11.1	41.0	20.1	40.3	20.2	39.5	20.3	26.0	32.1	25.6	31.7	25.3	31.3	2.5	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.6	20.4	28.2	24.2	19.9	27.9	23.9	19.6	27.8	82.6	32.2	80.9	31.7	79.6	31.4	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.4	5.5	DB	14.4	43.1	0.6	0.5	13.9	43.5	13.6	43.8	13.3	44.0	12.9	44.4	(4)
(5)			WB	6.0	27.0	0.6	0.7	5.6	27.5	5.2	28.0	4.9	28.4	4.5	28.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	29.3	24.8	27.8	31.6	33.9	33.8	31.4	28.5	27.0	28.0	30.3	29.2	25.9	(6)
(7)		DBStd	3.43	2.11	2.90	2.40	1.70	2.05	2.29	1.93	1.51	1.65	1.43	1.40	1.97	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	7062	459	497	669	717	738	643	572	528	540	628	577	494	(10)
(11)		CDD18.3	4020	201	264	411	467	479	393	314	269	290	370	327	236	(11)
(12)		CDH23.3	54418	2080	3380	6323	7671	7786	5772	3769	2669	3271	4952	4235	2511	(12)
(13)		CDH26.7	31552	929	1867	4068	5293	5337	3514	1761	954	1437	2745	2437	1211	(13)
(14)	Wind	WSAvg	2.2	1.9	2.4	2.2	2.5	3.0	3.3	2.7	2.0	1.8	1.7	1.4	1.8	(14)
(15)	Precipitation	PrecAvg	640	0	0	2	9	29	93	165	211	117	31	1	0	(15)
(16)		PrecMax	991	4	9	25	64	119	180	289	399	239	150	30	10	(16)
(17)		PrecMin	358	0	0	0	0	0	9	67	82	33	0	0	0	(17)
(18)		PrecStd	169	1	1	4	15	24	44	53	80	44	34	5	1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.0	40.0	41.1	41.9	42.2	40.2	37.0	34.0	36.1	38.3	38.1	36.2	(19)
(20)			MCWB	15.9	16.9	18.3	19.8	21.1	23.1	24.0	25.5	24.6	20.3	18.5	17.0	(20)
(21)		2%	DB	34.1	38.0	40.2	41.0	41.1	38.9	35.4	32.8	34.8	37.5	37.2	34.9	(21)
(22)			MCWB	15.1	16.8	18.0	19.6	21.5	23.7	24.1	25.0	24.9	20.8	18.2	16.1	(22)
(23)		5%	DB	32.7	36.6	39.4	40.3	40.2	37.8	34.3	31.9	33.6	36.6	36.5	33.8	(23)
(24)			MCWB	14.4	16.5	17.8	19.7	22.0	23.8	24.3	25.0	24.9	21.4	17.9	15.7	(24)
(25)		10%	DB	31.3	35.0	38.4	39.5	39.3	36.6	33.1	31.0	32.6	35.6	35.6	32.5	(25)
(26)			MCWB	14.0	16.0	17.6	19.6	22.4	23.7	24.3	24.8	24.8	22.1	17.5	15.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.6	20.6	23.5	25.4	25.9	25.8	26.1	26.2	26.6	26.1	22.6	19.0	(27)
(28)			MCD B	29.0	31.1	33.0	36.0	35.4	32.8	32.4	31.5	32.6	32.2	32.8	32.8	(28)
(29)		2%	WB	16.8	19.1	21.8	24.2	25.3	25.3	25.5	25.7	26.1	25.4	21.4	17.6	(29)
(30)			MCD B	31.7	33.1	34.7	34.5	34.7	33.1	31.5	30.6	31.7	31.7	31.7	32.2	(30)
(31)		5%	WB	15.6	17.7	20.7	23.6	24.7	25.0	25.1	25.4	25.6	24.9	20.4	16.8	(31)
(32)			MCD B	30.6	34.0	34.4	34.3	34.4	33.2	30.9	30.1	31.1	31.4	31.8	31.7	(32)
(33)		10%	WB	14.6	16.6	19.3	23.0	24.4	24.6	24.8	25.1	25.2	24.5	19.0	16.0	(33)
(34)			MCD B	29.9	34.0	35.1	34.3	34.3	32.9	30.5	29.6	30.5	31.0	32.6	31.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.9	13.1	12.8	11.1	10.3	9.4	8.2	7.2	8.6	11.3	14.0	13.3	(35)
(36)			MCDBR	14.6	14.8	13.7	12.1	11.4	10.4	9.7	8.4	10.2	12.5	14.3	14.6	(36)
(37)			MCWBR	5.6	5.5	5.0	4.5	3.5	2.6	2.3	2.7	3.0	3.4	4.8	5.5	(37)
(38)		5% WB	MCD BR	13.3	13.5	11.4	9.8	10.1	9.4	8.4	7.8	9.2	10.2	12.7	13.5	(38)
(39)			MCWBR	5.7	5.8	5.4	3.7	3.2	2.7	2.9	3.0	3.5	3.2	4.6	5.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.534	0.580	0.700	0.713	0.710	0.681	0.610	0.565	0.554	0.586	0.526	0.500	(40)	
(41)		taud	1.825	1.708	1.497	1.563	1.564	1.644	1.826	1.930	1.937	1.828	1.850	1.901	(41)	
(42)		Ebn at Noon	762	748	673	664	654	664	717	759	771	734	764	779	(42)	
(43)		Edh at Noon	206	241	304	284	278	254	212	194	193	211	199	187	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.55	6.07	6.42	6.53	6.35	5.98	5.83	5.64	6.02	6.03	5.70	5.39	(44)	
(45)		RadStd	0.27	0.30	0.35	0.34	0.23	0.21	0.21	0.29	0.17	0.14	0.14	0.20	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page